

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



Property Reference	SECANG003b			Issued on Date	04/02/2021
Assessment Reference	001	Prop Type Ref	Det Br Ea Ga		
Property	Coniston+, Plot 57				
SAP Rating	84 B	DER	16.70	TER	17.21
Environmental	36 B	% DER<TER	2.95		
CO ₂ Emissions (t/year)	1.55	DPFE	50.16	TFEE	54.68
General Requirements Compliance	Pass	% DPFE<TFEE	8.27		
Assessor Details	Mr. Stuart Harvey, Stuart Harvey, [REDACTED]			Assessor ID	T555-0001
Client	Persimon Homes Thames Valley				

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



REGULATIONS COMPLIANCE REPORT - Approved Document L1A, 2013 Edition, England

REGULATIONS COMPLIANCE REPORT - Approved Document L1A, 2013 Edition, England

DWELLING AS DESIGNED

Detached House, total floor area 113 m²

This report covers items included within the SAP calculations.
It is not a complete report of regulations compliance.

1a TER and DER

Fuel for main heating: Mains gas
Fuel factor: 1.00 (mains gas)
Target Carbon Dioxide Emission Rate (TER) 17.21 kgCO₂/m²
Dwelling Carbon Dioxide Emission Rate (DER) 16.70 kgCO₂/m² OK

1b TFEE and DFEE

Target Fabric Energy Efficiency (TFEE) 54.7 kWh/m²/yr
Dwelling Fabric Energy Efficiency (DFEE) 50.2 kWh/m²/yr OK

2 Fabric U-values

Element	Average	Highest	
External wall	0.25 (max. 0.30)	0.25 (max. 0.70)	OK
Party wall	0.00 (max. 0.20)	-	OK
Floor	0.19 (max. 0.25)	0.19 (max. 0.70)	OK
Roof	0.11 (max. 0.20)	0.11 (max. 0.35)	OK
Openings	1.34 (max. 2.00)	1.60 (max. 3.30)	OK

2a Thermal bridging

Thermal bridging calculated from linear thermal transmittances for each junction

3 Air permeability

Air permeability at 50 pascals: 5.00 (design value)
Maximum 10.0 OK

4 Heating efficiency

Main heating system: Boiler system with radiators or underfloor - Mains gas
Data from database
Ideal LOGIC COMBI ESP1 35
Combi boiler
Efficiency: 89.6% SEDBUK2009
Minimum: 88.0% OK

Secondary heating system:

None

5 Cylinder insulation

Hot water storage No cylinder

6 Controls

Space heating controls: Time and temperature zone control OK

Hot water controls:

No cylinder

Boiler interlock

Yes OK

7 Low energy lights

Percentage of fixed lights with low-energy fittings: 100%
Minimum 75% OK

8 Mechanical ventilation

Not applicable

9 Summertime temperature

Overheating risk (Thames Valley): Slight OK

Based on:


Overshading: Average
Windows facing North: 7.24 m², No overhang
Windows facing East: 0.84 m², No overhang
Windows facing South: 8.32 m², No overhang
Windows facing West: 1.44 m², No overhang
Air change rate: 4.00 ach
Blinds/curtains: None

10 Key features

Party wall U-value 0.00 W/m²K
Roof U-value 0.11 W/m²K
Roof U-value 0.11 W/m²K
Thermal bridging y-value 0.039 W/m²K

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF DWELLING EMISSIONS FOR REGULATIONS COMPLIANCE 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF DWELLING EMISSIONS FOR REGULATIONS COMPLIANCE 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n) =	274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m3 per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =				40.0000 / (5) =	0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor			(20) = 1 - [0.075 x (19)] =		0.8500 (20)
Infiltration rate adjusted to include shelter factor			(21) = (18) x (20) =		0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000 (22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750 (22a)
Adj infilt rate	0.4290	0.4206	0.4122	0.3701	0.3617	0.3196	0.3196	0.3112	0.3365	0.3617	0.3785	0.3954 (22b)
Effective ac	0.5920	0.5884	0.5849	0.5685	0.5654	0.5511	0.5511	0.5484	0.5566	0.5654	0.5716	0.5782 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Opening Type 1			2.1500	1.4000	3.0100		(26)
Opening Type 2 (Uw = 1.30)			17.8400	1.2357	22.0456		(27)
Opening Type 3			2.1500	1.6000	3.4400		(26a)
Heat Loss Floor 1			56.8600	0.1900	10.8034	75.0000	4264.5000 (28a)
Brick Cavity	149.5100	22.1400	127.3700	0.2500	31.8425	60.0000	7642.2000 (29a)
Main Plane	55.8100		55.8100	0.1100	6.1391	9.0000	502.2900 (30)
Bay Roof	1.5000		1.5000	0.1100	0.1650	9.0000	13.5000 (30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)				(26)...(30) + (32) =	77.4456		(33)
Internal Wall 1			73.8800			75.0000	5541.0000 (32c)
Internal Wall 2			199.2400			9.0000	1793.1600 (32c)
Internal Floor 1			55.8100			18.0000	1004.5800 (32d)
Internal Ceiling 1			55.8100			18.0000	1004.5800 (32e)
Heat capacity Cm = Sum(A x k)						(28)...(30) + (32) + (32a)...(32e) =	21765.8100 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							193.1819 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							10.3899 (36)
Total fabric heat loss						(33) + (36) =	87.8355 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m	53.5816	53.2582	52.9412	51.4523	51.1737	49.8769	49.8769	49.6368	50.3764	51.1737	51.7373	52.3265 (38)
Heat transfer coeff	141.4171	141.0937	140.7767	139.2878	139.0092	137.7124	137.7124	137.4723	138.2119	139.0092	139.5728	140.1619 (39)
Average = Sum(39)m / 12 =												139.2865 (39)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP	1.2551	1.2523	1.2495	1.2362	1.2338	1.2223	1.2223	1.2201	1.2267	1.2338	1.2388	1.2440 (40)
HLP (average)												1.2362 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)

Regs Region: England

Elmhurst Energy Systems

SAP2012 Calculator (Design

System) version 4.14r16

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF DWELLING EMISSIONS FOR REGULATIONS COMPLIANCE 09 Jan 2014

Energy content (annual)												Total = Sum(45)m =	1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m	24.8143	21.7027	22.3953	19.5247	18.7345	16.1664	14.9806	17.1904	17.3957	20.2730	22.1296	24.0313 (46)	
Water storage loss:													
Total storage loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)	
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)	
Combi loss	14.1536	12.7725	14.1149	13.6233	14.0423	13.5489	13.9753	14.0188	13.5894	14.0809	13.6669	14.1411 (61)	
Total heat required for water heating calculated for each month	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (62)	
Solar input	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63)	
								Solar input (sum of months) = Sum(63)m =					0.0000 (63)
Output from w/h	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (64)	
								Total per year (kWh/year) = Sum(64)m =					1761.3181 (64)
Heat gains from water heating, kWh/month	58.5434	51.3009	53.1716	46.6857	45.0386	39.2228	36.7007	41.6101	41.9579	48.4588	52.4707	56.8047 (65)	

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	25.6620	22.7928	18.5363	14.0332	10.4900	8.8561	9.5693	12.4386	16.6950	21.1981	24.7414	26.3753	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	275.3376	278.1948	270.9948	255.6671	236.3186	218.1337	205.9850	203.1279	210.3278	225.6556	245.0041	263.1890	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	78.6874	76.3406	71.4672	64.8412	60.5358	54.4761	49.3289	55.9275	58.2748	65.1328	72.8759	76.3504	(72)
Total internal gains	448.1361	445.7772	429.4474	402.9906	375.7934	349.9149	333.3324	339.9431	353.7467	380.4355	411.0704	434.3637	(73)

6. Solar gains

[Jan]				Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Access factor Table 6d	Gains W			
North				7.2400	10.6334	0.4400	0.0000	0.7700	26.0828 (74)			
East				0.8400	19.6403	0.4400	0.0000	0.7700	5.5895 (76)			
South				8.3200	46.7521	0.4400	0.0000	0.7700	131.7855 (78)			
West				1.4400	19.6403	0.4400	0.0000	0.7700	9.5819 (80)			
Solar gains	173.0396	295.3546	408.5059	518.0630	594.4316	597.2395	572.7804	514.1381	445.8784	327.3442	207.3041	148.0949 (83)
Total gains	621.1757	741.1318	837.9533	921.0536	970.2250	947.1544	906.1128	854.0812	799.6250	707.7797	618.3746	582.4586 (84)

7. Mean internal temperature (heating season)


Temperature during heating periods in the living area from Table 9, Th1 (C)												21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)												
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
tau	42.7534	42.8514	42.9479	43.4069	43.4939	43.9035	43.9035	43.9802	43.7448	43.4939	43.3183	43.1362
alpha	3.8502	3.8568	3.8632	3.8938	3.8996	3.9269	3.9269	3.9320	3.9163	3.8996	3.8879	3.8757
util living area	0.9957	0.9910	0.9808	0.9545	0.8921	0.7674	0.6158	0.6641	0.8602	0.9675	0.9920	0.9966 (86)
MIT	19.2692	19.4728	19.7878	20.1962	20.5738	20.8455	20.9521	20.9348	20.7344	20.2410	19.6780	19.2341 (87)
Th 2	19.8761	19.8784	19.8806	19.8911	19.8931	19.9022	19.9022	19.9039	19.8987	19.8931	19.8891	19.8850 (88)
util rest of house	0.9945	0.9885	0.9752	0.9399	0.8543	0.6829	0.4846	0.5365	0.7975	0.9543	0.9893	0.9957 (89)
MIT 2	17.5711	17.8692	18.3277	18.9197	19.4401	19.7801	19.8793	19.8695	19.6591	18.9925	18.1768	17.5255 (90)
Living area fraction	fLA = Living area / (4) =											0.1278 (91)
MIT	17.7881	18.0741	18.5143	19.0829	19.5850	19.9163	20.0164	20.0057	19.7965	19.1521	18.3687	17.7439 (92)
Temperature adjustment												-0.1500
adjusted MIT	17.6381	17.9241	18.3643	18.9329	19.4350	19.7663	19.8664	19.8557	19.6465	19.0021	18.2187	17.5939 (93)

8. Space heating requirement

Utilisation	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
	0.9906	0.9818	0.9641	0.9227	0.8346	0.6708	0.4799	0.5302	0.7795	0.9389	0.9830	0.9926	(94)
Useful gains	615.3622	727.6421	807.8292	849.8632	809.7873	635.3122	434.8723	452.8260	623.2754	664.5146	607.8607	578.1388	(95)
Ext temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	(96)
Heat loss rate W	1886.2416	1837.6205	1670.2229	1397.4538	1075.2322	711.4638	449.8275	475.0579	766.5950	1167.9662	1551.8640	1877.3137	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(97a)
Space heating kWh	945.5343	745.9055	641.6209	394.2653	197.4910	0.0000	0.0000	0.0000	0.0000	374.5680	679.6824	966.5861	(98)
Space heating												4945.6534	(98)
Space heating per m2												(98) / (4) =	43.8950 (99)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF DWELLING EMISSIONS FOR REGULATIONS COMPLIANCE 09 Jan 2014

8c. Space cooling requirement

Not applicable

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 11)												0.0000 (201)
Fraction of space heat from main system(s)												1.0000 (202)
Efficiency of main space heating system 1 (in %)												90.5000 (206)
Efficiency of secondary/supplementary heating system, %												0.0000 (208)
Space heating requirement												5464.8104 (211)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Space heating requirement	945.5343	745.9055	641.6209	394.2653	197.4910	0.0000	0.0000	0.0000	0.0000	374.5680	679.6824	966.5861 (98)
Space heating efficiency (main heating system 1)	90.5000	90.5000	90.5000	90.5000	90.5000	0.0000	0.0000	0.0000	0.0000	90.5000	90.5000	90.5000 (210)
Space heating fuel (main heating system)	1044.7892	824.2049	708.9734	435.6522	218.2221	0.0000	0.0000	0.0000	0.0000	413.8873	751.0303	1068.0510 (211)
Water heating requirement	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (215)
Water heating												
Water heating requirement	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (64)
Efficiency of water heater (217)m	89.9736	89.9255	89.8316	89.6221	89.1505	87.3000	87.3000	87.3000	87.3000	89.5647	89.8685	87.3000 (216)
Fuel for water heating, kWh/month	199.5943	175.0977	181.9146	160.4384	155.8474	138.9748	130.4075	147.3327	148.4088	166.6221	179.3704	193.7308 (219)
Water heating fuel used												1977.7395 (219)
Annual totals kWh/year												
Space heating fuel - main system												5464.8104 (211)
Space heating fuel - secondary												0.0000 (215)
Electricity for pumps and fans:												
central heating pump												30.0000 (230c)
main heating flue fan												45.0000 (230e)
Total electricity for the above, kWh/year												75.0000 (231)
Electricity for lighting (calculated in Appendix L)												453.1995 (232)
Total delivered energy for all uses												7970.7494 (238)

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating - main system 1	5464.8104	0.2160	1180.3990 (261)
Space heating - secondary	0.0000	0.0000	0.0000 (263)
Water heating (other fuel)	1977.7395	0.2160	427.1917 (264)
Space and water heating			1607.5908 (265)
Pumps and fans	75.0000	0.5190	38.9250 (267)
Energy for lighting	453.1995	0.5190	235.2106 (268)
Total CO2, kg/year			1881.7263 (272)
Dwelling Carbon Dioxide Emission Rate (DER)			16.7000 (273)

16 CO2 EMISSIONS ASSOCIATED WITH APPLIANCES AND COOKING AND SITE-WIDE ELECTRICITY GENERATION TECHNOLOGIES

DER		16.7000 ZC1
Total Floor Area	TFA	112.6700
Assumed number of occupants	N	2.8299
CO2 emission factor in Table 12 for electricity displaced from grid	EF	0.5190
CO2 emissions from appliances, equation (L14)		14.4812 ZC2
CO2 emissions from cooking, equation (L16)		1.6590 ZC3
Total CO2 emissions		32.8402 ZC4
Residual CO2 emissions offset from biofuel CHP		0.0000 ZC5
Additional allowable electricity generation, kWh/m²/year		0.0000 ZC6
Resulting CO2 emissions offset from additional allowable electricity generation		0.0000 ZC7
Net CO2 emissions		32.8402 ZC8

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF TARGET EMISSIONS 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF TARGET EMISSIONS 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m3 per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c)					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor				(20) = 1 - [0.075 x (19)] =	0.8500 (20)
Infiltration rate adjusted to include shelter factor				(21) = (18) x (20) =	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000 (22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750 (22a)
Adj infilt rate	0.4290	0.4206	0.4122	0.3701	0.3617	0.3196	0.3196	0.3112	0.3365	0.3617	0.3785	0.3954 (22b)
Effective ac	0.5920	0.5884	0.5849	0.5685	0.5654	0.5511	0.5511	0.5484	0.5566	0.5654	0.5716	0.5782 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
TER Opaque door			2.1500	1.0000	2.1500		(26)
TER Semi-glazed door			2.1500	1.2000	2.5800		(26a)
TER Opening Type (Uw = 1.40)			17.8400	1.3258	23.6515		(27)
Heat Loss Floor 1			56.8600	0.1300	7.3918		(28a)
Brick Cavity	149.5100	22.1400	127.3700	0.1800	22.9266		(29a)
Main Plane	55.8100		55.8100	0.1300	7.2553		(30)
Bay Roof	1.5000		1.5000	0.1300	0.1950		(30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)			(26)...(30) + (32) =		66.1502		(33)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							250.0000 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							12.6831 (36)
Total fabric heat loss						(33) + (36) =	78.8333 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)												
(38)m	53.5816	53.2582	52.9412	51.4523	51.1737	49.8769	49.8769	49.6368	50.3764	51.1737	51.7373	52.3265 (38)
Heat transfer coeff	132.4150	132.0916	131.7746	130.2856	130.0071	128.7103	128.7103	128.4701	129.2098	130.0071	130.5706	131.1598 (39)
Average = Sum(39)m / 12 =												130.2843 (39)
HLP	1.1752	1.1724	1.1696	1.1563	1.1539	1.1424	1.1424	1.1402	1.1468	1.1539	1.1589	1.1641 (40)
HLP (average)												1.1563 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)
Energy content (annual)										Total = Sum(45)m =		1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m												
24.8143	21.7027	22.3953	19.5247	18.7345	16.1664	14.9806	17.1904	17.3957	20.2730	22.1296	24.0313 (46)	
Water storage loss:												
Total storage loss												

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF TARGET EMISSIONS 09 Jan 2014

If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)
Combi loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)
Total heat required for water heating calculated for each month	50.9589	46.0274	50.9589	49.0107	48.5773	45.0098	46.5102	48.5773	49.0107	50.9589	49.3151	50.9589 (61)
Solar input	216.3875	190.7123	200.2608	179.1757	173.4737	152.7859	146.3805	163.1800	164.9822	186.1125	196.8457	211.1677 (62)
Output from w/h	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63)
Heat gains from water heating, kWh/month	216.3875	190.7123	200.2608	179.1757	173.4737	152.7859	146.3805	163.1800	164.9822	186.1125	196.8457	211.1677 (64)
	67.7447	59.6146	62.3826	55.5325	53.6724	47.0880	44.8344	50.2497	50.8132	57.6783	61.3827	66.0091 (65)

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	25.6620	22.7928	18.5363	14.0332	10.4900	8.8561	9.5693	12.4386	16.6950	21.1981	24.7414	26.3753	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	275.3376	278.1948	270.9948	255.6671	236.3186	218.1337	205.9850	203.1279	210.3278	225.6556	245.0041	263.1890	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	91.0547	88.7122	83.8476	77.1285	72.1403	65.4000	60.2613	67.5400	70.5739	77.5246	85.2538	88.7220	(72)
Total internal gains	460.5035	458.1488	441.8278	415.2779	387.3979	360.8388	344.2648	351.5555	366.0457	392.8273	423.4483	446.7353	(73)

6. Solar gains

[Jan]					Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Access factor Table 6d		Gains W	
North					7.2400	10.6334	0.6300	0.7000	0.7700		23.5278 (74)	
East					0.8400	19.6403	0.6300	0.7000	0.7700		5.0419 (76)	
South					8.3200	46.7521	0.6300	0.7000	0.7700		118.8765 (78)	
West					1.4400	19.6403	0.6300	0.7000	0.7700		8.6433 (80)	
Solar gains	156.0896	266.4233	368.4909	467.3164	536.2043	538.7372	516.6740	463.7760	402.2025	295.2793	186.9977	133.5883 (83)
Total gains	616.5931	724.5721	810.3187	882.5943	923.6022	899.5760	860.9388	815.3314	768.2483	688.1067	610.4460	580.3236 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)													21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
tau	59.0893	59.2340	59.3765	60.0550	60.1837	60.7901	60.7901	60.9037	60.5551	60.1837	59.9239	59.6548	
alpha	4.9393	4.9489	4.9584	5.0037	5.0122	5.0527	5.0527	5.0602	5.0370	5.0122	4.9949	4.9770	
util living area	0.9987	0.9968	0.9918	0.9751	0.9237	0.7960	0.6283	0.6792	0.8898	0.9831	0.9971	0.9990	(86)
MIT	19.6761	19.8341	20.0805	20.4040	20.7035	20.9101	20.9788	20.9689	20.8265	20.4372	19.9962	19.6500	(87)
Th 2	19.9399	19.9422	19.9444	19.9551	19.9571	19.9664	19.9664	19.9681	19.9628	19.9571	19.9530	19.9488	(88)
util rest of house	0.9982	0.9957	0.9887	0.9647	0.8896	0.7090	0.4954	0.5484	0.8284	0.9742	0.9959	0.9987	(89)
MIT 2	18.1711	18.4034	18.7638	19.2370	19.6498	19.9017	19.9581	19.9544	19.8149	19.2908	18.6485	18.1392	(90)
Living area fraction	18.3634	18.5863	18.9321	19.3862	19.7845	20.0306	20.0885	20.0840	19.9442	19.4373	18.8207	18.3323	(92)
Temperature adjustment	18.3634	18.5863	18.9321	19.3862	19.7845	20.0306	20.0885	20.0840	19.9442	19.4373	18.8207	18.3323	(93)
adjusted MIT	18.3634	18.5863	18.9321	19.3862	19.7845	20.0306	20.0885	20.0840	19.9442	19.4373	18.8207	18.3323	(93)

8. Space heating requirement

Utilisation	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Useful gains	0.9971	0.9935	0.9844	0.9571	0.8826	0.7151	0.5120	0.5644	0.8271	0.9678	0.9939	0.9979	(94)
Ext temp.	614.8353	719.8468	797.6429	844.7499	815.1603	643.3287	440.8399	460.1375	635.4065	665.9556	606.7082	579.0908	(95)
Heat loss rate W	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	(96)
Month fracti	1862.2108	1807.8426	1638.2318	1366.1966	1051.0404	698.9735	449.0086	473.2894	755.1253	1148.9126	1530.3840	1853.5919	(97)
Space heating kWh	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(97a)
Space heating	928.0474	731.1332	625.3982	375.4416	175.4948	0.0000	0.0000	0.0000	0.0000	359.3200	665.0466	948.2288	(98)
Space heating per m ²												4808.1106	(98)
												42.6743	(99)

8c. Space cooling requirement

Not applicable

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)

CALCULATION OF TARGET EMISSIONS 09 Jan 2014

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 11)													0.0000 (201)
Fraction of space heat from main system(s)													1.0000 (202)
Efficiency of main space heating system 1 (in %)													93.4000 (206)
Efficiency of secondary/supplementary heating system, %													0.0000 (208)
Space heating requirement													5147.8701 (211)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Space heating requirement	928.0474	731.1332	625.3982	375.4416	175.4948	0.0000	0.0000	0.0000	0.0000	359.3200	665.0466	948.2288	(98)
Space heating efficiency (main heating system 1)	93.4000	93.4000	93.4000	93.4000	93.4000	0.0000	0.0000	0.0000	0.0000	93.4000	93.4000	93.4000	(210)
Space heating fuel (main heating system)	993.6267	782.7979	669.5912	401.9717	187.8960	0.0000	0.0000	0.0000	0.0000	384.7109	712.0413	1015.2343	(211)
Water heating requirement	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(215)
Water heating requirement	216.3875	190.7123	200.2608	179.1757	173.4737	152.7859	146.3805	163.1800	164.9822	186.1125	196.8457	211.1677	(64)
Efficiency of water heater (217)m	88.3001	88.1073	87.7238	86.8701	85.0804	80.3000	80.3000	80.3000	80.3000	86.6799	87.8757	88.3754	(216)
Fuel for water heating, kWh/month	245.0593	216.4545	228.2855	206.2570	203.8939	190.2689	182.2921	203.2130	205.4572	214.7124	224.0048	238.9438	(219)
Water heating fuel used												2558.8425	(219)
Annual totals kWh/year													
Space heating fuel - main system												5147.8701	(211)
Space heating fuel - secondary												0.0000	(215)
Electricity for pumps and fans:													
central heating pump												30.0000	(230c)
main heating flue fan												45.0000	(230e)
Total electricity for the above, kWh/year												75.0000	(231)
Electricity for lighting (calculated in Appendix L)												453.1995	(232)
Total delivered energy for all uses												8234.9121	(238)

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating - main system 1	5147.8701	0.2160	1111.9399 (261)
Space heating - secondary	0.0000	0.0000	0.0000 (263)
Water heating (other fuel)	2558.8425	0.2160	552.7100 (264)
Space and water heating			1664.6499 (265)
Pumps and fans	75.0000	0.5190	38.9250 (267)
Energy for lighting	453.1995	0.5190	235.2106 (268)
Total CO2, kg/m2/year			1938.7855 (272)
Emissions per m2 for space and water heating			14.7746 (272a)
Fuel factor (mains gas)			1.0000
Emissions per m2 for lighting			2.0876 (272b)
Emissions per m2 for pumps and fans			0.3455 (272c)
Target Carbon Dioxide Emission Rate (TER) = (14.7746 * 1.00) + 2.0876 + 0.3455, rounded to 2 d.p.			17.2100 (273)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF FABRIC ENERGY EFFICIENCY 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF FABRIC ENERGY EFFICIENCY 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m3 per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c)					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor				(20) = 1 - [0.075 x (19)] =	0.8500 (20)
Infiltration rate adjusted to include shelter factor				(21) = (18) x (20) =	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000 (22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750 (22a)
Adj infilt rate	0.4290	0.4206	0.4122	0.3701	0.3617	0.3196	0.3196	0.3112	0.3365	0.3617	0.3785	0.3954 (22b)
Effective ac	0.5920	0.5884	0.5849	0.5685	0.5654	0.5511	0.5511	0.5484	0.5566	0.5654	0.5716	0.5782 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Opening Type 1			2.1500	1.4000	3.0100		(26)
Opening Type 2 (Uw = 1.30)			17.8400	1.2357	22.0456		(27)
Opening Type 3			2.1500	1.6000	3.4400		(26a)
Heat Loss Floor 1			56.8600	0.1900	10.8034	75.0000	4264.5000 (28a)
Brick Cavity	149.5100	22.1400	127.3700	0.2500	31.8425	60.0000	7642.2000 (29a)
Main Plane	55.8100		55.8100	0.1100	6.1391	9.0000	502.2900 (30)
Bay Roof	1.5000		1.5000	0.1100	0.1650	9.0000	13.5000 (30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)				(26)...(30) + (32) =	77.4456		(33)
Internal Wall 1			73.8800			75.0000	5541.0000 (32c)
Internal Wall 2			199.2400			9.0000	1793.1600 (32c)
Internal Floor 1			55.8100			18.0000	1004.5800 (32d)
Internal Ceiling 1			55.8100			9.0000	502.2900 (32e)
Heat capacity Cm = Sum(A x k)							(28)...(30) + (32) + (32a)...(32e) = 21263.5200 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							188.7239 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							10.3899 (36)
Total fabric heat loss							(33) + (36) = 87.8355 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m	53.5816	53.2582	52.9412	51.4523	51.1737	49.8769	49.8769	49.6368	50.3764	51.1737	51.7373	52.3265 (38)
Heat transfer coeff	141.4171	141.0937	140.7767	139.2878	139.0092	137.7124	137.7124	137.4723	138.2119	139.0092	139.5728	140.1619 (39)
Average = Sum(39)m / 12 =												139.2865 (39)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP	1.2551	1.2523	1.2495	1.2362	1.2338	1.2223	1.2223	1.2201	1.2267	1.2338	1.2388	1.2440 (40)
HLP (average)												1.2362 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy	2.8299 (42)
Average daily hot water use (litres/day)	101.4110 (43)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)

Regs Region: England

Elmhurst Energy Systems

SAP2012 Calculator (Design

System) version 4.14r16

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF FABRIC ENERGY EFFICIENCY 09 Jan 2014

Energy content (annual)	Total = Sum(45)m = 1595.5903 (45)											
Distribution loss (46)m = 0.15 x (45)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (46)
Water storage loss:												
Total storage loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)
Primary loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (59)
Heat gains from water heating, kWh/month	35.1536	30.7455	31.7266	27.6601	26.5405	22.9024	21.2225	24.3531	24.6439	28.7201	31.3503	34.0444 (65)

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(66)
(66)m	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	25.6620	22.7928	18.5363	14.0332	10.4900	8.8561	9.5693	12.4386	16.6950	21.1981	24.7414	26.3753	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	275.3376	278.1948	270.9948	255.6671	236.3186	218.1337	205.9850	203.1279	210.3278	225.6556	245.0041	263.1890	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	(69)
Pumps, fans	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	47.2494	45.7523	42.6433	38.4167	35.6727	31.8089	28.5248	32.7326	34.2277	38.6023	43.5420	45.7585	(72)
Total internal gains	413.6981	412.1889	397.6236	373.5661	347.9303	324.2477	309.5282	313.7482	326.6996	350.9051	378.7366	400.7719	(73)

6. Solar gains

[Jan]				Area m2	Solar flux Table 6a W/m2		g Specific data or Table 6b	FF Specific data or Table 6c		Access factor Table 6d		Gains W	
North				7.2400	10.6334		0.4400	0.0000		0.7700		26.0828 (74)	
East				0.8400	19.6403		0.4400	0.0000		0.7700		5.5895 (76)	
South				8.3200	46.7521		0.4400	0.0000		0.7700		131.7855 (78)	
West				1.4400	19.6403		0.4400	0.0000		0.7700		9.5819 (80)	
Solar gains	173.0396	295.3546	408.5059	518.0630	594.4316	597.2395	572.7804	514.1381	445.8784	327.3442	207.3041	148.0949	(83)
Total gains	586.7378	707.5435	806.1295	891.6291	942.3619	921.4873	882.3087	827.8863	772.5779	678.2493	586.0407	548.8667	(84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)												21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)												
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
tau	41.7667	41.8625	41.9567	42.4052	42.4902	42.8903	42.8903	42.9653	42.7353	42.4902	42.3187	42.1408
alpha	3.7844	3.7908	3.7971	3.8270	3.8327	3.8594	3.8594	3.8644	3.8490	3.8327	3.8212	3.8094
util living area	0.9961	0.9917	0.9820	0.9568	0.8970	0.7762	0.6266	0.6766	0.8680	0.9700	0.9928	0.9970 (86)
MIT	19.2052	19.4135	19.7364	20.1560	20.5459	20.8310	20.9460	20.9265	20.7124	20.2007	19.6233	19.1701 (87)
Th 2	19.8761	19.8784	19.8806	19.8911	19.8931	19.9022	19.9022	19.9039	19.8987	19.8931	19.8891	19.8850 (88)
util rest of house	0.9951	0.9894	0.9768	0.9431	0.8608	0.6934	0.4953	0.5495	0.8081	0.9579	0.9904	0.9962 (89)
MIT 2	18.2412	18.4502	18.7722	19.1913	19.5605	19.8095	19.8841	19.8767	19.7187	19.2415	18.6682	18.2129 (90)
Living area fraction									fLA = Living area /	(4) =		0.1278 (91)
MIT	18.3644	18.5734	18.8954	19.3146	19.6864	19.9400	20.0199	20.0109	19.8457	19.3641	18.7903	18.3352 (92)
Temperature adjustment												0.0000
adjusted MIT	18.3644	18.5734	18.8954	19.3146	19.6864	19.9400	20.0199	20.0109	19.8457	19.3641	18.7903	18.3352 (93)

8. Space heating requirement

Utilisation	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Useful gains	0.9930	0.9858	0.9706	0.9339	0.8526	0.6967	0.5106	0.5633	0.8045	0.9501	0.9871	0.9945	(94)
Ext temp.	582.6503	697.4626	782.4413	832.6528	803.4251	642.0046	450.5198	466.3643	621.5721	644.3977	578.4811	545.8752	(95)
Heat loss rate W	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	(96)
Month fracti	1988.9539	1929.2242	1744.9836	1450.6253	1110.1901	735.3882	470.9570	496.3936	794.1203	1218.2948	1631.6445	1981.2177	(97)
Space heating kWh	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	1.0000	(97a)
Space heating per m2	1046.2899	827.7438	716.1315	444.9402	228.2332	0.0000	0.0000	0.0000	0.0000	426.9794	758.2777	1067.8948	(98)
												5516.4904	(98)
												48.9615	(99)

8c. Space cooling requirement

Calculated for June, July and August. See Table 10b	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Ext. temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	
Heat loss rate W													

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)




CALCULATION OF FABRIC ENERGY EFFICIENCY 09 Jan 2014

Utilisation	0.0000	0.0000	0.0000	0.0000	0.0000	1294.4968	1019.0719	1044.7893	0.0000	0.0000	0.0000	0.0000 (100)
Useful loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.7592	0.8364	0.8071	0.0000	0.0000	0.0000	0.0000 (101)
Total gains	0.0000	0.0000	0.0000	0.0000	0.0000	982.7442	852.3924	843.2973	0.0000	0.0000	0.0000	0.0000 (102)
Month fracti	0.0000	0.0000	0.0000	0.0000	0.0000	1189.0023	1140.7804	1079.3540	0.0000	0.0000	0.0000	0.0000 (103)
Space cooling kWh	0.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000 (103a)
Space cooling	0.0000	0.0000	0.0000	0.0000	0.0000	148.5058	214.5607	175.6262	0.0000	0.0000	0.0000	0.0000 (104)
Cooled fraction									FC = cooled area / (4) =			538.6926 (104)
Intermittency factor (Table 10b)												1.0000 (105)
Space cooling kWh	0.0000	0.0000	0.0000	0.0000	0.0000	0.2500	0.2500	0.2500	0.0000	0.0000	0.0000	0.0000 (106)
Space cooling	0.0000	0.0000	0.0000	0.0000	0.0000	37.1264	53.6402	43.9065	0.0000	0.0000	0.0000	0.0000 (107)
Space cooling per m2												134.6732 (107)
Energy for space heating												1.1953 (108)
Energy for space cooling												48.9615 (99)
Total												1.1953 (108)
Dwelling Fabric Energy Efficiency (DFEE)												50.1568 (109)
												50.2 (109)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



Calculation of Target Fabric Energy Efficiency 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
 CALCULATION OF TARGET FABRIC ENERGY EFFICIENCY 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m3 per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c)					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor				(20) = 1 - [0.075 x (19)] =	0.8500 (20)
Infiltration rate adjusted to include shelter factor				(21) = (18) x (20) =	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000 (22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750 (22a)
Adj infilt rate	0.4290	0.4206	0.4122	0.3701	0.3617	0.3196	0.3196	0.3112	0.3365	0.3617	0.3785	0.3954 (22b)
Effective ac	0.5920	0.5884	0.5849	0.5685	0.5654	0.5511	0.5511	0.5484	0.5566	0.5654	0.5716	0.5782 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
TER Opaque door			2.1500	1.0000	2.1500		(26)
TER Semi-glazed door			2.1500	1.2000	2.5800		(26a)
TER Opening Type (Uw = 1.40)			17.8400	1.3258	23.6515		(27)
Heat Loss Floor 1			56.8600	0.1300	7.3918		(28a)
Brick Cavity	149.5100	22.1400	127.3700	0.1800	22.9266		(29a)
Main Plane	55.8100		55.8100	0.1300	7.2553		(30)
Bay Roof	1.5000		1.5000	0.1300	0.1950		(30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)			(26)...(30) + (32) =		66.1502		(33)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							250.0000 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							12.6831 (36)
Total fabric heat loss						(33) + (36) =	78.8333 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)												
(38)m	53.5816	53.2582	52.9412	51.4523	51.1737	49.8769	49.8769	49.6368	50.3764	51.1737	51.7373	52.3265 (38)
Heat transfer coeff	132.4150	132.0916	131.7746	130.2856	130.0071	128.7103	128.7103	128.4701	129.2098	130.0071	130.5706	131.1598 (39)
Average = Sum(39)m / 12 =												130.2843 (39)
HLP	1.1752	1.1724	1.1696	1.1563	1.1539	1.1424	1.1424	1.1402	1.1468	1.1539	1.1589	1.1641 (40)
HLP (average)												1.1563 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)
Energy content (annual)										Total = Sum(45)m =		1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (46)
Water storage loss:												
Total storage loss												

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)

CALCULATION OF TARGET FABRIC ENERGY EFFICIENCY 09 Jan 2014

	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)
Primary loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (59)
Heat gains from water heating, kWh/month	35.1536	30.7455	31.7266	27.6601	26.5405	22.9024	21.2225	24.3531	24.6439	28.7201	31.3503	34.0444 (65)

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	25.6620	22.7928	18.5363	14.0332	10.4900	8.8561	9.5693	12.4386	16.6950	21.1981	24.7414	26.3753	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	275.3376	278.1948	270.9948	255.6671	236.3186	218.1337	205.9850	203.1279	210.3278	225.6556	245.0041	263.1890	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	(69)
Pumps, fans	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	47.2494	45.7523	42.6433	38.4167	35.6727	31.8089	28.5248	32.7326	34.2277	38.6023	43.5420	45.7585	(72)
Total internal gains	413.6981	412.1889	397.6236	373.5661	347.9303	324.2477	309.5282	313.7482	326.6996	350.9051	378.7366	400.7719	(73)

6. Solar gains

[Jan]	Area m ²	Solar flux Table 6a W/m ²	Specific data or Table 6b	g	FF Specific data or Table 6c	Access factor Table 6d	Gains W	
North	7.2400	10.6334	0.6300		0.7000	0.7700	23.5278	(74)
East	0.8400	19.6403	0.6300		0.7000	0.7700	5.0419	(76)
South	8.3200	46.7521	0.6300		0.7000	0.7700	118.8765	(78)
West	1.4400	19.6403	0.6300		0.7000	0.7700	8.6433	(80)

Solar gains	156.0896	266.4233	368.4909	467.3164	536.2043	538.7372	516.6740	463.7760	402.2025	295.2793	186.9977	133.5883	(83)
Total gains	569.7878	678.6122	766.1145	840.8825	884.1346	862.9850	826.2022	777.5241	728.9021	646.1844	565.7343	534.3602	(84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)													21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
tau	59.0893	59.2340	59.3765	60.0550	60.1837	60.7901	60.7901	60.9037	60.5551	60.1837	59.9239	59.6548	
alpha	4.9393	4.9489	4.9584	5.0037	5.0122	5.0527	5.0527	5.0602	5.0370	5.0122	4.9949	4.9770	
util living area	0.9991	0.9976	0.9935	0.9794	0.9340	0.8148	0.6499	0.7039	0.9060	0.9869	0.9980	0.9993	(86)
MIT	19.6375	19.7965	20.0452	20.3732	20.6807	20.8993	20.9754	20.9635	20.8072	20.4050	19.9595	19.6120	(87)
Th 2	19.9399	19.9422	19.9444	19.9551	19.9571	19.9664	19.9664	19.9681	19.9628	19.9571	19.9530	19.9488	(88)
util rest of house	0.9988	0.9968	0.9911	0.9707	0.9032	0.7303	0.5147	0.5722	0.8500	0.9799	0.9971	0.9991	(89)
MIT 2	18.6937	18.8542	19.1036	19.4355	19.7280	19.9159	19.9597	19.9568	19.8477	19.4712	19.0258	18.6753	(90)
Living area fraction									fLA = Living area / (4) =			0.1278	(91)
MIT	18.8143	18.9746	19.2239	19.5553	19.8498	20.0416	20.0895	20.0855	19.9704	19.5906	19.1452	18.7950	(92)
Temperature adjustment												0.0000	
adjusted MIT	18.8143	18.9746	19.2239	19.5553	19.8498	20.0416	20.0895	20.0855	19.9704	19.5906	19.1452	18.7950	(93)

8. Space heating requirement

Utilisation	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
	0.9983	0.9957	0.9887	0.9662	0.8992	0.7374	0.5319	0.5886	0.8505	0.9764	0.9961	0.9987	(94)
Useful gains	568.7986	675.6653	757.4726	812.4994	795.0322	636.3248	439.4670	457.6431	619.9376	630.9381	563.5367	533.6875	(95)
Ext temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	(96)
Heat loss rate W	1921.9144	1859.1413	1676.6869	1388.2337	1059.5311	700.3893	449.1318	473.4739	758.5074	1168.8352	1572.7452	1914.2816	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(97a)
Space heating kWh	1006.7182	795.2959	683.8954	414.5287	196.7872	0.0000	0.0000	0.0000	0.0000	400.1955	726.6301	1027.1620	(98)
Space heating												5251.2129	(98)
Space heating per m2										(98) / (4) =		46.6070	(99)

8c. Space cooling requirement

Calculated for June, July and August. See Table 10b	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Ext. temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	
Heat loss rate W	0.0000	0.0000	0.0000	0.0000	0.0000	1209.8764	952.4559	976.3728	0.0000	0.0000	0.0000	0.0000	(100)
Utilisation	0.0000	0.0000	0.0000	0.0000	0.0000	0.8012	0.8810	0.8529	0.0000	0.0000	0.0000	0.0000	(101)
Useful loss	0.0000	0.0000	0.0000	0.0000	0.0000	969.3880	839.0940	832.7235	0.0000	0.0000	0.0000	0.0000	(102)
Total gains	0.0000	0.0000	0.0000	0.0000	0.0000	1120.6229	1075.2014	1020.4891	0.0000	0.0000	0.0000	0.0000	(103)
Month fracti	0.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	(103a)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF TARGET FABRIC ENERGY EFFICIENCY 09 Jan 2014

Space cooling kWh	0.0000	0.0000	0.0000	0.0000	0.0000	108.8892	175.6639	139.6976	0.0000	0.0000	0.0000	0.0000 (104)
Space cooling												424.2507 (104)
Cooled fraction									fC = cooled area / (4) =			1.0000 (105)
Intermittency factor (Table 10b)	0.0000	0.0000	0.0000	0.0000	0.0000	0.2500	0.2500	0.2500	0.0000	0.0000	0.0000	0.0000 (106)
Space cooling kWh	0.0000	0.0000	0.0000	0.0000	0.0000	27.2223	43.9160	34.9244	0.0000	0.0000	0.0000	0.0000 (107)
Space cooling												106.0627 (107)
Space cooling per m2												0.9414 (108)
Energy for space heating												46.6070 (99)
Energy for space cooling												0.9414 (108)
Total												47.5484 (109)
Target Fabric Energy Efficiency (TFEE)												54.7 (109)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF HEAT DEMAND 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF HEAT DEMAND 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m3 per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c)					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor			(20) = 1 - [0.075 x (19)]	=	0.8500 (20)
Infiltration rate adjusted to include shelter factor			(21) = (18) x (20)	=	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	4.2000	4.0000	4.0000	3.7000	3.7000	3.3000	3.4000	3.2000	3.3000	3.5000	3.5000	3.8000 (22)
Wind factor	1.0500	1.0000	1.0000	0.9250	0.9250	0.8250	0.8500	0.8000	0.8250	0.8750	0.8750	0.9500 (22a)
Adj infilt rate	0.3533	0.3365	0.3365	0.3112	0.3112	0.2776	0.2860	0.2692	0.2776	0.2944	0.2944	0.3196 (22b)
Effective ac	0.5624	0.5566	0.5566	0.5484	0.5484	0.5385	0.5409	0.5362	0.5385	0.5433	0.5433	0.5511 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Opening Type 1			2.1500	1.4000	3.0100		(26)
Opening Type 2 (Uw = 1.30)			17.8400	1.2357	22.0456		(27)
Opening Type 3			2.1500	1.6000	3.4400		(26a)
Heat Loss Floor 1			56.8600	0.1900	10.8034	75.0000	4264.5000 (28a)
Brick Cavity	149.5100	22.1400	127.3700	0.2500	31.8425	60.0000	7642.2000 (29a)
Main Plane	55.8100		55.8100	0.1100	6.1391	9.0000	502.2900 (30)
Bay Roof	1.5000		1.5000	0.1100	0.1650	9.0000	13.5000 (30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)				(26)...(30) + (32) =	77.4456		(33)
Internal Wall 1			73.8800			75.0000	5541.0000 (32c)
Internal Wall 2			199.2400			9.0000	1793.1600 (32c)
Internal Floor 1			55.8100			18.0000	1004.5800 (32d)
Internal Ceiling 1			55.8100			18.0000	1004.5800 (32e)
Heat capacity Cm = Sum(A x k)						(28)...(30) + (32) + (32a)...(32e) =	21765.8100 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							193.1819 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							10.3899 (36)
Total fabric heat loss						(33) + (36) =	87.8355 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m	50.9016	50.3764	50.3764	49.6368	49.6368	48.7402	48.9548	48.5321	48.7402	49.1757	49.1757	49.8769 (38)
Heat transfer coeff	138.7371	138.2119	138.2119	137.4723	137.4723	136.5757	136.7903	136.3676	136.5757	137.0112	137.0112	137.7124 (39)
Average = Sum(39)m / 12 =												137.3458 (39)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP	1.2314	1.2267	1.2267	1.2201	1.2201	1.2122	1.2141	1.2103	1.2122	1.2160	1.2160	1.2223 (40)
HLP (average)												1.2190 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)

Regs Region: England

Elmhurst Energy Systems

SAP2012 Calculator (Design

System) version 4.14r16

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF HEAT DEMAND 09 Jan 2014

Energy content (annual)												Total = Sum(45)m = 1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m												
	24.8143	21.7027	22.3953	19.5247	18.7345	16.1664	14.9806	17.1904	17.3957	20.2730	22.1296	24.0313 (46)
Water storage loss:												
Total storage loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)
Combi loss	14.1536	12.7725	14.1149	13.6233	14.0423	13.5489	13.9753	14.0188	13.5894	14.0809	13.6669	14.1411 (61)
Total heat required for water heating calculated for each month	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (62)
Solar input	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63)
Solar input (sum of months) = Sum(63)m =												0.0000 (63)
Output from w/h	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (64)
RHI water heating demand												
Heat gains from water heating, kWh/month	58.5434	51.3009	53.1716	46.6857	45.0386	39.2228	36.7007	41.6101	41.9579	48.4588	52.4707	56.8047 (65)

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	64.1551	56.9820	46.3409	35.0830	26.2250	22.1402	23.9233	31.0964	41.7375	52.9954	61.8534	65.9382	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	410.9517	415.2160	404.4699	381.5927	352.7143	325.5726	307.4404	303.1760	313.9221	336.7993	365.6777	392.8194	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	78.6874	76.3406	71.4672	64.8412	60.5358	54.4761	49.3289	55.9275	58.2748	65.1328	72.8759	76.3504	(72)
Total internal gains	668.2024	662.9469	636.6863	595.9252	553.8833	516.5973	495.1009	504.6082	528.3427	569.3358	614.8154	649.5162	(73)

6. Solar gains

[Jan]				Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Access factor Table 6d		Gains W			
North				7.2400	11.9814	0.4400	0.0000	0.7700		29.3894 (74)			
East				0.8400	22.3313	0.4400	0.0000	0.7700		6.3553 (76)			
South				8.3200	50.9848	0.4400	0.0000	0.7700		143.7168 (78)			
West				1.4400	22.3313	0.4400	0.0000	0.7700		10.8948 (80)			
Solar gains	190.3564	292.5741	401.1166	527.7688	593.4473	639.6574	606.1981	553.8342	475.7176	346.5355	233.6492	161.3447	(83)
Total gains	858.5588	955.5210	1037.8029	1123.6940	1147.3307	1156.2547	1101.2991	1058.4424	1004.0603	915.8713	848.4646	810.8609	(84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)												21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)												
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
tau	43.5793	43.7448	43.7448	43.9802	43.9802	44.2689	44.1995	44.3365	44.2689	44.1282	44.1282	43.9035
alpha	3.9053	3.9163	3.9163	3.9320	3.9320	3.9513	3.9466	3.9558	3.9513	3.9419	3.9419	3.9269
util living area	0.9845	0.9756	0.9538	0.8984	0.7800	0.5580	0.3795	0.4049	0.6945	0.9075	0.9711	0.9872 (86)
MIT	19.6420	19.8048	20.1109	20.4833	20.7951	20.9622	20.9939	20.9922	20.9049	20.5426	20.0414	19.6107 (87)
Th 2	19.8950	19.8987	19.8987	19.9039	19.9039	19.9103	19.9088	19.9117	19.9103	19.9072	19.9072	19.9022 (88)
util rest of house	0.9804	0.9691	0.9409	0.8690	0.7156	0.4499	0.2487	0.2709	0.5961	0.8740	0.9620	0.9837 (89)
MIT 2	18.1249	18.3619	18.7997	19.3195	19.7163	19.8899	19.9075	19.9100	19.8446	19.4119	18.7115	18.0848 (90)
Living area fraction	18.3188	18.5463	18.9673	19.4682	19.8542	20.0269	20.0463	20.0483	19.9801	19.5564	18.8815	18.2798 (91)
MIT	18.3188	18.5463	18.9673	19.4682	19.8542	20.0269	20.0463	20.0483	19.9801	19.5564	18.8815	18.2798 (92)
Temperature adjustment	18.1688	18.3963	18.8173	19.3182	19.7042	19.8769	19.8963	19.8983	19.8301	19.4064	18.7315	-0.1500
adjusted MIT	18.1688	18.3963	18.8173	19.3182	19.7042	19.8769	19.8963	19.8983	19.8301	19.4064	18.7315	18.1298 (93)

8. Space heating requirement

Utilisation	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Useful gains	833.5258	914.1083	958.9148	954.5704	805.6386	516.1040	272.2427	284.9530	590.4418	782.5173	804.4755	790.8194	(94)
Ext temp.	5.1000	5.6000	7.4000	9.9000	13.0000	16.0000	17.9000	17.8000	15.2000	11.6000	8.0000	5.1000	(96)
Heat loss rate W	1813.1216	1768.6018	1578.0110	1294.7460	921.6418	529.4965	273.0799	286.1363	632.3609	1069.5651	1470.3379	1794.3645	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(98a)
Space heating kWh	728.8193	574.2197	460.6075	244.9264	86.3064	0.0000	0.0000	0.0000	0.0000	213.5636	479.4209	746.6376	(98)
Space heating												3534.5014	(98)
RHI space heating demand												3535	(98)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF HEAT DEMAND 09 Jan 2014

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF ENERGY RATINGS 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF ENERGY RATINGS 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m3 per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c)					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor				(20) = 1 - [0.075 x (19)] =	0.8500 (20)
Infiltration rate adjusted to include shelter factor				(21) = (18) x (20) =	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000 (22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750 (22a)
Adj infilt rate	0.4290	0.4206	0.4122	0.3701	0.3617	0.3196	0.3196	0.3112	0.3365	0.3617	0.3785	0.3954 (22b)
Effective ac	0.5920	0.5884	0.5849	0.5685	0.5654	0.5511	0.5511	0.5484	0.5566	0.5654	0.5716	0.5782 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Opening Type 1			2.1500	1.4000	3.0100		(26)
Opening Type 2 (Uw = 1.30)			17.8400	1.2357	22.0456		(27)
Opening Type 3			2.1500	1.6000	3.4400		(26a)
Heat Loss Floor 1			56.8600	0.1900	10.8034	75.0000	4264.5000 (28a)
Brick Cavity	149.5100	22.1400	127.3700	0.2500	31.8425	60.0000	7642.2000 (29a)
Main Plane	55.8100		55.8100	0.1100	6.1391	9.0000	502.2900 (30)
Bay Roof	1.5000		1.5000	0.1100	0.1650	9.0000	13.5000 (30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)				(26)...(30) + (32) =	77.4456		(33)
Internal Wall 1			73.8800			75.0000	5541.0000 (32c)
Internal Wall 2			199.2400			9.0000	1793.1600 (32c)
Internal Floor 1			55.8100			18.0000	1004.5800 (32d)
Internal Ceiling 1			55.8100			18.0000	1004.5800 (32e)
Heat capacity Cm = Sum(A x k)						(28)...(30) + (32) + (32a)...(32e) =	21765.8100 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							193.1819 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							10.3899 (36)
Total fabric heat loss						(33) + (36) =	87.8355 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m	53.5816	53.2582	52.9412	51.4523	51.1737	49.8769	49.8769	49.6368	50.3764	51.1737	51.7373	52.3265 (38)
Heat transfer coeff	141.4171	141.0937	140.7767	139.2878	139.0092	137.7124	137.7124	137.4723	138.2119	139.0092	139.5728	140.1619 (39)
Average = Sum(39)m / 12 =												139.2865 (39)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP	1.2551	1.2523	1.2495	1.2362	1.2338	1.2223	1.2223	1.2201	1.2267	1.2338	1.2388	1.2440 (40)
HLP (average)												1.2362 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)

Regs Region: England

Elmhurst Energy Systems

SAP2012 Calculator (Design

System) version 4.14r16

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF ENERGY RATINGS 09 Jan 2014

Energy content (annual)												Total = Sum(45)m =	1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m	24.8143	21.7027	22.3953	19.5247	18.7345	16.1664	14.9806	17.1904	17.3957	20.2730	22.1296	24.0313 (46)	
Water storage loss:													
Total storage loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)	
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)	
Combi loss	14.1536	12.7725	14.1149	13.6233	14.0423	13.5489	13.9753	14.0188	13.5894	14.0809	13.6669	14.1411 (61)	
Total heat required for water heating calculated for each month	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (62)	
Solar input	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63)	
								Solar input (sum of months) = Sum(63)m =					0.0000 (63)
Output from w/h	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (64)	
								Total per year (kWh/year) = Sum(64)m =					1761.3181 (64)
Heat gains from water heating, kWh/month	58.5434	51.3009	53.1716	46.6857	45.0386	39.2228	36.7007	41.6101	41.9579	48.4588	52.4707	56.8047 (65)	

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	64.1551	56.9820	46.3409	35.0830	26.2250	22.1402	23.9233	31.0964	41.7375	52.9954	61.8534	65.9382	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	410.9517	415.2160	404.4699	381.5927	352.7143	325.5726	307.4404	303.1760	313.9221	336.7993	365.6777	392.8194	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	78.6874	76.3406	71.4672	64.8412	60.5358	54.4761	49.3289	55.9275	58.2748	65.1328	72.8759	76.3504	(72)
Total internal gains	668.2024	662.9469	636.6863	595.9252	553.8833	516.5973	495.1009	504.6082	528.3427	569.3358	614.8154	649.5162	(73)

6. Solar gains

[Jan]			Area m2		Solar flux Table 6a W/m2		g Specific data or Table 6b		FF Specific data or Table 6c		Access factor Table 6d		Gains W
North			7.2400		10.6334		0.4400		0.0000		0.7700		26.0828 (74)
East			0.8400		19.6403		0.4400		0.0000		0.7700		5.5895 (76)
South			8.3200		46.7521		0.4400		0.0000		0.7700		131.7855 (78)
West			1.4400		19.6403		0.4400		0.0000		0.7700		9.5819 (80)
Solar gains	173.0396	295.3546	408.5059	518.0630	594.4316	597.2395	572.7804	514.1381	445.8784	327.3442	207.3041	148.0949	(83)
Total gains	841.2421	958.3015	1045.1922	1113.9883	1148.3149	1113.8368	1067.8813	1018.7464	974.2211	896.6800	822.1195	797.6111	(84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)												21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)												
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
tau	42.7534	42.8514	42.9479	43.4069	43.4939	43.9035	43.9035	43.9802	43.7448	43.4939	43.3183	43.1362
alpha	3.8502	3.8568	3.8632	3.8938	3.8996	3.9269	3.9269	3.9320	3.9163	3.8996	3.8879	3.8757
util living area	0.9878	0.9790	0.9618	0.9221	0.8402	0.6951	0.5392	0.5808	0.7880	0.9348	0.9792	0.9900 (86)
MIT	19.4802	19.6751	19.9700	20.3438	20.6728	20.8928	20.9698	20.9593	20.8142	20.3940	19.8690	19.4422 (87)
Th 2	19.8761	19.8784	19.8806	19.8911	19.8931	19.9022	19.9022	19.9039	19.8987	19.8931	19.8891	19.8850 (88)
util rest of house	0.9847	0.9736	0.9515	0.8999	0.7926	0.6064	0.4172	0.4594	0.7126	0.9116	0.9729	0.9874 (89)
MIT 2	17.8774	18.1607	18.5859	19.1194	19.5589	19.8220	19.8886	19.8839	19.7418	19.1999	18.4513	17.8281 (90)
Living area fraction	18.0822	18.3542	18.7628	19.2759	19.7012	19.9589	20.0268	20.0213	19.8788	19.3525	18.6325	18.0344 (92)
MIT	17.9322	18.2042	18.6128	19.1259	19.5512	19.8089	19.8768	19.8713	19.7288	19.2025	18.4825	17.8844 (93)
Temperature adjustment												-0.1500
adjusted MIT												

8. Space heating requirement

Utilisation	0.9764	0.9619	0.9356	0.8804	0.7752	0.5980	0.4142	0.4555	0.6989	0.8923	0.9612	0.9802	(94)
Useful gains	821.4214	821.8265	977.9111	980.7412	890.1631	666.1059	442.2818	464.0364	680.9147	800.1269	790.2174	781.8543	(95)
Ext temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	(96)
Heat loss rate W	1927.8293	1877.1454	1705.2015	1424.3457	1091.3948	717.3299	451.2593	477.2089	777.9722	1195.8259	1588.6839	1918.0372	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(97a)
Space heating kWh	823.1675	641.9743	541.1041	319.3952	149.7164	0.0000	0.0000	0.0000	0.0000	294.4001	574.8959	845.3201	(98)
Space heating												4189.9736	(98)
Space heating per m2												37.1880	(99)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF ENERGY RATINGS 09 Jan 2014

8c. Space cooling requirement

Not applicable

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 11)													0.0000 (201)
Fraction of space heat from main system(s)													1.0000 (202)
Efficiency of main space heating system 1 (in %)													90.5000 (206)
Efficiency of secondary/supplementary heating system, %													0.0000 (208)
Space heating requirement													4629.8050 (211)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Space heating requirement	823.1675	641.9743	541.1041	319.3952	149.7164	0.0000	0.0000	0.0000	0.0000	294.4001	574.8959	845.3201	(98)
Space heating efficiency (main heating system 1)	90.5000	90.5000	90.5000	90.5000	90.5000	0.0000	0.0000	0.0000	0.0000	90.5000	90.5000	90.5000	(210)
Space heating fuel (main heating system)	909.5774	709.3639	597.9051	352.9229	165.4325	0.0000	0.0000	0.0000	0.0000	325.3040	635.2441	934.0553	(211)
Water heating requirement	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(215)
Water heating													
Water heating requirement	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498	(64)
Efficiency of water heater	89.9098	89.8513	89.7370	89.4818	88.9310	87.3000	87.3000	87.3000	87.3000	89.3977	89.7793	87.3000	(216)
(217)m	89.9098	89.8513	89.7370	89.4818	88.9310	87.3000	87.3000	87.3000	87.3000	89.3977	89.7793	89.9363	(217)
Fuel for water heating, kWh/month	199.7360	175.2422	182.1063	160.6900	156.2321	138.9748	130.4075	147.3327	148.4088	166.9333	179.5486	193.8592	(219)
Water heating fuel used												1979.4713	(219)
Annual totals kWh/year													
Space heating fuel - main system												4629.8050	(211)
Space heating fuel - secondary												0.0000	(215)
Electricity for pumps and fans:													
central heating pump												30.0000	(230c)
main heating flue fan												45.0000	(230e)
Total electricity for the above, kWh/year												75.0000	(231)
Electricity for lighting (calculated in Appendix L)												453.1995	(232)
Total delivered energy for all uses												7137.4759	(238)

10a. Fuel costs - using Table 12 prices

	Fuel	Fuel price	Fuel cost
	kWh/year	p/kWh	£/year
Space heating - main system 1	4629.8050	3.4800	161.1172 (240)
Space heating - secondary	0.0000	0.0000	0.0000 (242)
Water heating (other fuel)	1979.4713	3.4800	68.8856 (247)
Pumps and fans for heating	75.0000	13.1900	9.8925 (249)
Energy for lighting	453.1995	13.1900	59.7770 (250)
Additional standing charges			120.0000 (251)
Total energy cost			419.6723 (255)

11a. SAP rating - Individual heating systems

Energy cost deflator (Table 12):	0.4200 (256)
Energy cost factor (ECF)	1.1179 (257)
SAP value	84.4050
SAP rating (Section 12)	84 (258)
SAP band	B

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

	Energy	Emission factor	Emissions
	kWh/year	kg CO2/kWh	kg CO2/year
Space heating - main system 1	4629.8050	0.2160	1000.0379 (261)
Space heating - secondary	0.0000	0.0000	0.0000 (263)
Water heating (other fuel)	1979.4713	0.2160	427.5658 (264)
Space and water heating			1427.6037 (265)
Pumps and fans	75.0000	0.5190	38.9250 (267)
Energy for lighting	453.1995	0.5190	235.2106 (268)
Total kg/year			1701.7392 (272)
CO2 emissions per m2			15.1000 (273)
EI value			85.5373
EI rating			86 (274)
EI band			B

Calculation of stars for heating and DHW

Main heating energy efficiency	$3.48 \times (1 + 0.29 \times 0.00) / 0.9050 = 3.845$, stars = 4
Main heating environmental impact	$0.216 \times (1 + 0.29 \times 0.00) / 0.9050 = 0.2387$, stars = 4
Water heating energy efficiency	$3.48 / 0.8885 = 3.917$, stars = 4
Water heating environmental impact	$0.216 / 0.8885 = 0.2431$, stars = 4

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF ENERGY RATINGS 09 Jan 2014

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m ³ per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c)					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor				(20) = 1 - [0.075 x (19)] =	0.8500 (20)
Infiltration rate adjusted to include shelter factor				(21) = (18) x (20) =	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	4.2000	4.0000	4.0000	3.7000	3.7000	3.3000	3.4000	3.2000	3.3000	3.5000	3.5000	3.8000 (22)
Wind factor	1.0500	1.0000	1.0000	0.9250	0.9250	0.8250	0.8500	0.8000	0.8250	0.8750	0.8750	0.9500 (22a)
Adj infilt rate	0.3533	0.3365	0.3365	0.3112	0.3112	0.2776	0.2860	0.2692	0.2776	0.2944	0.2944	0.3196 (22b)
Effective ac	0.5624	0.5566	0.5566	0.5484	0.5484	0.5385	0.5409	0.5362	0.5385	0.5433	0.5433	0.5511 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Opening Type 1			2.1500	1.4000	3.0100		(26)
Opening Type 2 (Uw = 1.30)			17.8400	1.2357	22.0456		(27)
Opening Type 3			2.1500	1.6000	3.4400		(26a)
Heat Loss Floor 1			56.8600	0.1900	10.8034	75.0000	4264.5000 (28a)
Brick Cavity	149.5100	22.1400	127.3700	0.2500	31.8425	60.0000	7642.2000 (29a)
Main Plane	55.8100		55.8100	0.1100	6.1391	9.0000	502.2900 (30)
Bay Roof	1.5000		1.5000	0.1100	0.1650	9.0000	13.5000 (30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)				(26)...(30) + (32) =	77.4456		(33)
Internal Wall 1			73.8800			75.0000	5541.0000 (32c)
Internal Wall 2			199.2400			9.0000	1793.1600 (32c)
Internal Floor 1			55.8100			18.0000	1004.5800 (32d)
Internal Ceiling 1			55.8100			18.0000	1004.5800 (32e)
Heat capacity Cm = Sum(A x k)						(28)...(30) + (32) + (32a)...(32e) =	21765.8100 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							193.1819 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							10.3899 (36)
Total fabric heat loss						(33) + (36) =	87.8355 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m	50.9016	50.3764	50.3764	49.6368	49.6368	48.7402	48.9548	48.5321	48.7402	49.1757	49.1757	49.8769 (38)
Heat transfer coeff	138.7371	138.2119	138.2119	137.4723	137.4723	136.5757	136.7903	136.3676	136.5757	137.0112	137.0112	137.7124 (39)
Average = Sum(39)m / 12 =												137.3458 (39)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP	1.2314	1.2267	1.2267	1.2201	1.2201	1.2122	1.2141	1.2103	1.2122	1.2160	1.2160	1.2223 (40)
HLP (average)												1.2190 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)

Regs Region: England


Elmhurst Energy Systems

SAP2012 Calculator (Design

System) version 4.14r16

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY 09 Jan 2014

Energy content (annual)												Total = Sum(45)m =	1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m	24.8143	21.7027	22.3953	19.5247	18.7345	16.1664	14.9806	17.1904	17.3957	20.2730	22.1296	24.0313 (46)	
Water storage loss:													
Total storage loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)	
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)	
Combi loss	14.1536	12.7725	14.1149	13.6233	14.0423	13.5489	13.9753	14.0188	13.5894	14.0809	13.6669	14.1411 (61)	
Total heat required for water heating calculated for each month	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (62)	
Solar input	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63)	
								Solar input (sum of months) = Sum(63)m =					0.0000 (63)
Output from w/h	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (64)	
								Total per year (kWh/year) = Sum(64)m =					1761.3181 (64)
Heat gains from water heating, kWh/month	58.5434	51.3009	53.1716	46.6857	45.0386	39.2228	36.7007	41.6101	41.9579	48.4588	52.4707	56.8047 (65)	

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	64.1551	56.9820	46.3409	35.0830	26.2250	22.1402	23.9233	31.0964	41.7375	52.9954	61.8534	65.9382	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	410.9517	415.2160	404.4699	381.5927	352.7143	325.5726	307.4404	303.1760	313.9221	336.7993	365.6777	392.8194	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	78.6874	76.3406	71.4672	64.8412	60.5358	54.4761	49.3289	55.9275	58.2748	65.1328	72.8759	76.3504	(72)
Total internal gains	668.2024	662.9469	636.6863	595.9252	553.8833	516.5973	495.1009	504.6082	528.3427	569.3358	614.8154	649.5162	(73)

6. Solar gains

[Jan]					Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Access factor Table 6d	Gains W		
North					7.2400	11.9814	0.4400	0.0000	0.7700	29.3894 (74)		
East					0.8400	22.3313	0.4400	0.0000	0.7700	6.3553 (76)		
South					8.3200	50.9848	0.4400	0.0000	0.7700	143.7168 (78)		
West					1.4400	22.3313	0.4400	0.0000	0.7700	10.8948 (80)		
Solar gains	190.3564	292.5741	401.1166	527.7688	593.4473	639.6574	606.1981	553.8342	475.7176	346.5355	233.6492	161.3447 (83)
Total gains	858.5588	955.5210	1037.8029	1123.6940	1147.3307	1156.2547	1101.2991	1058.4424	1004.0603	915.8713	848.4646	810.8609 (84)

7. Mean internal temperature (heating season)


Temperature during heating periods in the living area from Table 9, Th1 (C)												21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)												
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
tau	43.5793	43.7448	43.7448	43.9802	43.9802	44.2689	44.1995	44.3365	44.2689	44.1282	44.1282	43.9035
alpha	3.9053	3.9163	3.9163	3.9320	3.9320	3.9513	3.9466	3.9558	3.9513	3.9419	3.9419	3.9269
util living area	0.9845	0.9756	0.9538	0.8984	0.7800	0.5580	0.3795	0.4049	0.6945	0.9075	0.9711	0.9872 (86)
MIT	19.6420	19.8048	20.1109	20.4833	20.7951	20.9622	20.9939	20.9922	20.9049	20.5426	20.0414	19.6107 (87)
Th 2	19.8950	19.8987	19.8987	19.9039	19.9039	19.9103	19.9088	19.9117	19.9103	19.9072	19.9072	19.9022 (88)
util rest of house	0.9804	0.9691	0.9409	0.8690	0.7156	0.4499	0.2487	0.2709	0.5961	0.8740	0.9620	0.9837 (89)
MIT 2	18.1249	18.3619	18.7997	19.3195	19.7163	19.8899	19.9075	19.9100	19.8446	19.4119	18.7115	18.0848 (90)
Living area fraction	fLA = Living area / (4) =											0.1278 (91)
MIT	18.3188	18.5463	18.9673	19.4682	19.8542	20.0269	20.0463	20.0483	19.9801	19.5564	18.8815	18.2798 (92)
Temperature adjustment												-0.1500
adjusted MIT	18.1688	18.3963	18.8173	19.3182	19.7042	19.8769	19.8963	19.8983	19.8301	19.4064	18.7315	18.1298 (93)

8. Space heating requirement

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
Utilisation	0.9708	0.9567	0.9240	0.8495	0.7022	0.4464	0.2472	0.2692	0.5881	0.8544	0.9482	0.9753	(94)	
Useful gains	833.5258	914.1083	958.9148	954.5704	805.6386	516.1040	272.2427	284.9530	590.4418	782.5173	804.4755	790.8194	(95)	
Ext temp.	5.1000	5.6000	7.4000	9.9000	13.0000	16.0000	17.9000	17.8000	15.2000	11.6000	8.0000	5.1000	(96)	
Heat loss rate W	1813.1216	1768.6018	1578.0110	1294.7460	921.6418	529.4965	273.0799	286.1363	632.3609	1069.5651	1470.3379	1794.3645	(97)	
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(97a)	
Space heating kWh	728.8193	574.2197	460.6075	244.9264	86.3064	0.0000	0.0000	0.0000	0.0000	213.5636	479.4209	746.6376	(98)	
Space heating												3534.5014	(98)	
Space heating per m2												(98) / (4) =	31.3704	(99)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY 09 Jan 2014

8c. Space cooling requirement

Not applicable

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 11)													0.0000 (201)
Fraction of space heat from main system(s)													1.0000 (202)
Efficiency of main space heating system 1 (in %)													90.5000 (206)
Efficiency of secondary/supplementary heating system, %													0.0000 (208)
Space heating requirement													3905.5264 (211)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Space heating requirement	728.8193	574.2197	460.6075	244.9264	86.3064	0.0000	0.0000	0.0000	0.0000	213.5636	479.4209	746.6376	(98)
Space heating efficiency (main heating system 1)	90.5000	90.5000	90.5000	90.5000	90.5000	0.0000	0.0000	0.0000	0.0000	90.5000	90.5000	90.5000	(210)
Space heating fuel (main heating system)	805.3252	634.4969	508.9586	270.6369	95.3662	0.0000	0.0000	0.0000	0.0000	235.9818	529.7469	825.0139	(211)
Water heating requirement	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(215)
Water heating													
Water heating requirement	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498	(64)
Efficiency of water heater (217)m	89.8489	89.7917	89.6395	89.2893	88.4990	87.3000	87.3000	87.3000	87.3000	89.1557	89.6729	87.3000	(216)
Fuel for water heating, kWh/month	199.8713	175.3585	182.3043	161.0363	156.9946	138.9748	130.4075	147.3327	148.4088	167.3863	179.7617	193.9886	(219)
Water heating fuel used												1981.8254	(219)
Annual totals kWh/year													
Space heating fuel - main system												3905.5264	(211)
Space heating fuel - secondary												0.0000	(215)
Electricity for pumps and fans:													
central heating pump												30.0000	(230c)
main heating flue fan												45.0000	(230e)
Total electricity for the above, kWh/year												75.0000	(231)
Electricity for lighting (calculated in Appendix L)												453.1995	(232)
Total delivered energy for all uses												6415.5513	(238)

10a. Fuel costs - using BEDF prices (470)

	Fuel kWh/year	Fuel price p/kWh	Fuel cost £/year
Space heating - main system 1	3905.5264	3.8700	151.1439 (240)
Space heating - secondary	0.0000	0.0000	0.0000 (242)
Water heating (other fuel)	1981.8254	3.8700	76.6966 (247)
Pumps and fans for heating	75.0000	18.9000	14.1750 (249)
Energy for lighting	453.1995	18.9000	85.6547 (250)
Additional standing charges			93.0000 (251)
Total energy cost			420.6702 (255)

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating - main system 1	3905.5264	0.2160	843.5937 (261)
Space heating - secondary	0.0000	0.0000	0.0000 (263)
Water heating (other fuel)	1981.8254	0.2160	428.0743 (264)
Space and water heating			1271.6680 (265)
Pumps and fans	75.0000	0.5190	38.9250 (267)
Energy for lighting	453.1995	0.5190	235.2106 (268)
Total kg/year			1545.8035 (272)

13a. Primary energy - Individual heating systems including micro-CHP

	Energy kWh/year	Primary energy factor kg CO2/kWh	Primary energy kWh/year
Space heating - main system 1	3905.5264	1.2200	4764.7422 (261)
Space heating - secondary	0.0000	0.0000	0.0000 (263)
Water heating (other fuel)	1981.8254	1.2200	2417.8269 (264)
Space and water heating			7182.5692 (265)
Pumps and fans	75.0000	3.0700	230.2500 (267)
Energy for lighting	453.1995	3.0700	1391.3225 (268)
Primary energy kWh/year			8804.1417 (272)
Primary energy kWh/m2/year			78.1410 (273)

SAP 2012 EPC IMPROVEMENTS

Current energy efficiency rating: B 84
Current environmental impact rating: B 86

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)

CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY 09 Jan 2014

(For testing purposes):

A	Not considered
B	Not considered
C	Not considered
D	Not considered
E Low energy lighting	Already installed
F	Not considered
G	Not considered
H	Not considered
I	Not considered
J	Not considered
K	Not considered
M	Not considered
N Solar water heating	Recommended
O	Not considered
P	Not considered
R	Not considered
S	Not considered
T	Not considered
U Solar photovoltaic panels	Recommended
A2	Not considered
A3	Not considered
T2	Not considered
W	Not considered
X	Not considered
Y	Not considered
J2	Not considered
Q2	Not considered
Z1	Not considered
Z2	Not considered
Z3	Not considered
Z4	Not considered
Z5	Not considered
V2 Wind turbine	Not applicable
L2	Not considered
Q3	Not considered
O3	Not considered

Recommended measures:	SAP change	Cost change	CO2 change
N Solar water heating	+ 1.0	-£ 30	-192 kg (12.4%)
U Solar photovoltaic panels	+ 8.5	-£ 345	-947 kg (69.9%)

Recommended measures	Typical annual savings	Energy efficiency	Environmental impact
Solar water heating	£30	1.70 kg/m²	B 85 B 87
Solar photovoltaic panels	£345	8.40 kg/m²	A 94 A 95
Total Savings	£374	10.11 kg/m²	

Potential energy efficiency rating: A 94
Potential environmental impact rating: A 95

Fuel prices for cost data on this page from database revision number 470 TEST (21 Dec 2020)
Recommendation texts revision number 4.9c (22 Feb 2014)

Typical heating and lighting costs of this home (per year, Thames Valley):

	Current	Potential	Saving
Electricity	£100	£109	-£9
Mains gas	£321	£282	£39
Space heating	£258	£258	£0
Water heating	£77	£47	£30
Lighting	£86	£86	£0
Generated (PV)	-£0	-£345	£345
Total cost of fuels	£421	£46	£375
Total cost of uses	£421	£46	£375
Delivered energy	57 kWh/m²	32 kWh/m²	25 kWh/m²
Carbon dioxide emissions	1.5 tonnes	0.4 tonnes	1.1 tonnes
CO2 emissions per m²	14 kg/m²	4 kg/m²	10 kg/m²
Primary energy	78 kWh/m²	19 kWh/m²	59 kWh/m²

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF ENERGY RATINGS FOR IMPROVED DWELLING 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF ENERGY RATINGS FOR IMPROVED DWELLING 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m3 per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor					(20) = 1 - [0.075 x (19)] = 0.8500 (20)
Infiltration rate adjusted to include shelter factor					(21) = (18) x (20) = 0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000 (22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750 (22a)
Adj infilt rate	0.4290	0.4206	0.4122	0.3701	0.3617	0.3196	0.3196	0.3112	0.3365	0.3617	0.3785	0.3954 (22b)
Effective ac	0.5920	0.5884	0.5849	0.5685	0.5654	0.5511	0.5511	0.5484	0.5566	0.5654	0.5716	0.5782 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Opening Type 1			2.1500	1.4000	3.0100		(26)
Opening Type 2 (Uw = 1.30)			17.8400	1.2357	22.0456		(27)
Opening Type 3			2.1500	1.6000	3.4400		(26a)
Heat Loss Floor 1			56.8600	0.1900	10.8034	75.0000	4264.5000 (28a)
Brick Cavity	149.5100	22.1400	127.3700	0.2500	31.8425	60.0000	7642.2000 (29a)
Main Plane	55.8100		55.8100	0.1100	6.1391	9.0000	502.2900 (30)
Bay Roof	1.5000		1.5000	0.1100	0.1650	9.0000	13.5000 (30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)				(26)...(30) + (32) =	77.4456		(33)
Internal Wall 1			73.8800			75.0000	5541.0000 (32c)
Internal Wall 2			199.2400			9.0000	1793.1600 (32c)
Internal Floor 1			55.8100			18.0000	1004.5800 (32d)
Internal Ceiling 1			55.8100			18.0000	1004.5800 (32e)
Heat capacity Cm = Sum(A x k)							(28)...(30) + (32) + (32a)...(32e) = 21765.8100 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							193.1819 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							10.3899 (36)
Total fabric heat loss							(33) + (36) = 87.8355 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m	53.5816	53.2582	52.9412	51.4523	51.1737	49.8769	49.8769	49.6368	50.3764	51.1737	51.7373	52.3265 (38)
Heat transfer coeff	141.4171	141.0937	140.7767	139.2878	139.0092	137.7124	137.7124	137.4723	138.2119	139.0092	139.5728	140.1619 (39)
Average = Sum(39)m / 12 =												139.2865 (39)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP	1.2551	1.2523	1.2495	1.2362	1.2338	1.2223	1.2223	1.2201	1.2267	1.2338	1.2388	1.2440 (40)
HLP (average)												1.2362 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy	2.8299 (42)
Average daily hot water use (litres/day)	101.4110 (43)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)

Regs Region: England

Elmhurst Energy Systems

SAP2012 Calculator (Design

System) version 4.14r16

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)

CALCULATION OF ENERGY RATINGS FOR IMPROVED DWELLING 09 Jan 2014

Energy content (annual)												Total = Sum(45)m =	1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m													
	24.8143	21.7027	22.3953	19.5247	18.7345	16.1664	14.9806	17.1904	17.3957	20.2730	22.1296	24.0313 (46)	
Water storage loss:													
Total storage loss													
	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)	
If cylinder contains dedicated solar storage													
	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)	
Combi loss	14.1536	12.7725	14.1149	13.6233	14.0423	13.5489	13.9753	14.0188	13.5894	14.0809	13.6669	14.1411 (61)	
Total heat required for water heating calculated for each month													
	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (62)	
Aperture area of solar collector													3.0000 (H1)
Zero-loss collector efficiency													0.7000 (H2)
Collector heat loss coefficient													1.8000 (H3)
Collector 2nd order heat loss coefficient													0.0050 (H3a)
Collector effective heat loss coefficient													1.8063 (H3b)
Collector performance ratio													2.5804 (H4)
Annual solar radiation per m2													1079.5246 (H5)
Overshading factor													0.8000 (H6)
Solar energy available													1813.6014 (H7)
Adjustment factor for showers													1.0000 (H7a)
Solar-to-load ratio													1.1366 (H8)
Utilisation factor													0.5851 (H9)
Collector performance factor													0.8793 (H10)
Dedicated solar storage volume													75.0000 (H11)
Effective solar volume													75.0000 (H13)
Daily hot water demand													101.4110 (H14)
Volume ratio Veff/V													0.7396 (H15)
Solar storage volume factor													0.9397 (H16)
Solar input													-876.7982 (H17)
Solar input	-25.4254	-42.4277	-72.2592	-96.8416	-119.6396	-117.6248	-116.0703	-101.4112	-79.4253	-54.2382	-30.1582	-21.2767 (63)	
	Solar input (sum of months) = Sum(63)m =											-876.7982 (63)	
Output from w/h	154.1568	115.0297	91.1575	46.9467	19.2991	3.7002	0.0000	27.2102	50.1355	94.9963	131.0394	153.0731 (64)	
	Total per year (kWh/year) = Sum(64)m =											886.7445 (64)	
Heat gains from water heating, kWh/month													
	58.5434	51.3009	53.1716	46.6857	45.0386	39.2228	36.7007	41.6101	41.9579	48.4588	52.4707	56.8047 (65)	

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	64.1551	56.9820	46.3409	35.0830	26.2250	22.1402	23.9233	31.0964	41.7375	52.9954	61.8534	65.9382	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	410.9517	415.2160	404.4699	381.5927	352.7143	325.5726	307.4404	303.1760	313.9221	336.7993	365.6777	392.8194	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	78.6874	76.3406	71.4672	64.8412	60.5358	54.4761	49.3289	55.9275	58.2748	65.1328	72.8759	76.3504	(72)
Total internal gains	668.2024	662.9469	636.6863	595.9252	553.8833	516.5973	495.1009	504.6082	528.3427	569.3358	614.8154	649.5162	(73)

6. Solar gains

[Jan]	Area m2	Solar flux Table 6a W/m2	Specific data or Table 6b	g	FF Specific data or Table 6c	Access factor Table 6d	Gains W	
North	7.2400	10.6334	0.4400		0.0000	0.7700	26.0828	(74)
East	0.8400	19.6403	0.4400		0.0000	0.7700	5.5895	(76)
South	8.3200	46.7521	0.4400		0.0000	0.7700	131.7855	(78)
West	1.4400	19.6403	0.4400		0.0000	0.7700	9.5819	(80)

Solar gains	173.0396	295.3546	408.5059	518.0630	594.4316	597.2395	572.7804	514.1381	445.8784	327.3442	207.3041	148.0949	(83)
Total gains	841.2421	958.3015	1045.1922	1113.9863	1148.3149	1113.8368	1067.8813	1018.7464	974.2211	896.6800	822.1195	797.6111	(84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)												21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)												
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
tau	42.7534	42.8514	42.9479	43.4069	43.4939	43.9035	43.9035	43.9802	43.7448	43.4939	43.3183	43.1362
alpha	3.8502	3.8568	3.8632	3.8938	3.8996	3.9269	3.9269	3.9320	3.9163	3.8996	3.8879	3.8757
util living area	0.9878	0.9790	0.9618	0.9221	0.8402	0.6951	0.5392	0.5808	0.7880	0.9348	0.9792	0.9900 (86)
MIT	19.4802	19.6751	19.9700	20.3438	20.6728	20.8928	20.9698	20.9593	20.8142	20.3940	19.8690	19.4422 (87)
Th 2	19.8761	19.8784	19.8806	19.8911	19.8931	19.9022	19.9022	19.9039	19.8987	19.8931	19.8891	19.8850 (88)
util rest of house	0.9847	0.9736	0.9515	0.8999	0.7926	0.6064	0.4172	0.4594	0.7126	0.9116	0.9729	0.9874 (89)
MIT 2	17.8774	18.1607	18.5859	19.1194	19.5589	19.8220	19.8886	19.8839	19.7418	19.1999	18.4513	17.8281 (90)
Living area fraction	fLA = Living area / (4) =											0.1278 (91)
MIT	18.0822	18.3542	18.7628	19.2759	19.7012	19.9589	20.0268	20.0213	19.8788	19.3525	18.6325	18.0344 (92)
Temperature adjustment												-0.1500
adjusted MIT	17.9322	18.2042	18.6128	19.1259	19.5512	19.8089	19.8768	19.8713	19.7288	19.2025	18.4825	17.8844 (93)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)

Calculation of Energy Ratings for Improved Dwelling 09 Jan 2014

8. Space heating requirement

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Utilisation	0.9764	0.9619	0.9356	0.8804	0.7752	0.5980	0.4142	0.4555	0.6989	0.8923	0.9612	0.9802	(94)
Useful gains	821.4214	921.8265	977.9111	980.7412	890.1631	666.1059	442.2818	464.0364	680.9147	800.1269	790.2174	781.8543	(95)
Ext temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	(96)
Heat loss rate W	1927.8293	1877.1454	1705.2015	1424.3457	1091.3948	717.3299	451.2593	477.2089	777.9722	1195.8259	1588.6839	1918.0372	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(97a)
Space heating kWh	823.1675	641.9743	541.1041	319.3952	149.7164	0.0000	0.0000	0.0000	0.0000	294.4001	574.8959	845.3201	(98)
Space heating												4189.9736	(98)
Space heating per m2												37.1880	(99)

(98) / (4) = 37.1880 (99)

8c. Space cooling requirement

Not applicable

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 11)													0.0000 (201)
Fraction of space heat from main system(s)													1.0000 (202)
Efficiency of main space heating system 1 (in %)													90.5000 (206)
Efficiency of secondary/supplementary heating system, %													0.0000 (208)
Space heating requirement													4629.8050 (211)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Space heating requirement	823.1675	641.9743	541.1041	319.3952	149.7164	0.0000	0.0000	0.0000	0.0000	294.4001	574.8959	845.3201	(98)
Space heating efficiency (main heating system 1)	90.5000	90.5000	90.5000	90.5000	90.5000	0.0000	0.0000	0.0000	0.0000	90.5000	90.5000	90.5000	(210)
Space heating fuel (main heating system)	909.5774	709.3639	597.9051	352.9229	165.4325	0.0000	0.0000	0.0000	0.0000	325.3040	635.2441	934.0553	(211)
Water heating requirement	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(215)
Water heating													
Water heating requirement	154.1568	115.0297	91.1575	46.9467	19.2991	3.7002	0.0000	27.2102	50.1355	94.9963	131.0394	153.0731	(64)
Efficiency of water heater	89.9798	89.9987	90.0242	90.0769	90.1228	87.3000	87.3000	87.3000	87.3000	89.6979	89.8884	87.3000	(216)
(217)m	89.9798	89.9987	90.0242	90.0769	90.1228	87.3000	87.3000	87.3000	87.3000	89.6979	89.8884	87.3000	(217)
Fuel for water heating, kWh/month	171.3238	127.8126	101.2589	52.1184	21.4142	4.2385	0.0000	31.1687	57.4290	105.9070	145.7801	170.0921	(219)
Water heating fuel used												988.5433	(219)
Annual totals kWh/year													
Space heating fuel - main system												4629.8050	(211)
Space heating fuel - secondary												0.0000	(215)
Electricity for pumps and fans:													
central heating pump												30.0000	(230c)
main heating flue fan												45.0000	(230e)
pump for solar water heating												50.0000	(230g)
Total electricity for the above, kWh/year												125.0000	(231)
Electricity for lighting (calculated in Appendix L)												453.1995	(232)
Energy saving/generation technologies (Appendices M, N and Q)													
PV Unit 0 (0.80 * 2.50 * 1080 * 0.80) =										-1727.2394		-1727.2394	(233)
Total delivered energy for all uses												4469.3085	(238)

10a. Fuel costs - using Table 12 prices

	Fuel kWh/year	Fuel price p/kWh	Fuel cost £/year
Space heating - main system 1	4629.8050	3.4800	161.1172 (240)
Space heating - secondary	0.0000	0.0000	0.0000 (242)
Water heating (other fuel)	988.5433	3.4800	34.4013 (247)
Pumps and fans for heating	75.0000	13.1900	9.8925 (249)
Pump for solar water heating	50.0000	13.1900	6.5950 (249)
Energy for lighting	453.1995	13.1900	59.7770 (250)
Additional standing charges			120.0000 (251)
Energy saving/generation technologies			
PV Unit	-1727.2394	13.1900	-227.8229 (252)
Total energy cost			163.9602 (255)

11a. SAP rating - Individual heating systems

Energy cost deflator (Table 12):		0.4200 (256)
Energy cost factor (ECF)	[(255) x (256)] / [(4) + 45.0] =	0.4368 (257)
SAP value		93.9073
SAP rating (Section 12)		94 (258)
SAP band		A

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF ENERGY RATINGS FOR IMPROVED DWELLING 09 Jan 2014

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating - main system 1	4629.8050	0.2160	1000.0379 (261)
Space heating - secondary	0.0000	0.0000	0.0000 (263)
Water heating (other fuel)	988.5433	0.2160	213.5254 (264)
Space and water heating			1213.5632 (265)
Pumps and fans	125.0000	0.5190	64.8750 (267)
Energy for lighting	453.1995	0.5190	235.2106 (268)
Energy saving/generation technologies			
PV Unit	-1727.2394	0.5190	-896.4372 (269)
Total kg/year			617.2115 (272)
CO2 emissions per m2			5.4800 (273)
EI value			94.7545
EI rating			95 (274)
EI band			A

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY FOR IMPROVED DWELLING 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
 CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY FOR IMPROVED DWELLING 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m ³ per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c)					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor			(20) = 1 - [0.075 x (19)]	=	0.8500 (20)
Infiltration rate adjusted to include shelter factor			(21) = (18) x (20)	=	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	4.2000	4.0000	4.0000	3.7000	3.7000	3.3000	3.4000	3.2000	3.3000	3.5000	3.5000	3.8000 (22)
Wind factor	1.0500	1.0000	1.0000	0.9250	0.9250	0.8250	0.8500	0.8000	0.8250	0.8750	0.8750	0.9500 (22a)
Adj infilt rate	0.3533	0.3365	0.3365	0.3112	0.3112	0.2776	0.2860	0.2692	0.2776	0.2944	0.2944	0.3196 (22b)
Effective ac	0.5624	0.5566	0.5566	0.5484	0.5484	0.5385	0.5409	0.5362	0.5385	0.5433	0.5433	0.5511 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Opening Type 1			2.1500	1.4000	3.0100		(26)
Opening Type 2 (Uw = 1.30)			17.8400	1.2357	22.0456		(27)
Opening Type 3			2.1500	1.6000	3.4400		(26a)
Heat Loss Floor 1			56.8600	0.1900	10.8034	75.0000	4264.5000 (28a)
Brick Cavity	149.5100	22.1400	127.3700	0.2500	31.8425	60.0000	7642.2000 (29a)
Main Plane	55.8100		55.8100	0.1100	6.1391	9.0000	502.2900 (30)
Bay Roof	1.5000		1.5000	0.1100	0.1650	9.0000	13.5000 (30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)				(26)...(30) + (32) =	77.4456		(33)
Internal Wall 1			73.8800			75.0000	5541.0000 (32c)
Internal Wall 2			199.2400			9.0000	1793.1600 (32c)
Internal Floor 1			55.8100			18.0000	1004.5800 (32d)
Internal Ceiling 1			55.8100			18.0000	1004.5800 (32e)
Heat capacity Cm = Sum(A x k)						(28)...(30) + (32) + (32a)...(32e) =	21765.8100 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							193.1819 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							10.3899 (36)
Total fabric heat loss						(33) + (36) =	87.8355 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m	50.9016	50.3764	50.3764	49.6368	49.6368	48.7402	48.9548	48.5321	48.7402	49.1757	49.1757	49.8769 (38)
Heat transfer coeff	138.7371	138.2119	138.2119	137.4723	137.4723	136.5757	136.7903	136.3676	136.5757	137.0112	137.0112	137.7124 (39)
Average = Sum(39)m / 12 =												137.3458 (39)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP	1.2314	1.2267	1.2267	1.2201	1.2201	1.2122	1.2141	1.2103	1.2122	1.2160	1.2160	1.2223 (40)
HLP (average)												1.2190 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)

Regs Region: England

Elmhurst Energy Systems

SAP2012 Calculator (Design

System) version 4.14r16

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)

CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY FOR IMPROVED DWELLING 09 Jan 2014

Energy content (annual)												Total = Sum(45)m =	1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m													
	24.8143	21.7027	22.3953	19.5247	18.7345	16.1664	14.9806	17.1904	17.3957	20.2730	22.1296	24.0313 (46)	
Water storage loss:													
Total storage loss													
	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)	
If cylinder contains dedicated solar storage													
	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)	
Combi loss	14.1536	12.7725	14.1149	13.6233	14.0423	13.5489	13.9753	14.0188	13.5894	14.0809	13.6669	14.1411 (61)	
Total heat required for water heating calculated for each month													
	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (62)	
Aperture area of solar collector												3.0000 (H1)	
Zero-loss collector efficiency												0.7000 (H2)	
Collector heat loss coefficient												1.8000 (H3)	
Collector 2nd order heat loss coefficient												0.0050 (H3a)	
Collector effective heat loss coefficient												1.8063 (H3b)	
Collector performance ratio												2.5804 (H4)	
Annual solar radiation per m2												1140.0998 (H5)	
Overshading factor												0.8000 (H6)	
Solar energy available												1915.3676 (H7)	
Adjustment factor for showers												1.0000 (H7a)	
Solar-to-load ratio												1.2004 (H8)	
Utilisation factor												0.5653 (H9)	
Collector performance factor												0.8793 (H10)	
Dedicated solar storage volume												75.0000 (H11)	
Effective solar volume												75.0000 (H13)	
Daily hot water demand												101.4110 (H14)	
Volume ratio Veff/V												0.7396 (H15)	
Solar storage volume factor												0.9397 (H16)	
Solar input												-894.5790 (H17)	
Solar input	-27.5347	-41.3846	-69.6969	-96.3424	-116.0287	-122.1152	-119.1829	-106.4311	-83.0698	-56.5109	-33.4691	-22.8127 (63)	
	Solar input (sum of months) = Sum(63)m =											-894.5790 (63)	
Output from w/h													
	152.0475	116.0728	93.7198	47.4458	22.9100	0.0000	0.0000	22.1904	46.4910	92.7236	127.7284	151.5371 (64)	
	Total per year (kWh/year) = Sum(64)m =											872.8665 (64)	
Heat gains from water heating, kWh/month													
	58.5434	51.3009	53.1716	46.6857	45.0386	39.2228	36.7007	41.6101	41.9579	48.4588	52.4707	56.8047 (65)	

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	64.1551	56.9820	46.3409	35.0830	26.2250	22.1402	23.9233	31.0964	41.7375	52.9954	61.8534	65.9382	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	410.9517	415.2160	404.4699	381.5927	352.7143	325.5726	307.4404	303.1760	313.9221	336.7993	365.6777	392.8194	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	78.6874	76.3406	71.4672	64.8412	60.5358	54.4761	49.3289	55.9275	58.2748	65.1328	72.8759	76.3504	(72)
Total internal gains	668.2024	662.9469	636.6863	595.9252	553.8833	516.5973	495.1009	504.6082	528.3427	569.3358	614.8154	649.5162	(73)

6. Solar gains

[Jan]	Area m2	Solar flux Table 6a W/m2	Specific data or Table 6b	g	FF Specific data or Table 6c	Access factor Table 6d	Gains W	
North	7.2400	11.9814	0.4400		0.0000	0.7700	29.3894	(74)
East	0.8400	22.3313	0.4400		0.0000	0.7700	6.3553	(76)
South	8.3200	50.9848	0.4400		0.0000	0.7700	143.7168	(78)
West	1.4400	22.3313	0.4400		0.0000	0.7700	10.8948	(80)

Solar gains	190.3564	292.5741	401.1166	527.7688	593.4473	639.6574	606.1981	553.8342	475.7176	346.5355	233.6492	161.3447	(83)
Total gains	858.5588	955.5210	1037.8029	1123.6940	1147.3307	1156.2547	1101.2991	1058.4424	1004.0603	915.8713	848.4646	810.8609	(84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9a, Th1 (C)												21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)												
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
tau	43.5793	43.7448	43.7448	43.9802	43.9802	44.2689	44.1995	44.3365	44.2689	44.1282	44.1282	43.9035
alpha	3.9053	3.9163	3.9163	3.9320	3.9320	3.9513	3.9466	3.9558	3.9513	3.9419	3.9419	3.9269
util living area	0.9845	0.9756	0.9538	0.8984	0.7800	0.5580	0.3795	0.4049	0.6945	0.9075	0.9711	0.9872 (86)
MIT	19.6420	19.8048	20.1109	20.4833	20.7951	20.9622	20.9939	20.9922	20.9049	20.5426	20.0414	19.6107 (87)
Th 2	19.8950	19.8987	19.8987	19.9039	19.9039	19.9103	19.9088	19.9117	19.9103	19.9072	19.9072	19.9022 (88)
util rest of house	0.9804	0.9691	0.9409	0.8690	0.7156	0.4499	0.2487	0.2709	0.5961	0.8740	0.9620	0.9837 (89)
MIT 2	18.1249	18.3619	18.7997	19.3195	19.7163	19.8899	19.9075	19.9100	19.8446	19.4119	18.7115	18.0848 (90)
Living area fraction	fLA = Living area / (4) =											0.1278 (91)
MIT	18.3188	18.5463	18.9673	19.4682	19.8542	20.0269	20.0463	20.0483	19.9801	19.5564	18.8815	18.2798 (92)
Temperature adjustment												-0.1500
adjusted MIT	18.1688	18.3963	18.8173	19.3182	19.7042	19.8769	19.8963	19.8983	19.8301	19.4064	18.7315	18.1298 (93)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)

CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY FOR IMPROVED DWELLING 09 Jan 2014

8. Space heating requirement

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Utilisation	0.9708	0.9567	0.9240	0.8495	0.7022	0.4464	0.2472	0.2692	0.5881	0.8544	0.9482	0.9753	(94)
Useful gains	833.5258	914.1083	958.9148	954.5704	805.6386	516.1040	272.2427	284.9530	590.4418	782.5173	804.4755	790.8194	(95)
Ext temp.	5.1000	5.6000	7.4000	9.9000	13.0000	16.0000	17.9000	17.8000	15.2000	11.6000	8.0000	5.1000	(96)
Heat loss rate W	1813.1216	1768.6018	1578.0110	1294.7460	921.6418	529.4965	273.0799	286.1363	632.3609	1069.5651	1470.3379	1794.3645	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(97a)
Space heating kWh	728.8193	574.2197	460.6075	244.9264	86.3064	0.0000	0.0000	0.0000	0.0000	213.5636	479.4209	746.6376	(98)
Space heating												3534.5014	(98)
Space heating per m2											(98) / (4) =	31.3704	(99)

8c. Space cooling requirement

Not applicable

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 11)													0.0000	(201)
Fraction of space heat from main system(s)													1.0000	(202)
Efficiency of main space heating system 1 (in %)													90.5000	(206)
Efficiency of secondary/supplementary heating system, %													0.0000	(208)
Space heating requirement													3905.5264	(211)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
Space heating requirement	728.8193	574.2197	460.6075	244.9264	86.3064	0.0000	0.0000	0.0000	0.0000	213.5636	479.4209	746.6376	(98)	
Space heating efficiency (main heating system 1)	90.5000	90.5000	90.5000	90.5000	90.5000	0.0000	0.0000	0.0000	0.0000	90.5000	90.5000	90.5000	(210)	
Space heating fuel (main heating system)	805.3252	634.4969	508.9586	270.6369	95.3662	0.0000	0.0000	0.0000	0.0000	235.9818	529.7469	825.0139	(211)	
Water heating requirement	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(215)	
Water heating														
Water heating requirement	152.0475	116.0728	93.7198	47.4458	22.9100	0.0000	0.0000	22.1904	46.4910	92.7236	127.7284	151.5371	(64)	
Efficiency of water heater	89.9310	89.9456	89.9426	89.9649	89.8095	87.3000	87.3000	87.3000	87.3000	89.5068	89.8075	87.3000	(216)	
(217)m	89.9310	89.9456	89.9426	89.9649	89.8095	87.3000	87.3000	87.3000	87.3000	89.5068	89.8075	89.9438	(217)	
Fuel for water heating, kWh/month	169.0713	129.0478	104.1996	52.7381	25.5096	0.0000	0.0000	25.4186	53.2543	103.5940	142.2247	168.4799	(219)	
Water heating fuel used												973.5378	(219)	
Annual totals kWh/year														
Space heating fuel - main system												3905.5264	(211)	
Space heating fuel - secondary												0.0000	(215)	
Electricity for pumps and fans:														
central heating pump												30.0000	(230c)	
main heating flue fan												45.0000	(230e)	
pump for solar water heating												50.0000	(230g)	
Total electricity for the above, kWh/year												125.0000	(231)	
Electricity for lighting (calculated in Appendix L)												453.1995	(232)	
Energy saving/generation technologies (Appendices M ,N and Q)														
PV Unit 0 (0.80 * 2.50 * 1140 * 0.80) =										-1824.1596		-1824.1596	(233)	
Total delivered energy for all uses												3633.1041	(238)	

10a. Fuel costs - using BEDF prices (470)


	Fuel kWh/year	Fuel price p/kWh	Fuel cost £/year	
Space heating - main system 1	3905.5264	3.8700	151.1439	(240)
Space heating - secondary	0.0000	0.0000	0.0000	(242)
Water heating (other fuel)	973.5378	3.8700	37.6759	(247)
Pumps and fans for heating	75.0000	18.9000	14.1750	(249)
Pump for solar water heating	50.0000	18.9000	9.4500	(249)
Energy for lighting	453.1995	18.9000	85.6547	(250)
Additional standing charges			93.0000	(251)
Energy saving/generation technologies				
PV Unit	-1824.1596	18.9000	-344.7662	(252)
Total energy cost			46.3333	(255)

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year	
Space heating - main system 1	3905.5264	0.2160	843.5937	(261)
Space heating - secondary	0.0000	0.0000	0.0000	(263)
Water heating (other fuel)	973.5378	0.2160	210.2842	(264)
Space and water heating			1053.8779	(265)
Pumps and fans	125.0000	0.5190	64.8750	(267)
Energy for lighting	453.1995	0.5190	235.2106	(268)
Energy saving/generation technologies				

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY FOR IMPROVED DWELLING 09 Jan 2014

PV Unit	-1824.1596	0.5190	-946.7389 (269)
Total kg/year			407.2246 (272)

13a. Primary energy - Individual heating systems including micro-CHP

	Energy kWh/year	Primary energy factor kg CO2/kWh	Primary energy kWh/year
Space heating - main system 1	3905.5264	1.2200	4764.7422 (261)
Space heating - secondary	0.0000	0.0000	0.0000 (263)
Water heating (other fuel)	973.5378	1.2200	1187.7162 (264)
Space and water heating			5952.4584 (265)
Pumps and fans	125.0000	3.0700	383.7500 (267)
Energy for lighting	453.1995	3.0700	1391.3225 (268)
Energy saving/generation technologies			
PV Unit	-1824.1596	3.0700	-5600.1701 (269)
Primary energy kWh/year			2127.3608 (272)
Primary energy kWh/m2/year			18.8813 (273)

SAP 2012 OVERHEATING ASSESSMENT FOR New Build (As Designed) 9.92

Overheating Calculation Input Data

Dwelling type	Detached House
Number of storeys	2
Cross ventilation possible	Yes
SAP Region	Thames Valley
Front of dwelling faces	North
Overshading	Average or unknown
Thermal mass parameter	193.2 (calculated from construction elements)
Night ventilation	Yes
Ventilation rate during hot weather (ach)	4.00 (Windows half open)

Overheating Calculation

Summer ventilation heat loss coefficient	362.03 (P1)
Transmission heat loss coefficient	87.84 (37)
Summer heat loss coefficient	449.86 (P2)

Overhangs Orientation	Ratio	Z_overhangs	Overhang type
North	0.000	1.000	None
East	0.000	1.000	None
South	0.000	1.000	None
West	0.000	1.000	None

Solar shading Orientation	Z blinds	Solar access	Z overhangs	Z summer
North	1.000	0.90	1.000	0.900 (P8)
East	1.000	0.90	1.000	0.900 (P8)
South	1.000	0.90	1.000	0.900 (P8)
West	1.000	0.90	1.000	0.900 (P8)

[Jul]	Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Shading	Gains W
North	7.2400	81.1852	0.4400	0.0000	0.9000	232.7611
East	0.8400	117.5071	0.4400	0.0000	0.9000	39.0876
South	8.3200	112.2060	0.4400	0.0000	0.9000	369.6873
West	1.4400	117.5071	0.4400	0.0000	0.9000	67.0072
total:						708.5433

	Jun	Jul	Aug	
Solar gains	748	709	647	(P4)
Internal gains	514	492	502	
Total summer gains	1261	1201	1149	(P5)
Summer gain/loss ratio	2.80	2.67	2.55	(P6)
Summer external temperature	16.00	17.90	17.80	
Thermal mass temperature increment (TMP = 193.2)	0.65	0.65	0.65	
Threshold temperature	19.45	21.22	21.00	(P7)
Likelihood of high internal temperature	Not significant	Slight	Slight	
Assessment of likelihood of high internal temperature:	Slight			