

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



Property Reference	SECANG003d			Issued on Date	04/02/2021
Assessment Reference	001	Prop Type Ref	Det Br Ea Ga		
Property	Coniston+, Plot 78				
SAP Rating	84 B	DER	16.94	TST	17.44
Environmental	85 B	% DER<TER	2.87		
CO ₂ Emissions (t/year)	1.57	DPEE	51.39	TPEE	56.04
General Requirements Compliance	Pass	% DPEE<TPEE	8.31		
Assessor Details	Mr. Stuart Harvey, Stuart Harvey [REDACTED]			Assessor ID	T555-0001
Client	[REDACTED]				

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



REGULATIONS COMPLIANCE REPORT - Approved Document L1A, 2013 Edition, England

REGULATIONS COMPLIANCE REPORT - Approved Document L1A, 2013 Edition, England

DWELLING AS DESIGNED

Detached House, total floor area 113 m²

This report covers items included within the SAP calculations.
It is not a complete report of regulations compliance.

1a TER and DER

Fuel for main heating:Mains gas
Fuel factor:1.00 (mains gas)
Target Carbon Dioxide Emission Rate (TER) 17.44 kgCO₂/m²
Dwelling Carbon Dioxide Emission Rate (DER) 16.94 kgCO₂/m²OK

1b TFEE and DFEE

Target Fabric Energy Efficiency (TFEE)56.0 kWh/m²/yr
Dwelling Fabric Energy Efficiency (DFEE)51.4 kWh/m²/yrOK

2 Fabric U-values

Element	Average	Highest	
External wall	0.25 (max. 0.30)	0.25 (max. 0.70)	OK
Party wall	0.00 (max. 0.20)	-	OK
Floor	0.19 (max. 0.25)	0.19 (max. 0.70)	OK
Roof	0.11 (max. 0.20)	0.11 (max. 0.35)	OK
Openings	1.34 (max. 2.00)	1.60 (max. 3.30)	OK

2a Thermal bridging

Thermal bridging calculated from linear thermal transmittances for each junction

3 Air permeability

Air permeability at 50 pascals: 5.00 (design value)
Maximum 10.0 OK

4 Heating efficiency

Main heating system: Boiler system with radiators or underfloor - Mains gas
Data from database
Ideal LOGIC COMBI ESP1 35
Combi boiler
Efficiency: 89.6% SEDBUK2009
Minimum: 88.0% OK

Secondary heating system:

None

5 Cylinder insulation

Hot water storage No cylinder

6 Controls

Space heating controls: Time and temperature zone control OK

Hot water controls:

No cylinder

Boiler interlock

Yes

OK

7 Low energy lights

Percentage of fixed lights with low-energy fittings:100%
Minimum 75% OK

8 Mechanical ventilation

Not applicable

9 Summertime temperature

Overheating risk (Thames Valley): Slight OK

Based on:

Overshading: Average
Windows facing North East: 8.32 m², No overhang
Windows facing South East: 0.84 m², No overhang
Windows facing South West: 7.24 m², No overhang
Windows facing North West: 1.44 m², No overhang
Air change rate: 4.00 ach
Blinds/curtains: None

10 Key features

Party wall U-value 0.00 W/m²K
Roof U-value 0.11 W/m²K
Roof U-value 0.11 W/m²K
Thermal bridging y-value 0.039 W/m²K

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF DWELLING EMISSIONS FOR REGULATIONS COMPLIANCE 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF DWELLING EMISSIONS FOR REGULATIONS COMPLIANCE 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m3 per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =				40.0000 / (5) =	0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor			(20) = 1 - [0.075 x (19)] =		0.8500 (20)
Infiltration rate adjusted to include shelter factor			(21) = (18) x (20) =		0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000 (22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750 (22a)
Adj infilt rate	0.4290	0.4206	0.4122	0.3701	0.3617	0.3196	0.3196	0.3112	0.3365	0.3617	0.3785	0.3954 (22b)
Effective ac	0.5920	0.5884	0.5849	0.5685	0.5654	0.5511	0.5511	0.5484	0.5566	0.5654	0.5716	0.5782 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Opening Type 1			2.1500	1.4000	3.0100		(26)
Opening Type 2 (Uw = 1.30)			17.8400	1.2357	22.0456		(27)
Opening Type 3			2.1500	1.6000	3.4400		(26a)
Heat Loss Floor 1			56.8600	0.1900	10.8034	75.0000	4264.5000 (28a)
Brick Cavity	149.5100	22.1400	127.3700	0.2500	31.8425	60.0000	7642.2000 (29a)
Main Plane	55.8100		55.8100	0.1100	6.1391	9.0000	502.2900 (30)
Bay Roof	1.5000		1.5000	0.1100	0.1650	9.0000	13.5000 (30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)				(26)...(30) + (32) =	77.4456		(33)
Internal Wall 1			73.8800			75.0000	5541.0000 (32c)
Internal Wall 2			199.2400			9.0000	1793.1600 (32c)
Internal Floor 1			55.8100			18.0000	1004.5800 (32d)
Internal Ceiling 1			55.8100			18.0000	1004.5800 (32e)
Heat capacity Cm = Sum(A x k)						(28)...(30) + (32) + (32a)...(32e) =	21765.8100 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							193.1819 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							10.3899 (36)
Total fabric heat loss						(33) + (36) =	87.8355 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m	53.5816	53.2582	52.9412	51.4523	51.1737	49.8769	49.8769	49.6368	50.3764	51.1737	51.7373	52.3265 (38)
Heat transfer coeff	141.4171	141.0937	140.7767	139.2878	139.0092	137.7124	137.7124	137.4723	138.2119	139.0092	139.5728	140.1619 (39)
Average = Sum(39)m / 12 =												139.2865 (39)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP	1.2551	1.2523	1.2495	1.2362	1.2338	1.2223	1.2223	1.2201	1.2267	1.2338	1.2388	1.2440 (40)
HLP (average)												1.2362 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF DWELLING EMISSIONS FOR REGULATIONS COMPLIANCE 09 Jan 2014

Energy content (annual)												Total = Sum(45)m =	1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m													
	24.8143	21.7027	22.3953	19.5247	18.7345	16.1664	14.9806	17.1904	17.3957	20.2730	22.1296	24.0313	(46)
Water storage loss:													
Total storage loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(56)
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(57)
Combi loss	14.1536	12.7725	14.1149	13.6233	14.0423	13.5489	13.9753	14.0188	13.5894	14.0809	13.6669	14.1411	(61)
Total heat required for water heating calculated for each month	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498	(62)
Solar input	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(63)
Solar input (sum of months) = Sum(63)m =												0.0000	(63)
Output from w/h	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498	(64)
Heat gains from water heating, kWh/month	58.5434	51.3009	53.1716	46.6857	45.0386	39.2228	36.7007	41.6101	41.9579	48.4588	52.4707	56.8047	(65)
Total per year (kWh/year) = Sum(64)m =												1761.3181	(64)

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	25.6620	22.7928	18.5363	14.0332	10.4900	8.8561	9.5693	12.4386	16.6950	21.1981	24.7414	26.3753	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	275.3376	278.1948	270.9948	255.6671	236.3186	218.1337	205.9850	203.1279	210.3278	225.6556	245.0041	263.1890	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	78.6874	76.3406	71.4672	64.8412	60.5358	54.4761	49.3289	55.9275	58.2748	65.1328	72.8759	76.3504	(72)
Total internal gains	448.1361	445.7772	429.4474	402.9906	375.7934	349.9149	333.3324	339.9431	353.7467	380.4355	411.0704	434.3637	(73)

6. Solar gains

[Jan]					Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Access factor Table 6d		Gains W	
Northeast					8.3200	11.2829	0.4400	0.0000	0.7700		31.8045 (75)	
Southeast					0.8400	36.7938	0.4400	0.0000	0.7700		10.4712 (77)	
Southwest					7.2400	36.7938	0.4400	0.0000	0.7700		90.2520 (79)	
Northwest					1.4400	11.2829	0.4400	0.0000	0.7700		5.5046 (81)	
Solar gains	138.0324	247.5129	371.5749	515.5732	627.8450	645.4565	613.0704	525.9240	420.9081	282.4297	167.5878	116.6667 (83)
Total gains	586.1685	693.2900	801.0223	918.5637	1003.6384	995.3714	946.4028	865.8670	774.6548	662.8653	578.6583	551.0304 (84)

7. Mean internal temperature (heating season)


Temperature during heating periods in the living area from Table 9, Th1 (C)												21.0000	(85)
Utilisation factor for gains for living area, nil,m (see Table 9a)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
tau	42.7534	42.8514	42.9479	43.4069	43.4939	43.9035	43.9035	43.9802	43.7448	43.4939	43.3183	43.1362	
alpha	3.8502	3.8568	3.8632	3.8938	3.8996	3.9269	3.9269	3.9320	3.9163	3.8996	3.8879	3.8757	
util living area	0.9965	0.9928	0.9835	0.9549	0.8827	0.7459	0.5953	0.6577	0.8701	0.9735	0.9936	0.9972	(86)
MIT	19.2350	19.4269	19.7538	20.1941	20.5942	20.8611	20.9574	20.9370	20.7206	20.2016	19.6397	19.2032	(87)
Th 2	19.8761	19.8784	19.8806	19.8911	19.8931	19.9022	19.9022	19.9039	19.8987	19.8931	19.8891	19.8850	(88)
util rest of house	0.9955	0.9908	0.9785	0.9404	0.8429	0.6596	0.4661	0.5303	0.8099	0.9625	0.9915	0.9965	(89)
MIT 2	17.5213	17.8027	18.2792	18.9169	19.4651	19.7944	19.8822	19.8709	19.6440	18.9378	18.1213	17.4805	(90)
Living area fraction	17.7404	18.0103	18.4676	19.0801	19.6094	19.9307	20.0196	20.0071	19.7816	19.0993	18.3153	17.7007	(91)
MIT	17.7404	18.0103	18.4676	19.0801	19.6094	19.9307	20.0196	20.0071	19.7816	19.0993	18.3153	17.7007	(92)
Temperature adjustment	17.5904	17.8603	18.3176	18.9301	19.4594	19.7807	19.8696	19.8571	19.6316	18.9493	18.1653	17.5507	(93)
adjusted MIT	17.5904	17.8603	18.3176	18.9301	19.4594	19.7807	19.8696	19.8571	19.6316	18.9493	18.1653	17.5507	(93)

8. Space heating requirement

Utilisation	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
	0.9922	0.9851	0.9683	0.9232	0.8235	0.6487	0.4619	0.5242	0.7913	0.9484	0.9861	0.9938	(94)
Useful gains	581.6088	682.9779	775.6263	848.0303	826.5292	645.6584	437.1640	453.8815	613.0037	628.6705	570.6314	547.6188	(95)
Ext temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	(96)
Heat loss rate W	1879.4852	1828.6118	1663.6469	1397.0771	1078.6265	713.4498	450.2707	475.2611	764.5346	1160.6313	1544.4214	1871.2589	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(97a)
Space heating kWh	965.6201	769.8659	660.6873	395.3137	187.5604	0.0000	0.0000	0.0000	0.0000	395.7789	701.1288	984.7882	(98)
Space heating												5060.7433	(98)
Space heating per m2												(98) / (4) =	44.9165 (99)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF DWELLING EMISSIONS FOR REGULATIONS COMPLIANCE 09 Jan 2014

8c. Space cooling requirement

Not applicable

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 11)													0.0000 (201)
Fraction of space heat from main system(s)													1.0000 (202)
Efficiency of main space heating system 1 (in %)													90.5000 (206)
Efficiency of secondary/supplementary heating system, %													0.0000 (208)
Space heating requirement													5591.9815 (211)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Space heating requirement	965.6201	769.8659	660.6873	395.3137	187.5604	0.0000	0.0000	0.0000	0.0000	395.7789	701.1288	984.7882	(98)
Space heating efficiency (main heating system 1)	90.5000	90.5000	90.5000	90.5000	90.5000	0.0000	0.0000	0.0000	0.0000	90.5000	90.5000	90.5000	(210)
Space heating fuel (main heating system)	1066.9835	850.6806	730.0412	436.8107	207.2491	0.0000	0.0000	0.0000	0.0000	437.3247	774.7279	1088.1638	(211)
Water heating requirement	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(215)
Water heating													
Water heating requirement	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498	(64)
Efficiency of water heater (217)m	89.9828	89.9402	89.8469	89.6238	89.1100	87.3000	87.3000	87.3000	87.3000	89.6007	89.8841	87.3000	(216)
Fuel for water heating, kWh/month	199.5739	175.0690	181.8835	160.4354	155.9181	138.9748	130.4075	147.3327	148.4088	166.5551	179.3393	193.7139	(219)
Water heating fuel used												1977.6119	(219)
Annual totals kWh/year													
Space heating fuel - main system												5591.9815	(211)
Space heating fuel - secondary												0.0000	(215)
Electricity for pumps and fans:													
central heating pump												30.0000	(230c)
main heating flue fan												45.0000	(230e)
Total electricity for the above, kWh/year												75.0000	(231)
Electricity for lighting (calculated in Appendix L)												453.1995	(232)
Total delivered energy for all uses												8097.7929	(238)

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year	
Space heating - main system 1	5591.9815	0.2160	1207.8680	(261)
Space heating - secondary	0.0000	0.0000	0.0000	(263)
Water heating (other fuel)	1977.6119	0.2160	427.1642	(264)
Space and water heating			1635.0322	(265)
Pumps and fans	75.0000	0.5190	38.9250	(267)
Energy for lighting	453.1995	0.5190	235.2106	(268)
Total CO2, kg/year			1909.1677	(272)
Dwelling Carbon Dioxide Emission Rate (DER)			16.9400	(273)

16 CO2 EMISSIONS ASSOCIATED WITH APPLIANCES AND COOKING AND SITE-WIDE ELECTRICITY GENERATION TECHNOLOGIES

DER		16.9400	ZC1
Total Floor Area	TFA	112.6700	
Assumed number of occupants	N	2.8299	
CO2 emission factor in Table 12 for electricity displaced from grid	EF	0.5190	
CO2 emissions from appliances, equation (L14)		14.4812	ZC2
CO2 emissions from cooking, equation (L16)		1.6590	ZC3
Total CO2 emissions		33.0802	ZC4
Residual CO2 emissions offset from biofuel CHP		0.0000	ZC5
Additional allowable electricity generation, kWh/m²/year		0.0000	ZC6
Resulting CO2 emissions offset from additional allowable electricity generation		0.0000	ZC7
Net CO2 emissions		33.0802	ZC8

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF TARGET EMISSIONS 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF TARGET EMISSIONS 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m3 per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor				(20) = 1 - [0.075 x (19)] =	0.8500 (20)
Infiltration rate adjusted to include shelter factor				(21) = (18) x (20) =	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000 (22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750 (22a)
Adj infilt rate	0.4290	0.4206	0.4122	0.3701	0.3617	0.3196	0.3196	0.3112	0.3365	0.3617	0.3785	0.3954 (22b)
Effective ac	0.5920	0.5884	0.5849	0.5685	0.5654	0.5511	0.5511	0.5484	0.5566	0.5654	0.5716	0.5782 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
TER Opaque door			2.1500	1.0000	2.1500		(26)
TER Semi-glazed door			2.1500	1.2000	2.5800		(26a)
TER Opening Type (Uw = 1.40)			17.8400	1.3258	23.6515		(27)
Heat Loss Floor 1			56.8600	0.1300	7.3918		(28a)
Brick Cavity	149.5100	22.1400	127.3700	0.1800	22.9266		(29a)
Main Plane	55.8100		55.8100	0.1300	7.2553		(30)
Bay Roof	1.5000		1.5000	0.1300	0.1950		(30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)			(26)...(30) + (32) =		66.1502		(33)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							250.0000 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							12.6831 (36)
Total fabric heat loss						(33) + (36) =	78.8333 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)												
(38)m	53.5816	53.2582	52.9412	51.4523	51.1737	49.8769	49.8769	49.6368	50.3764	51.1737	51.7373	52.3265 (38)
Heat transfer coeff	132.4150	132.0916	131.7746	130.2856	130.0071	128.7103	128.7103	128.4701	129.2098	130.0071	130.5706	131.1598 (39)
Average = Sum(39)m / 12 =												130.2843 (39)
HLP	1.1752	1.1724	1.1696	1.1563	1.1539	1.1424	1.1424	1.1402	1.1468	1.1539	1.1589	1.1641 (40)
HLP (average)												1.1563 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)
Energy content (annual)										Total = Sum(45)m =		1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m												
24.8143	21.7027	22.3953	19.5247	18.7345	16.1664	14.9806	17.1904	17.3957	20.2730	22.1296	24.0313 (46)	
Water storage loss:												
Total storage loss												

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF TARGET EMISSIONS 09 Jan 2014

	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)
Combi loss	50.9589	46.0274	50.9589	49.0107	48.5773	45.0098	46.5102	48.5773	49.0107	50.9589	49.3151	50.9589 (61)
Total heat required for water heating calculated for each month	216.3875	190.7123	200.2608	179.1757	173.4737	152.7859	146.3805	163.1800	164.9822	186.1125	196.8457	211.1677 (62)
Solar input	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63)
Output from w/h	216.3875	190.7123	200.2608	179.1757	173.4737	152.7859	146.3805	163.1800	164.9822	186.1125	196.8457	211.1677 (64)
Heat gains from water heating, kWh/month	67.7447	59.6146	62.3826	55.5325	53.6724	47.0880	44.8344	50.2497	50.8132	57.6783	61.3827	66.0091 (65)

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	25.6620	22.7928	18.5363	14.0332	10.4900	8.8561	9.5693	12.4386	16.6950	21.1981	24.7414	26.3753	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	275.3376	278.1948	270.9948	255.6671	236.3186	218.1337	205.9850	203.1279	210.3278	225.6556	245.0041	263.1890	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	91.0547	88.7122	83.8476	77.1285	72.1403	65.4000	60.2613	67.5400	70.5739	77.5246	85.2538	88.7220	(72)
Total internal gains	460.5035	458.1488	441.8278	415.2779	387.3979	360.8388	344.2648	351.5555	366.0457	392.8273	423.4483	446.7353	(73)

6. Solar gains

[Jan]					Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Access factor Table 6d		Gains W	
Northeast					8.3200	11.2829	0.6300	0.7000	0.7700		28.6891 (75)	
Southeast					0.8400	36.7938	0.6300	0.7000	0.7700		9.4455 (77)	
Southwest					7.2400	36.7938	0.6300	0.7000	0.7700		81.4114 (79)	
Northwest					1.4400	11.2829	0.6300	0.7000	0.7700		4.9654 (81)	
Solar gains	124.5115	223.2679	335.1774	465.0704	566.3448	582.2311	553.0174	474.4073	379.6783	254.7645	151.1719	105.2386 (83)
Total gains	585.0150	681.4166	777.0053	880.3483	953.7427	943.0700	897.2822	825.9628	745.7240	647.5918	574.6201	551.9739 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)													21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
tau	59.0893	59.2340	59.3765	60.0550	60.1837	60.7901	60.7901	60.9037	60.5551	60.1837	59.9239	59.6548	
alpha	4.9393	4.9489	4.9584	5.0037	5.0122	5.0527	5.0527	5.0602	5.0370	5.0122	4.9949	4.9770	
util living area	0.9990	0.9976	0.9931	0.9753	0.9154	0.7737	0.6069	0.6724	0.8992	0.9868	0.9978	0.9992	(86)
MIT	19.6501	19.7988	20.0539	20.4023	20.7201	20.9214	20.9818	20.9703	20.8157	20.4061	19.9668	19.6266	(87)
Th 2	19.9399	19.9422	19.9444	19.9551	19.9571	19.9664	19.9664	19.9681	19.9628	19.9571	19.9530	19.9488	(88)
util rest of house	0.9986	0.9967	0.9905	0.9651	0.8788	0.6845	0.4765	0.5421	0.8408	0.9797	0.9969	0.9990	(89)
MIT 2	18.1331	18.3520	18.7255	19.2347	19.6700	19.9112	19.9594	19.9551	19.8034	19.2470	18.6057	18.1049	(90)
Living area fraction	18.3269	18.5369	18.8952	19.3840	19.8042	20.0403	20.0901	20.0848	19.9328	19.3951	18.7796	18.2994	(92)
Temperature adjustment	18.3269	18.5369	18.8952	19.3840	19.8042	20.0403	20.0901	20.0848	19.9328	19.3951	18.7796	18.2994	(93)
adjusted MIT	18.3269	18.5369	18.8952	19.3840	19.8042	20.0403	20.0901	20.0848	19.9328	19.3951	18.7796	18.2994	(93)

8. Space heating requirement


Utilisation	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Useful gains	583.6811	677.9572	766.6462	842.9211	831.9210	652.2510	442.2992	460.8755	625.4640	630.7906	571.8789	551.0300	(94)
Ext temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	(96)
Heat loss rate W	1857.3769	1801.3259	1633.3781	1365.9100	1053.6059	700.2190	449.2058	473.3890	753.6499	1143.4294	1525.0177	1849.2752	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	1.0000	(97a)
Space heating kWh	947.6297	754.9038	644.8486	376.5520	164.9336	0.0000	0.0000	0.0000	0.0000	381.4032	686.2599	965.8944	(98)
Space heating												4922.4251	(98)
Space heating per m ²												43.6889	(99)

8c. Space cooling requirement

Not applicable

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF TARGET EMISSIONS 09 Jan 2014

9a. Energy requirements - Individual heating systems, including micro-CHP


Fraction of space heat from secondary/supplementary system (Table 11)													0.0000 (201)
Fraction of space heat from main system(s)													1.0000 (202)
Efficiency of main space heating system 1 (in %)													93.4000 (206)
Efficiency of secondary/supplementary heating system, %													0.0000 (208)
Space heating requirement													5270.2624 (211)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Space heating requirement	947.6297	754.9038	644.8486	376.5520	164.9336	0.0000	0.0000	0.0000	0.0000	381.4032	686.2599	965.8944	(98)
Space heating efficiency (main heating system 1)	93.4000	93.4000	93.4000	93.4000	93.4000	0.0000	0.0000	0.0000	0.0000	93.4000	93.4000	93.4000	(210)
Space heating fuel (main heating system)	1014.5928	808.2481	690.4160	403.1606	176.5884	0.0000	0.0000	0.0000	0.0000	408.3546	734.7536	1034.1482	(211)
Water heating requirement	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(215)
Water heating requirement	216.3875	190.7123	200.2608	179.1757	173.4737	152.7859	146.3805	163.1800	164.9822	186.1125	196.8457	211.1677	(64)
Efficiency of water heater (217)m	88.3346	88.1636	87.7836	86.8769	84.9244	80.3000	80.3000	80.3000	80.3000	86.8189	87.9346	88.4051	(217)
Fuel for water heating, kWh/month	244.9635	216.3165	228.1300	206.2409	204.2684	190.2689	182.2921	203.2130	205.4572	214.3686	223.8546	238.8635	(219)
Water heating fuel used												2558.2371	(219)
Annual totals kWh/year													
Space heating fuel - main system												5270.2624	(211)
Space heating fuel - secondary												0.0000	(215)
Electricity for pumps and fans:													
central heating pump												30.0000	(230c)
main heating flue fan												45.0000	(230e)
Total electricity for the above, kWh/year												75.0000	(231)
Electricity for lighting (calculated in Appendix L)												453.1995	(232)
Total delivered energy for all uses												8356.6991	(238)

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating - main system 1	5270.2624	0.2160	1138.3767 (261)
Space heating - secondary	0.0000	0.0000	0.0000 (263)
Water heating (other fuel)	2558.2371	0.2160	552.5792 (264)
Space and water heating			1690.9559 (265)
Pumps and fans	75.0000	0.5190	38.9250 (267)
Energy for lighting	453.1995	0.5190	235.2106 (268)
Total CO2, kg/m2/year			1965.0915 (272)
Emissions per m2 for space and water heating			15.0080 (272a)
Fuel factor (mains gas)			1.0000
Emissions per m2 for lighting			2.0876 (272b)
Emissions per m2 for pumps and fans			0.3455 (272c)
Target Carbon Dioxide Emission Rate (TER) = (15.0080 * 1.00) + 2.0876 + 0.3455, rounded to 2 d.p.			17.4400 (273)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF FABRIC ENERGY EFFICIENCY 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF FABRIC ENERGY EFFICIENCY 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m3 per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c)					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor			(20) = 1 - [0.075 x (19)]	=	0.8500 (20)
Infiltration rate adjusted to include shelter factor			(21) = (18) x (20)	=	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000 (22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750 (22a)
Adj infilt rate	0.4290	0.4206	0.4122	0.3701	0.3617	0.3196	0.3196	0.3112	0.3365	0.3617	0.3785	0.3954 (22b)
Effective ac	0.5920	0.5884	0.5849	0.5685	0.5654	0.5511	0.5511	0.5484	0.5566	0.5654	0.5716	0.5782 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Opening Type 1			2.1500	1.4000	3.0100		(26)
Opening Type 2 (Uw = 1.30)			17.8400	1.2357	22.0456		(27)
Opening Type 3			2.1500	1.6000	3.4400		(26a)
Heat Loss Floor 1			56.8600	0.1900	10.8034	75.0000	4264.5000 (28a)
Brick Cavity	149.5100	22.1400	127.3700	0.2500	31.8425	60.0000	7642.2000 (29a)
Main Plane	55.8100		55.8100	0.1100	6.1391	9.0000	502.2900 (30)
Bay Roof	1.5000		1.5000	0.1100	0.1650	9.0000	13.5000 (30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)				(26)...(30) + (32) =	77.4456		(33)
Internal Wall 1			73.8800			75.0000	5541.0000 (32c)
Internal Wall 2			199.2400			9.0000	1793.1600 (32c)
Internal Floor 1			55.8100			18.0000	1004.5800 (32d)
Internal Ceiling 1			55.8100			9.0000	502.2900 (32e)
Heat capacity Cm = Sum(A x k)						(28)...(30) + (32) + (32a)...(32e) =	21263.5200 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							188.7239 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							10.3899 (36)
Total fabric heat loss						(33) + (36) =	87.8355 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m	53.5816	53.2582	52.9412	51.4523	51.1737	49.8769	49.8769	49.6368	50.3764	51.1737	51.7373	52.3265 (38)
Heat transfer coeff	141.4171	141.0937	140.7767	139.2878	139.0092	137.7124	137.7124	137.4723	138.2119	139.0092	139.5728	140.1619 (39)
Average = Sum(39)m / 12 =												139.2865 (39)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP	1.2551	1.2523	1.2495	1.2362	1.2338	1.2223	1.2223	1.2201	1.2267	1.2338	1.2388	1.2440 (40)
HLP (average)												1.2362 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy	2.8299 (42)
Average daily hot water use (litres/day)	101.4110 (43)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)

Regs Region: England

Elmhurst Energy Systems

SAP2012 Calculator (Design

System) version 4.14r16

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF FABRIC ENERGY EFFICIENCY 09 Jan 2014

Energy content (annual)	Total = Sum(45)m = 1595.5903 (45)											
Distribution loss (46)m = 0.15 x (45)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (46)
Water storage loss:												
Total storage loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)
Primary loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (59)
Heat gains from water heating, kWh/month	35.1536	30.7455	31.7266	27.6601	26.5405	22.9024	21.2225	24.3531	24.6439	28.7201	31.3503	34.0444 (65)

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(66)
(66)m	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	25.6620	22.7928	18.5363	14.0332	10.4900	8.8561	9.5693	12.4386	16.6950	21.1981	24.7414	26.3753	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	275.3376	278.1948	270.9948	255.6671	236.3186	218.1337	205.9850	203.1279	210.3278	225.6556	245.0041	263.1890	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	(69)
Pumps, fans	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	47.2494	45.7523	42.6433	38.4167	35.6727	31.8089	28.5248	32.7326	34.2277	38.6023	43.5420	45.7585	(72)
Total internal gains	413.6981	412.1889	397.6236	373.5661	347.9303	324.2477	309.5282	313.7482	326.6996	350.9051	378.7366	400.7719	(73)

6. Solar gains

[Jan]					Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Access factor Table 6d		Gains W	
Northeast					8.3200	11.2829	0.4400	0.0000	0.7700		31.8045 (75)	
Southeast					0.8400	36.7938	0.4400	0.0000	0.7700		10.4712 (77)	
Southwest					7.2400	36.7938	0.4400	0.0000	0.7700		90.2520 (79)	
Northwest					1.4400	11.2829	0.4400	0.0000	0.7700		5.5046 (81)	
Solar gains	138.0324	247.5129	371.5749	515.5732	627.8450	645.4565	613.0704	525.9240	420.9081	282.4297	167.5878	116.6667 (83)
Total gains	551.7306	659.7018	769.1985	889.1393	975.7753	969.7043	922.5987	839.6721	747.6077	633.3348	546.3244	517.4385 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)													21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
tau	41.7667	41.8625	41.9567	42.4052	42.4902	42.8903	42.8903	42.9653	42.7353	42.4902	42.3187	42.1408	
alpha	3.7844	3.7908	3.7971	3.8270	3.8327	3.8594	3.8594	3.8644	3.8490	3.8327	3.8212	3.8094	
util living area	0.9969	0.9934	0.9845	0.9572	0.8878	0.7547	0.6056	0.6700	0.8778	0.9758	0.9943	0.9976	(86)
MIT	19.1704	19.3667	19.7017	20.1539	20.5672	20.8479	20.9520	20.9290	20.6978	20.1602	19.5842	19.1387	(87)
Th 2	19.8761	19.8784	19.8806	19.8911	19.8931	19.9022	19.9022	19.9039	19.8987	19.8931	19.8891	19.8850	(88)
util rest of house	0.9960	0.9916	0.9800	0.9435	0.8495	0.6698	0.4761	0.5431	0.8204	0.9657	0.9925	0.9969	(89)
MIT 2	18.2066	18.4039	18.7382	19.1893	19.5785	19.8202	19.8864	19.8778	19.7075	19.2029	18.6295	18.1815	(90)
Living area fraction	18.3298	18.5269	18.8613	19.3126	19.7049	19.9515	20.0226	20.0121	19.8341	19.3252	18.7515	18.3039	(92)
Temperature adjustment	18.3298	18.5269	18.8613	19.3126	19.7049	19.9515	20.0226	20.0121	19.8341	19.3252	18.7515	18.3039	(93)
adjusted MIT	18.3298	18.5269	18.8613	19.3126	19.7049	19.9515	20.0226	20.0121	19.8341	19.3252	18.7515	18.3039	(93)

8. Space heating requirement

Utilisation	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Useful gains	548.5852	652.1445	749.4698	830.7464	821.2929	653.6950	453.3902	467.6713	610.2439	607.1177	540.6792	515.1197	(94)
Ext temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	(96)
Heat loss rate W	1984.0503	1922.6745	1740.1846	1450.3477	1112.7546	736.9703	471.3368	496.5667	792.5213	1212.8895	1626.2295	1976.8252	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	1.0000	(97a)
Space heating kWh	1067.9860	853.7961	737.0918	446.1130	216.8475	0.0000	0.0000	0.0000	0.0000	450.6942	781.5961	1087.5089	(98)
Space heating												5641.6337	(98)
Space heating per m2												50.0722	(99)

8c. Space cooling requirement

Calculated for June, July and August. See Table 10b	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Ext. temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	
Heat loss rate W													

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)




CALCULATION OF FABRIC ENERGY EFFICIENCY 09 Jan 2014

Utilisation	0.0000	0.0000	0.0000	0.0000	0.0000	1294.4968	1019.0719	1044.7893	0.0000	0.0000	0.0000	0.0000 (100)
Useful loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.7786	0.8502	0.8120	0.0000	0.0000	0.0000	0.0000 (101)
Total gains	0.0000	0.0000	0.0000	0.0000	0.0000	1007.8546	866.4525	848.3576	0.0000	0.0000	0.0000	0.0000 (102)
Month fracti	0.0000	0.0000	0.0000	0.0000	0.0000	1245.3598	1187.8726	1093.1296	0.0000	0.0000	0.0000	0.0000 (103)
Space cooling kWh	0.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000 (103a)
Space cooling	0.0000	0.0000	0.0000	0.0000	0.0000	171.0037	239.1366	182.1104	0.0000	0.0000	0.0000	0.0000 (104)
Cooled fraction									FC = cooled area / (4) =			592.2507 (104)
Intermittency factor (Table 10b)												1.0000 (105)
Space cooling kWh	0.0000	0.0000	0.0000	0.0000	0.0000	0.2500	0.2500	0.2500	0.0000	0.0000	0.0000	0.0000 (106)
Space cooling	0.0000	0.0000	0.0000	0.0000	0.0000	42.7509	59.7841	45.5276	0.0000	0.0000	0.0000	0.0000 (107)
Space cooling per m2												148.0627 (107)
Energy for space heating												1.3141 (108)
Energy for space cooling												50.0722 (99)
Total												1.3141 (108)
Dwelling Fabric Energy Efficiency (DFEE)												51.3863 (109)
												51.4 (109)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF TARGET FABRIC ENERGY EFFICIENCY 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF TARGET FABRIC ENERGY EFFICIENCY 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m3 per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor				(20) = 1 - [0.075 x (19)] =	0.8500 (20)
Infiltration rate adjusted to include shelter factor				(21) = (18) x (20) =	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000 (22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750 (22a)
Adj infilt rate	0.4290	0.4206	0.4122	0.3701	0.3617	0.3196	0.3196	0.3112	0.3365	0.3617	0.3785	0.3954 (22b)
Effective ac	0.5920	0.5884	0.5849	0.5685	0.5654	0.5511	0.5511	0.5484	0.5566	0.5654	0.5716	0.5782 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
TER Opaque door			2.1500	1.0000	2.1500		(26)
TER Semi-glazed door			2.1500	1.2000	2.5800		(26a)
TER Opening Type (Uw = 1.40)			17.8400	1.3258	23.6515		(27)
Heat Loss Floor 1			56.8600	0.1300	7.3918		(28a)
Brick Cavity	149.5100	22.1400	127.3700	0.1800	22.9266		(29a)
Main Plane	55.8100		55.8100	0.1300	7.2553		(30)
Bay Roof	1.5000		1.5000	0.1300	0.1950		(30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)			(26)...(30) + (32) =		66.1502		(33)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							250.0000 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							12.6831 (36)
Total fabric heat loss						(33) + (36) =	78.8333 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)												
(38)m	53.5816	53.2582	52.9412	51.4523	51.1737	49.8769	49.8769	49.6368	50.3764	51.1737	51.7373	52.3265 (38)
Heat transfer coeff	132.4150	132.0916	131.7746	130.2856	130.0071	128.7103	128.7103	128.4701	129.2098	130.0071	130.5706	131.1598 (39)
Average = Sum(39)m / 12 =												130.2843 (39)
HLP	1.1752	1.1724	1.1696	1.1563	1.1539	1.1424	1.1424	1.1402	1.1468	1.1539	1.1589	1.1641 (40)
HLP (average)												1.1563 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)
Energy content (annual)										Total = Sum(45)m =		1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (46)
Water storage loss:												
Total storage loss												

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)

CALCULATION OF TARGET FABRIC ENERGY EFFICIENCY 09 Jan 2014

	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)
Primary loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (59)
Heat gains from water heating, kWh/month	35.1536	30.7455	31.7266	27.6601	26.5405	22.9024	21.2225	24.3531	24.6439	28.7201	31.3503	34.0444 (65)

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	141.4969	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	25.6620	22.7928	18.5363	14.0332	10.4900	8.8561	9.5693	12.4386	16.6950	21.1981	24.7414	26.3753	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	275.3376	278.1948	270.9948	255.6671	236.3186	218.1337	205.9850	203.1279	210.3278	225.6556	245.0041	263.1890	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	37.1497	(69)
Pumps, fans	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	47.2494	45.7523	42.6433	38.4167	35.6727	31.8089	28.5248	32.7326	34.2277	38.6023	43.5420	45.7585	(72)
Total internal gains	413.6981	412.1889	397.6236	373.5661	347.9303	324.2477	309.5282	313.7482	326.6996	350.9051	378.7366	400.7719	(73)

6. Solar gains

[Jan]	Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Access factor Table 6d	Gains W
Northeast	8.3200	11.2829	0.6300	0.7000	0.7700	28.6891 (75)
Southeast	0.8400	36.7938	0.6300	0.7000	0.7700	9.4455 (77)
Southwest	7.2400	36.7938	0.6300	0.7000	0.7700	81.4114 (79)
Northwest	1.4400	11.2829	0.6300	0.7000	0.7700	4.9654 (81)

Solar gains	124.5115	223.2679	335.1774	465.0704	566.3448	582.2311	553.0174	474.4073	379.6783	254.7645	151.1719	105.2386	(83)
Total gains	538.2097	635.4568	732.8010	838.6365	914.2751	906.4789	862.5456	788.1555	706.3778	605.6695	529.9084	506.0105	(84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)													21.0000 (85)
Utilisation factor for gains for living area, nil, m (see Table 9a)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
tau	59.0893	59.2340	59.3765	60.0550	60.1837	60.7901	60.7901	60.9037	60.5551	60.1837	59.9239	59.6548	
alpha	4.9393	4.9489	4.9584	5.0037	5.0122	5.0527	5.0527	5.0602	5.0370	5.0122	4.9949	4.9770	
util living area	0.9993	0.9982	0.9947	0.9796	0.9262	0.7924	0.6274	0.6969	0.9148	0.9901	0.9985	0.9995	(86)
MIT	19.6114	19.7611	20.0184	20.3715	20.6982	20.9120	20.9790	20.9652	20.7954	20.3733	19.9299	19.5885	(87)
Th 2	19.9399	19.9422	19.9444	19.9551	19.9571	19.9664	19.9664	19.9681	19.9628	19.9571	19.9530	19.9488	(88)
util rest of house	0.9990	0.9976	0.9926	0.9710	0.8929	0.7051	0.4945	0.5653	0.8621	0.9845	0.9978	0.9993	(89)
MIT 2	18.6677	18.8189	19.0771	19.4339	19.7429	19.9233	19.9607	19.9574	19.8389	19.4405	18.9964	18.6519	(90)
Living area fraction									fLA = Living area / (4) =			0.1278	(91)
MIT	18.7883	18.9393	19.1974	19.5537	19.8650	20.0497	20.0909	20.0862	19.9611	19.5597	19.1158	18.7716	(92)
Temperature adjustment												0.0000	
adjusted MIT	18.7883	18.9393	19.1974	19.5537	19.8650	20.0497	20.0909	20.0862	19.9611	19.5597	19.1158	18.7716	(93)

8. Space heating requirement

Utilisation	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
	0.9986	0.9967	0.9906	0.9666	0.8892	0.7130	0.5115	0.5818	0.8620	0.9815	0.9971	0.9990	(94)
Useful gains	537.4824	633.3689	725.8821	810.5980	813.0124	646.3363	441.1777	458.5234	608.8898	594.4879	528.3550	505.5113	(95)
Ext temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	(96)
Heat loss rate W	1918.4653	1854.4792	1673.1918	1388.0233	1061.5036	701.4308	449.3124	473.5656	757.3158	1164.8247	1568.9044	1911.2034	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(97a)
Space heating kWh	1027.4513	820.5861	704.7984	415.7462	184.8774	0.0000	0.0000	0.0000	0.0000	424.3305	749.1955	1045.8349	(98)
Space heating												5372.8204	(98)
Space heating per m ²										(98) / (4) =		47.6863	(99)

8c. Space cooling requirement

Calculated for June, July and August. See Table 10b	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Ext. temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	
Heat loss rate W	0.0000	0.0000	0.0000	0.0000	0.0000	1209.8764	952.4559	976.3728	0.0000	0.0000	0.0000	0.0000	(100)
Utilisation	0.0000	0.0000	0.0000	0.0000	0.0000	0.8210	0.8938	0.8576	0.0000	0.0000	0.0000	0.0000	(101)
Useful loss	0.0000	0.0000	0.0000	0.0000	0.0000	993.3426	851.2943	837.3073	0.0000	0.0000	0.0000	0.0000	(102)
Total gains	0.0000	0.0000	0.0000	0.0000	0.0000	1171.4600	1117.6807	1032.9154	0.0000	0.0000	0.0000	0.0000	(103)
Month fracti	0.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	(103a)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF TARGET FABRIC ENERGY EFFICIENCY 09 Jan 2014

Space cooling kWh	0.0000	0.0000	0.0000	0.0000	0.0000	128.2445	198.1915	145.5324	0.0000	0.0000	0.0000	0.0000 (104)
Space cooling												471.9684 (104)
Cooled fraction									fC = cooled area / (4) =			1.0000 (105)
Intermittency factor (Table 10b)	0.0000	0.0000	0.0000	0.0000	0.0000	0.2500	0.2500	0.2500	0.0000	0.0000	0.0000	0.0000 (106)
Space cooling kWh	0.0000	0.0000	0.0000	0.0000	0.0000	32.0611	49.5479	36.3831	0.0000	0.0000	0.0000	0.0000 (107)
Space cooling												117.9921 (107)
Space cooling per m2												1.0472 (108)
Energy for space heating												47.6863 (99)
Energy for space cooling												1.0472 (108)
Total												48.7336 (109)
Target Fabric Energy Efficiency (TFEE)												56.0 (109)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF HEAT DEMAND 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF HEAT DEMAND 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m3 per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Air changes per hour					
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c)					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor			(20) = 1 - [0.075 x (19)]	=	0.8500 (20)
Infiltration rate adjusted to include shelter factor			(21) = (18) x (20)	=	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	4.2000	4.0000	4.0000	3.7000	3.7000	3.3000	3.4000	3.2000	3.3000	3.5000	3.5000	3.8000 (22)
Wind factor	1.0500	1.0000	1.0000	0.9250	0.9250	0.8250	0.8500	0.8000	0.8250	0.8750	0.8750	0.9500 (22a)
Adj infilt rate	0.3533	0.3365	0.3365	0.3112	0.3112	0.2776	0.2860	0.2692	0.2776	0.2944	0.2944	0.3196 (22b)
Effective ac	0.5624	0.5566	0.5566	0.5484	0.5484	0.5385	0.5409	0.5362	0.5385	0.5433	0.5433	0.5511 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Opening Type 1			2.1500	1.4000	3.0100		(26)
Opening Type 2 (Uw = 1.30)			17.8400	1.2357	22.0456		(27)
Opening Type 3			2.1500	1.6000	3.4400		(26a)
Heat Loss Floor 1			56.8600	0.1900	10.8034	75.0000	4264.5000 (28a)
Brick Cavity	149.5100	22.1400	127.3700	0.2500	31.8425	60.0000	7642.2000 (29a)
Main Plane	55.8100		55.8100	0.1100	6.1391	9.0000	502.2900 (30)
Bay Roof	1.5000		1.5000	0.1100	0.1650	9.0000	13.5000 (30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)				(26)...(30) + (32) =	77.4456		(33)
Internal Wall 1			73.8800			75.0000	5541.0000 (32c)
Internal Wall 2			199.2400			9.0000	1793.1600 (32c)
Internal Floor 1			55.8100			18.0000	1004.5800 (32d)
Internal Ceiling 1			55.8100			18.0000	1004.5800 (32e)
Heat capacity Cm = Sum(A x k)						(28)...(30) + (32) + (32a)...(32e) =	21765.8100 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							193.1819 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							10.3899 (36)
Total fabric heat loss						(33) + (36) =	87.8355 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m	50.9016	50.3764	50.3764	49.6368	49.6368	48.7402	48.9548	48.5321	48.7402	49.1757	49.1757	49.8769 (38)
Heat transfer coeff	138.7371	138.2119	138.2119	137.4723	137.4723	136.5757	136.7903	136.3676	136.5757	137.0112	137.0112	137.7124 (39)
Average = Sum(39)m / 12 =												137.3458 (39)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP	1.2314	1.2267	1.2267	1.2201	1.2201	1.2122	1.2141	1.2103	1.2122	1.2160	1.2160	1.2223 (40)
HLP (average)												1.2190 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)

Regs Region: England

Elmhurst Energy Systems

SAP2012 Calculator (Design

System) version 4.14r16

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF HEAT DEMAND 09 Jan 2014

Energy content (annual)												Total = Sum(45)m =	1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m													
	24.8143	21.7027	22.3953	19.5247	18.7345	16.1664	14.9806	17.1904	17.3957	20.2730	22.1296	24.0313	(46)
Water storage loss:													
Total storage loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(56)
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(57)
Combi loss	14.1536	12.7725	14.1149	13.6233	14.0423	13.5489	13.9753	14.0188	13.5894	14.0809	13.6669	14.1411	(61)
Total heat required for water heating calculated for each month	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498	(62)
Solar input	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(63)
Solar input (sum of months) = Sum(63)m =												0.0000	(63)
Output from w/h	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498	(64)
RHI water heating demand													
Heat gains from water heating, kWh/month	58.5434	51.3009	53.1716	46.6857	45.0386	39.2228	36.7007	41.6101	41.9579	48.4588	52.4707	56.8047	(65)

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	64.1551	56.9820	46.3409	35.0830	26.2250	22.1402	23.9233	31.0964	41.7375	52.9954	61.8534	65.9382	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	410.9517	415.2160	404.4699	381.5927	352.7143	325.5726	307.4404	303.1760	313.9221	336.7993	365.6777	392.8194	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	78.6874	76.3406	71.4672	64.8412	60.5358	54.4761	49.3289	55.9275	58.2748	65.1328	72.8759	76.3504	(72)
Total internal gains	668.2024	662.9469	636.6863	595.9252	553.8833	516.5973	495.1009	504.6082	528.3427	569.3358	614.8154	649.5162	(73)

6. Solar gains

[Jan]				Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b		FF Specific data or Table 6c		Access factor Table 6d		Gains W
Northeast				8.3200	12.9236	0.4400		0.0000		0.7700		36.4291 (75)
Southeast				0.8400	40.4699	0.4400		0.0000		0.7700		11.5174 (77)
Southwest				7.2400	40.4699	0.4400		0.0000		0.7700		99.2691 (79)
Northwest				1.4400	12.9236	0.4400		0.0000		0.7700		6.3050 (81)

Solar gains	153.5207	248.4493	370.3669	532.4620	633.4976	697.4744	655.1384	573.6553	455.8138	303.2521	191.1020	128.4161 (83)
Total gains	821.7232	911.3963	1007.0532	1128.3872	1187.3809	1214.0716	1150.2393	1078.2635	984.1565	872.5879	805.9174	777.9323 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)												21.0000	(85)
Utilisation factor for gains for living area, nil,m (see Table 9a)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
tau	43.5793	43.7448	43.7448	43.9802	43.9802	44.2689	44.1995	44.3365	44.2689	44.1282	44.1282	43.9035	
alpha	3.9053	3.9163	3.9163	3.9320	3.9320	3.9513	3.9466	3.9558	3.9513	3.9419	3.9419	3.9269	
util living area	0.9866	0.9790	0.9577	0.8973	0.7656	0.5356	0.3641	0.3979	0.7037	0.9186	0.9755	0.9889	(86)
MIT	19.6075	19.7649	20.0856	20.4863	20.8092	20.9673	20.9947	20.9926	20.9002	20.5130	20.0036	19.5795	(87)
Th 2	19.8950	19.8987	19.8987	19.9039	19.9039	19.9103	19.9088	19.9117	19.9103	19.9072	19.9072	19.9022	(88)
util rest of house	0.9830	0.9734	0.9458	0.8677	0.6999	0.4301	0.2382	0.2660	0.6056	0.8880	0.9676	0.9858	(89)
MIT 2	18.0752	18.3050	18.7646	19.3233	19.7309	19.8929	19.9077	19.9101	19.8409	19.3743	18.6581	18.0397	(90)
Living area fraction	18.2711	18.4916	18.9334	19.4720	19.8687	20.0302	20.0466	20.0484	19.9762	19.5198	18.6301	18.2365	(91)
MIT	18.2711	18.4916	18.9334	19.4720	19.8687	20.0302	20.0466	20.0484	19.9762	19.5198	18.6301	18.2365	(92)
Temperature adjustment	18.1211	18.3416	18.7834	19.3220	19.7187	19.8802	19.8966	19.8984	19.8262	19.3698	18.6801	-0.1500	
adjusted MIT	18.1211	18.3416	18.7834	19.3220	19.7187	19.8802	19.8966	19.8984	19.8262	19.3698	18.6801	18.0865	(93)

8. Space heating requirement

Utilisation	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Useful gains	800.6181	876.7030	935.9708	957.1194	816.0610	518.4616	272.4011	285.0509	587.6426	757.7492	769.5199	760.9272	(94)
Ext temp.	5.1000	5.6000	7.4000	9.9000	13.0000	16.0000	17.9000	17.8000	15.2000	11.6000	8.0000	5.1000	(96)
Heat loss rate W	1806.5037	1761.0403	1573.3284	1295.2597	923.6403	529.9383	273.1165	286.1582	631.8333	1064.5549	1463.2896	1788.4048	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(98a)
Space heating kWh	748.3788	594.2746	474.1941	243.4610	80.0390	0.0000	0.0000	0.0000	0.0000	228.2634	499.5142	764.4434	(98)
Space heating												3632.5685	(98)
RHI space heating demand												3633	(98)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF HEAT DEMAND 09 Jan 2014

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF ENERGY RATINGS 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF ENERGY RATINGS 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m3 per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c)					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor				(20) = 1 - [0.075 x (19)] =	0.8500 (20)
Infiltration rate adjusted to include shelter factor				(21) = (18) x (20) =	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000 (22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750 (22a)
Adj infilt rate	0.4290	0.4206	0.4122	0.3701	0.3617	0.3196	0.3196	0.3112	0.3365	0.3617	0.3785	0.3954 (22b)
Effective ac	0.5920	0.5884	0.5849	0.5685	0.5654	0.5511	0.5511	0.5484	0.5566	0.5654	0.5716	0.5782 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Opening Type 1			2.1500	1.4000	3.0100		(26)
Opening Type 2 (Uw = 1.30)			17.8400	1.2357	22.0456		(27)
Opening Type 3			2.1500	1.6000	3.4400		(26a)
Heat Loss Floor 1			56.8600	0.1900	10.8034	75.0000	4264.5000 (28a)
Brick Cavity	149.5100	22.1400	127.3700	0.2500	31.8425	60.0000	7642.2000 (29a)
Main Plane	55.8100		55.8100	0.1100	6.1391	9.0000	502.2900 (30)
Bay Roof	1.5000		1.5000	0.1100	0.1650	9.0000	13.5000 (30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)				(26)...(30) + (32) =	77.4456		(33)
Internal Wall 1			73.8800			75.0000	5541.0000 (32c)
Internal Wall 2			199.2400			9.0000	1793.1600 (32c)
Internal Floor 1			55.8100			18.0000	1004.5800 (32d)
Internal Ceiling 1			55.8100			18.0000	1004.5800 (32e)
Heat capacity Cm = Sum(A x k)						(28)...(30) + (32) + (32a)...(32e) =	21765.8100 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							193.1819 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							10.3899 (36)
Total fabric heat loss						(33) + (36) =	87.8355 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m	53.5816	53.2582	52.9412	51.4523	51.1737	49.8769	49.8769	49.6368	50.3764	51.1737	51.7373	52.3265 (38)
Heat transfer coeff	141.4171	141.0937	140.7767	139.2878	139.0092	137.7124	137.7124	137.4723	138.2119	139.0092	139.5728	140.1619 (39)
Average = Sum(39)m / 12 =												139.2865 (39)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP	1.2551	1.2523	1.2495	1.2362	1.2338	1.2223	1.2223	1.2201	1.2267	1.2338	1.2388	1.2440 (40)
HLP (average)												1.2362 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)


Regs Region: England

Elmhurst Energy Systems

SAP2012 Calculator (Design
System) version 4.14r16

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF ENERGY RATINGS 09 Jan 2014

Energy content (annual)												Total = Sum(45)m =	1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m													
	24.8143	21.7027	22.3953	19.5247	18.7345	16.1664	14.9806	17.1904	17.3957	20.2730	22.1296	24.0313	(46)
Water storage loss:													
Total storage loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(56)
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(57)
Combi loss	14.1536	12.7725	14.1149	13.6233	14.0423	13.5489	13.9753	14.0188	13.5894	14.0809	13.6669	14.1411	(61)
Total heat required for water heating calculated for each month	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498	(62)
Solar input	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(63)
Solar input (sum of months) = Sum(63)m =												0.0000	(63)
Output from w/h	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498	(64)
Heat gains from water heating, kWh/month	58.5434	51.3009	53.1716	46.6857	45.0386	39.2228	36.7007	41.6101	41.9579	48.4588	52.4707	56.8047	(65)
Total per year (kWh/year) = Sum(64)m =												1761.3181	(64)

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	64.1551	56.9820	46.3409	35.0830	26.2250	22.1402	23.9233	31.0964	41.7375	52.9954	61.8534	65.9382	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	410.9517	415.2160	404.4699	381.5927	352.7143	325.5726	307.4404	303.1760	313.9221	336.7993	365.6777	392.8194	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	78.6874	76.3406	71.4672	64.8412	60.5358	54.4761	49.3289	55.9275	58.2748	65.1328	72.8759	76.3504	(72)
Total internal gains	668.2024	662.9469	636.6863	595.9252	553.8833	516.5973	495.1009	504.6082	528.3427	569.3358	614.8154	649.5162	(73)

6. Solar gains

[Jan]					Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Access factor Table 6d		Gains W	
Northeast					8.3200	11.2829	0.4400	0.0000	0.7700		31.8045 (75)	
Southeast					0.8400	36.7938	0.4400	0.0000	0.7700		10.4712 (77)	
Southwest					7.2400	36.7938	0.4400	0.0000	0.7700		90.2520 (79)	
Northwest					1.4400	11.2829	0.4400	0.0000	0.7700		5.5046 (81)	
Solar gains	138.0324	247.5129	371.5749	515.5732	627.8450	645.4565	613.0704	525.9240	420.9081	282.4297	167.5878	116.6667 (83)
Total gains	806.2349	910.4598	1008.2612	1111.4984	1181.7284	1162.0538	1108.1713	1030.5322	949.2509	851.7655	782.4032	766.1829 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)												21.0000	(85)
Utilisation factor for gains for living area, nil,m (see Table 9a)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
tau	42.7534	42.8514	42.9479	43.4069	43.4939	43.9035	43.9035	43.9802	43.7448	43.4939	43.3183	43.1362	
alpha	3.8502	3.8568	3.8632	3.8938	3.8996	3.9269	3.9269	3.9320	3.9163	3.8996	3.8879	3.8757	
util living area	0.9894	0.9822	0.9657	0.9226	0.8300	0.6753	0.5224	0.5755	0.7984	0.9436	0.9823	0.9913	(86)
MIT	19.4471	19.6315	19.9387	20.3420	20.6888	20.9034	20.9730	20.9606	20.8044	20.3596	19.8326	19.4122	(87)
Th 2	19.8761	19.8784	19.8806	19.8911	19.8931	19.9022	19.9022	19.9039	19.8987	19.8931	19.8891	19.8850	(88)
util rest of house	0.9867	0.9775	0.9564	0.9005	0.7810	0.5864	0.4030	0.4546	0.7244	0.9228	0.9768	0.9890	(89)
MIT 2	17.8296	18.0981	18.5419	19.1171	19.5774	19.8309	19.8902	19.8846	19.7321	19.1541	18.3994	17.7847	(90)
Living area fraction	fLA = Living area / (4) =											0.1278	(91)
MIT	18.0363	18.2941	18.7204	19.2736	19.7195	19.9680	20.0286	20.0221	19.8691	19.3082	18.5826	17.9927	(92)
Temperature adjustment												-0.1500	
adjusted MIT	17.8863	18.1441	18.5704	19.1236	19.5695	19.8180	19.8786	19.8721	19.7191	19.1582	18.4326	17.8427	(93)

8. Space heating requirement

Utilisation	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
	0.9792	0.9670	0.9412	0.8810	0.7641	0.5789	0.4002	0.4508	0.7101	0.9042	0.9662	0.9825	(94)
Useful gains	789.4633	880.3809	948.9941	979.1924	902.9547	672.7567	443.5330	464.6058	674.0339	770.1450	755.9399	752.7675	(95)
Ext temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	(96)
Heat loss rate W	1921.3386	1868.6617	1699.2304	1424.0282	1093.9309	718.5785	451.5010	477.3178	776.6327	1189.6641	1581.7176	1912.1869	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(97a)
Space heating kWh	842.1152	664.1247	558.1759	320.2818	142.0863	0.0000	0.0000	0.0000	0.0000	312.1222	594.5599	862.6080	(98)
Space heating												4296.0740	(98)
Space heating per m2												(98) / (4) =	38.1297 (99)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF ENERGY RATINGS 09 Jan 2014

8c. Space cooling requirement

Not applicable

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 11)													0.0000 (201)
Fraction of space heat from main system(s)													1.0000 (202)
Efficiency of main space heating system 1 (in %)													90.5000 (206)
Efficiency of secondary/supplementary heating system, %													0.0000 (208)
Space heating requirement													4747.0431 (211)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Space heating requirement	842.1152	664.1247	558.1759	320.2818	142.0863	0.0000	0.0000	0.0000	0.0000	312.1222	594.5599	862.6080	(98)
Space heating efficiency (main heating system 1)	90.5000	90.5000	90.5000	90.5000	90.5000	0.0000	0.0000	0.0000	0.0000	90.5000	90.5000	90.5000	(210)
Space heating fuel (main heating system)	930.5141	733.8394	616.7689	353.9025	157.0014	0.0000	0.0000	0.0000	0.0000	344.8864	656.9723	953.1581	(211)
Water heating requirement	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(215)
Water heating													
Water heating requirement	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498	(64)
Efficiency of water heater	89.9207	89.8687	89.7549	89.4837	88.8891	87.3000	87.3000	87.3000	87.3000	89.4395	89.7979	87.3000	(216)
(217)m	89.9207	89.8687	89.7549	89.4837	88.8891	87.3000	87.3000	87.3000	87.3000	89.4395	89.7979	89.9457	(217)
Fuel for water heating, kWh/month	199.7118	175.2084	182.0699	160.6865	156.3056	138.9748	130.4075	147.3327	148.4088	166.8552	179.5114	193.8390	(219)
Water heating fuel used												1979.3116	(219)
Annual totals kWh/year													
Space heating fuel - main system												4747.0431	(211)
Space heating fuel - secondary												0.0000	(215)
Electricity for pumps and fans:													
central heating pump												30.0000	(230c)
main heating flue fan												45.0000	(230e)
Total electricity for the above, kWh/year												75.0000	(231)
Electricity for lighting (calculated in Appendix L)												453.1995	(232)
Total delivered energy for all uses												7254.5543	(238)

10a. Fuel costs - using Table 12 prices

	Fuel	Fuel price	Fuel cost	
	kWh/year	p/kWh	£/year	
Space heating - main system 1	4747.0431	3.4800	165.1971	(240)
Space heating - secondary	0.0000	0.0000	0.0000	(242)
Water heating (other fuel)	1979.3116	3.4800	68.8800	(247)
Pumps and fans for heating	75.0000	13.1900	9.8925	(249)
Energy for lighting	453.1995	13.1900	59.7770	(250)
Additional standing charges			120.0000	(251)
Total energy cost			423.7467	(255)

11a. SAP rating - Individual heating systems

Energy cost deflator (Table 12):	0.4200	(256)
Energy cost factor (ECF)	1.1288	(257)
SAP value	84.2536	
SAP rating (Section 12)	84	(258)
SAP band	B	

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

	Energy	Emission factor	Emissions	
	kWh/year	kg CO2/kWh	kg CO2/year	
Space heating - main system 1	4747.0431	0.2160	1025.3613	(261)
Space heating - secondary	0.0000	0.0000	0.0000	(263)
Water heating (other fuel)	1979.3116	0.2160	427.5313	(264)
Space and water heating			1452.8926	(265)
Pumps and fans	75.0000	0.5190	38.9250	(267)
Energy for lighting	453.1995	0.5190	235.2106	(268)
Total kg/year			1727.0282	(272)
CO2 emissions per m2			15.3300	(273)
EI value			85.3224	
EI rating			85	(274)
EI band			B	

Calculation of stars for heating and DHW

Main heating energy efficiency	$3.48 \times (1 + 0.29 \times 0.00) / 0.9050 = 3.845$, stars = 4
Main heating environmental impact	$0.216 \times (1 + 0.29 \times 0.00) / 0.9050 = 0.2387$, stars = 4
Water heating energy efficiency	$3.48 / 0.8886 = 3.916$, stars = 4
Water heating environmental impact	$0.216 / 0.8886 = 0.2431$, stars = 4

Regs Region: England

Elmhurst Energy Systems

SAP2012 Calculator (Design

System) version 4.14r16

FULL SAP CALCULATION PRINTOUT


Calculation Type: New Build (As Designed)



CALCULATION OF ENERGY RATINGS 09 Jan 2014

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m ³ per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c)					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor			(20) = 1 - [0.075 x (19)]	=	0.8500 (20)
Infiltration rate adjusted to include shelter factor			(21) = (18) x (20)	=	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	4.2000	4.0000	4.0000	3.7000	3.7000	3.3000	3.4000	3.2000	3.3000	3.5000	3.5000	3.8000 (22)
Wind factor	1.0500	1.0000	1.0000	0.9250	0.9250	0.8250	0.8500	0.8000	0.8250	0.8750	0.8750	0.9500 (22a)
Adj infilt rate	0.3533	0.3365	0.3365	0.3112	0.3112	0.2776	0.2860	0.2692	0.2776	0.2944	0.2944	0.3196 (22b)
Effective ac	0.5624	0.5566	0.5566	0.5484	0.5484	0.5385	0.5409	0.5362	0.5385	0.5433	0.5433	0.5511 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Opening Type 1			2.1500	1.4000	3.0100		(26)
Opening Type 2 (Uw = 1.30)			17.8400	1.2357	22.0456		(27)
Opening Type 3			2.1500	1.6000	3.4400		(26a)
Heat Loss Floor 1			56.8600	0.1900	10.8034	75.0000	4264.5000 (28a)
Brick Cavity	149.5100	22.1400	127.3700	0.2500	31.8425	60.0000	7642.2000 (29a)
Main Plane	55.8100		55.8100	0.1100	6.1391	9.0000	502.2900 (30)
Bay Roof	1.5000		1.5000	0.1100	0.1650	9.0000	13.5000 (30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)				(26)...(30) + (32) =	77.4456		(33)
Internal Wall 1			73.8800			75.0000	5541.0000 (32c)
Internal Wall 2			199.2400			9.0000	1793.1600 (32c)
Internal Floor 1			55.8100			18.0000	1004.5800 (32d)
Internal Ceiling 1			55.8100			18.0000	1004.5800 (32e)
Heat capacity Cm = Sum(A x k)						(28)...(30) + (32) + (32a)...(32e) =	21765.8100 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							193.1819 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							10.3899 (36)
Total fabric heat loss						(33) + (36) =	87.8355 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m	50.9016	50.3764	50.3764	49.6368	49.6368	48.7402	48.9548	48.5321	48.7402	49.1757	49.1757	49.8769 (38)
Heat transfer coeff	138.7371	138.2119	138.2119	137.4723	137.4723	136.5757	136.7903	136.3676	136.5757	137.0112	137.0112	137.7124 (39)
Average = Sum(39)m / 12 =												137.3458 (39)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP	1.2314	1.2267	1.2267	1.2201	1.2201	1.2122	1.2141	1.2103	1.2122	1.2160	1.2160	1.2223 (40)
HLP (average)												1.2190 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)

Regs Region: England

Elmhurst Energy Systems

SAP2012 Calculator (Design

System) version 4.14r16

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)

CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY 09 Jan 2014

Energy content (annual)												Total = Sum(45)m = 1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m												
	24.8143	21.7027	22.3953	19.5247	18.7345	16.1664	14.9806	17.1904	17.3957	20.2730	22.1296	24.0313 (46)
Water storage loss:												
Total storage loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)
Combi loss	14.1536	12.7725	14.1149	13.6233	14.0423	13.5489	13.9753	14.0188	13.5894	14.0809	13.6669	14.1411 (61)
Total heat required for water heating calculated for each month	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (62)
Solar input	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (63)
												Solar input (sum of months) = Sum(63)m = 0.0000 (63)
Output from w/h	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (64)
												Total per year (kWh/year) = Sum(64)m = 1761.3181 (64)
Heat gains from water heating, kWh/month	58.5434	51.3009	53.1716	46.6857	45.0386	39.2228	36.7007	41.6101	41.9579	48.4588	52.4707	56.8047 (65)

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	64.1551	56.9820	46.3409	35.0830	26.2250	22.1402	23.9233	31.0964	41.7375	52.9954	61.8534	65.9382	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	410.9517	415.2160	404.4699	381.5927	352.7143	325.5726	307.4404	303.1760	313.9221	336.7993	365.6777	392.8194	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	78.6874	76.3406	71.4672	64.8412	60.5358	54.4761	49.3289	55.9275	58.2748	65.1328	72.8759	76.3504	(72)
Total internal gains	668.2024	662.9469	636.6863	595.9252	553.8833	516.5973	495.1009	504.6082	528.3427	569.3358	614.8154	649.5162	(73)

6. Solar gains

[Jan]					Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Access factor Table 6d		Gains W	
Northeast					8.3200	12.9236	0.4400	0.0000	0.7700		36.4291 (75)	
Southeast					0.8400	40.4699	0.4400	0.0000	0.7700		11.5174 (77)	
Southwest					7.2400	40.4699	0.4400	0.0000	0.7700		99.2691 (79)	
Northwest					1.4400	12.9236	0.4400	0.0000	0.7700		6.3050 (81)	

Solar gains	153.5207	248.4493	370.3669	532.4620	633.4976	697.4744	655.1384	573.6553	455.8138	303.2521	191.1020	128.4161 (83)
Total gains	821.7232	911.3963	1007.0532	1128.3872	1187.3809	1214.0716	1150.2393	1078.2635	984.1565	872.5879	805.9174	777.9323 (84)

7. Mean internal temperature (heating season)


Temperature during heating periods in the living area from Table 9, Th1 (C)												21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)												
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
tau	43.5793	43.7448	43.7448	43.9802	43.9802	44.2689	44.1995	44.3365	44.2689	44.1282	44.1282	43.9035
alpha	3.9053	3.9163	3.9163	3.9320	3.9320	3.9513	3.9466	3.9558	3.9513	3.9419	3.9419	3.9269
util living area	0.9866	0.9790	0.9577	0.8973	0.7656	0.5356	0.3641	0.3979	0.7037	0.9186	0.9755	0.9889 (86)
MIT	19.6075	19.7649	20.0856	20.4863	20.8092	20.9673	20.9947	20.9926	20.9002	20.5130	20.0036	19.5795 (87)
Th 2	19.8950	19.8987	19.8987	19.9039	19.9039	19.9103	19.9088	19.9117	19.9103	19.9072	19.9072	19.9022 (88)
util rest of house	0.9830	0.9734	0.9458	0.8677	0.6999	0.4301	0.2382	0.2660	0.6056	0.8880	0.9676	0.9858 (89)
MIT 2	18.0752	18.3050	18.7646	19.3233	19.7309	19.8929	19.9077	19.9101	19.8409	19.3743	18.6581	18.0397 (90)
Living area fraction	fLA = Living area / (4) =											0.1278 (91)
MIT	18.2711	18.4916	18.9334	19.4720	19.8687	20.0302	20.0466	20.0484	19.9762	19.5198	18.8301	18.2365 (92)
Temperature adjustment												-0.1500
adjusted MIT	18.1211	18.3416	18.7834	19.3220	19.7187	19.8802	19.8966	19.8984	19.8262	19.3698	18.6801	18.0865 (93)

8. Space heating requirement

Utilisation	0.9743	0.9619	0.9294	0.8482	0.6873	0.4270	0.2368	0.2644	0.5971	0.8684	0.9548	0.9781	(94)
Useful gains	800.6181	876.7030	935.9708	957.1194	816.0610	518.4616	272.4011	285.0509	587.6426	757.7492	769.5199	760.9272	(95)
Ext temp.	5.1000	5.6000	7.4000	9.9000	13.0000	16.0000	17.9000	17.8000	15.2000	11.6000	8.0000	5.1000	(96)
Heat loss rate W	1806.5037	1761.0403	1573.3284	1295.2597	923.6403	529.9383	273.1165	286.1582	631.8333	1064.5549	1463.2896	1788.4048	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(97a)
Space heating kWh	748.3788	594.2746	474.1941	243.4610	80.0390	0.0000	0.0000	0.0000	0.0000	228.2634	499.5142	764.4434	(98)
Space heating												3632.5685	(98)
Space heating per m2												(98) / (4) = 32.2408	(99)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY 09 Jan 2014

8c. Space cooling requirement

Not applicable

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 11)													0.0000 (201)
Fraction of space heat from main system(s)													1.0000 (202)
Efficiency of main space heating system 1 (in %)													90.5000 (206)
Efficiency of secondary/supplementary heating system, %													0.0000 (208)
Space heating requirement													4013.8879 (211)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Space heating requirement	748.3788	594.2746	474.1941	243.4610	80.0390	0.0000	0.0000	0.0000	0.0000	228.2634	499.5142	764.4434	(98)
Space heating efficiency (main heating system 1)	90.5000	90.5000	90.5000	90.5000	90.5000	0.0000	0.0000	0.0000	0.0000	90.5000	90.5000	90.5000	(210)
Space heating fuel (main heating system)	826.9379	656.6571	523.9714	269.0177	88.4409	0.0000	0.0000	0.0000	0.0000	252.2247	551.9494	844.6888	(211)
Water heating requirement	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(215)
Water heating													
Water heating requirement	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498	(64)
Efficiency of water heater (217)m	89.8625	89.8105	89.6577	89.2848	88.4431	87.3000	87.3000	87.3000	87.3000	89.2073	89.6978	87.3000	(216)
Fuel for water heating, kWh/month	199.8410	175.3219	182.2674	161.0445	157.0940	138.9748	130.4075	147.3327	148.4088	167.2895	179.7117	193.9632	(219)
Water heating fuel used												1981.6569	(219)
Annual totals kWh/year													
Space heating fuel - main system												4013.8879	(211)
Space heating fuel - secondary												0.0000	(215)
Electricity for pumps and fans:													
central heating pump												30.0000	(230c)
main heating flue fan												45.0000	(230e)
Total electricity for the above, kWh/year												75.0000	(231)
Electricity for lighting (calculated in Appendix L)												453.1995	(232)
Total delivered energy for all uses												6523.7443	(238)

10a. Fuel costs - using BEDF prices (470)

	Fuel kWh/year	Fuel price p/kWh	Fuel cost £/year
Space heating - main system 1	4013.8879	3.8700	155.3375 (240)
Space heating - secondary	0.0000	0.0000	0.0000 (242)
Water heating (other fuel)	1981.6569	3.8700	76.6901 (247)
Pumps and fans for heating	75.0000	18.9000	14.1750 (249)
Energy for lighting	453.1995	18.9000	85.6547 (250)
Additional standing charges			93.0000 (251)
Total energy cost			424.8573 (255)

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating - main system 1	4013.8879	0.2160	866.9998 (261)
Space heating - secondary	0.0000	0.0000	0.0000 (263)
Water heating (other fuel)	1981.6569	0.2160	428.0379 (264)
Space and water heating			1295.0377 (265)
Pumps and fans	75.0000	0.5190	38.9250 (267)
Energy for lighting	453.1995	0.5190	235.2106 (268)
Total kg/year			1569.1732 (272)

13a. Primary energy - Individual heating systems including micro-CHP

	Energy kWh/year	Primary energy factor kg CO2/kWh	Primary energy kWh/year
Space heating - main system 1	4013.8879	1.2200	4896.9432 (261)
Space heating - secondary	0.0000	0.0000	0.0000 (263)
Water heating (other fuel)	1981.6569	1.2200	2417.6214 (264)
Space and water heating			7314.5646 (265)
Pumps and fans	75.0000	3.0700	230.2500 (267)
Energy for lighting	453.1995	3.0700	1391.3225 (268)
Primary energy kWh/year			8936.1371 (272)
Primary energy kWh/m2/year			79.3125 (273)

SAP 2012 EPC IMPROVEMENTS

Current energy efficiency rating: B 84
Current environmental impact rating: B 85

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)

CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY 09 Jan 2014

(For testing purposes):

A	Not considered
B	Not considered
C	Not considered
D	Not considered
E Low energy lighting	Already installed
F	Not considered
G	Not considered
H	Not considered
I	Not considered
J	Not considered
K	Not considered
M	Not considered
N Solar water heating	Recommended
O	Not considered
P	Not considered
R	Not considered
S	Not considered
T	Not considered
U Solar photovoltaic panels	Recommended
A2	Not considered
A3	Not considered
T2	Not considered
W	Not considered
X	Not considered
Y	Not considered
J2	Not considered
Q2	Not considered
Z1	Not considered
Z2	Not considered
Z3	Not considered
Z4	Not considered
Z5	Not considered
V2 Wind turbine	Not applicable
L2	Not considered
Q3	Not considered
O3	Not considered

Recommended measures:	SAP change	Cost change	CO2 change
N Solar water heating	+ 1.0	-£ 30	-192 kg (12.2%)
U Solar photovoltaic panels	+ 8.5	-£ 345	-947 kg (68.7%)

Recommended measures	Typical annual savings	Energy efficiency	Environmental impact
Solar water heating	£30	1.70 kg/m²	B 85 B 87
Solar photovoltaic panels	£345	8.40 kg/m²	A 94 A 95
Total Savings	£374	10.11 kg/m²	

Potential energy efficiency rating: A 94
 Potential environmental impact rating: A 95

Fuel prices for cost data on this page from database revision number 470 TEST (21 Dec 2020)
 Recommendation texts revision number 4.9c (22 Feb 2014)

Typical heating and lighting costs of this home (per year, Thames Valley):

	Current	Potential	Saving
Electricity	£100	£109	-£9
Mains gas	£325	£286	£39
Space heating	£263	£263	£0
Water heating	£77	£47	£30
Lighting	£86	£86	£0
Generated (PV)	-£0	-£345	£345
Total cost of fuels	£425	£50	£375
Total cost of uses	£426	£51	£375
Delivered energy	58 kWh/m²	33 kWh/m²	25 kWh/m²
Carbon dioxide emissions	1.6 tonnes	0.4 tonnes	1.1 tonnes
CO2 emissions per m²	14 kg/m²	4 kg/m²	10 kg/m²
Primary energy	79 kWh/m²	20 kWh/m²	59 kWh/m²

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF ENERGY RATINGS FOR IMPROVED DWELLING 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
CALCULATION OF ENERGY RATINGS FOR IMPROVED DWELLING 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m ³ per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c)					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor				(20) = 1 - [0.075 x (19)] =	0.8500 (20)
Infiltration rate adjusted to include shelter factor				(21) = (18) x (20) =	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	5.1000	5.0000	4.9000	4.4000	4.3000	3.8000	3.8000	3.7000	4.0000	4.3000	4.5000	4.7000 (22)
Wind factor	1.2750	1.2500	1.2250	1.1000	1.0750	0.9500	0.9500	0.9250	1.0000	1.0750	1.1250	1.1750 (22a)
Adj infilt rate	0.4290	0.4206	0.4122	0.3701	0.3617	0.3196	0.3196	0.3112	0.3365	0.3617	0.3785	0.3954 (22b)
Effective ac	0.5920	0.5884	0.5849	0.5685	0.5654	0.5511	0.5511	0.5484	0.5566	0.5654	0.5716	0.5782 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Opening Type 1			2.1500	1.4000	3.0100		(26)
Opening Type 2 (Uw = 1.30)			17.8400	1.2357	22.0456		(27)
Opening Type 3			2.1500	1.6000	3.4400		(26a)
Heat Loss Floor 1			56.8600	0.1900	10.8034	75.0000	4264.5000 (28a)
Brick Cavity	149.5100	22.1400	127.3700	0.2500	31.8425	60.0000	7642.2000 (29a)
Main Plane	55.8100		55.8100	0.1100	6.1391	9.0000	502.2900 (30)
Bay Roof	1.5000		1.5000	0.1100	0.1650	9.0000	13.5000 (30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)				(26)...(30) + (32) =	77.4456		(33)
Internal Wall 1			73.8800			75.0000	5541.0000 (32c)
Internal Wall 2			199.2400			9.0000	1793.1600 (32c)
Internal Floor 1			55.8100			18.0000	1004.5800 (32d)
Internal Ceiling 1			55.8100			18.0000	1004.5800 (32e)
Heat capacity Cm = Sum(A x k)						(28)...(30) + (32) + (32a)...(32e) =	21765.8100 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							193.1819 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							10.3899 (36)
Total fabric heat loss						(33) + (36) =	87.8355 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m	53.5816	53.2582	52.9412	51.4523	51.1737	49.8769	49.8769	49.6368	50.3764	51.1737	51.7373	52.3265 (38)
Heat transfer coeff	141.4171	141.0937	140.7767	139.2878	139.0092	137.7124	137.7124	137.4723	138.2119	139.0092	139.5728	140.1619 (39)
Average = Sum(39)m / 12 =												139.2865 (39)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP	1.2551	1.2523	1.2495	1.2362	1.2338	1.2223	1.2223	1.2201	1.2267	1.2338	1.2388	1.2440 (40)
HLP (average)												1.2362 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)

Regs Region: England

Elmhurst Energy Systems

SAP2012 Calculator (Design

System) version 4.14r16

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)

CALCULATION OF ENERGY RATINGS FOR IMPROVED DWELLING 09 Jan 2014

Energy content (annual)												Total = Sum(45)m =	1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m	24.8143	21.7027	22.3953	19.5247	18.7345	16.1664	14.9806	17.1904	17.3957	20.2730	22.1296	24.0313 (46)	
Water storage loss:													
Total storage loss	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)	
If cylinder contains dedicated solar storage	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)	
Combi loss	14.1536	12.7725	14.1149	13.6233	14.0423	13.5489	13.9753	14.0188	13.5894	14.0809	13.6669	14.1411 (61)	
Total heat required for water heating calculated for each month	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (62)	
Aperture area of solar collector												3.0000 (H1)	
Zero-loss collector efficiency												0.7000 (H2)	
Collector heat loss coefficient												1.8000 (H3)	
Collector 2nd order heat loss coefficient												0.0050 (H3a)	
Collector effective heat loss coefficient												1.8063 (H3b)	
Collector performance ratio												2.5804 (H4)	
Annual solar radiation per m2												1079.5246 (H5)	
Overshading factor												0.8000 (H6)	
Solar energy available												1813.6014 (H7)	
Adjustment factor for showers												1.0000 (H7a)	
Solar-to-load ratio												1.1366 (H8)	
Utilisation factor												0.5851 (H9)	
Collector performance factor												0.8793 (H10)	
Dedicated solar storage volume												75.0000 (H11)	
Effective solar volume												75.0000 (H13)	
Daily hot water demand												101.4110 (H14)	
Volume ratio Veff/V												0.7396 (H15)	
Solar storage volume factor												0.9397 (H16)	
Solar input												-876.7982 (H17)	
Solar input	-25.4254	-42.4277	-72.2592	-96.8416	-119.6396	-117.6248	-116.0703	-101.4112	-79.4253	-54.2382	-30.1582	-21.2767 (63)	
	Solar input (sum of months) = Sum(63)m =											-876.7982 (63)	
Output from w/h	154.1568	115.0297	91.1575	46.9467	19.2991	3.7002	0.0000	27.2102	50.1355	94.9963	131.0394	153.0731 (64)	
	Total per year (kWh/year) = Sum(64)m =											886.7445 (64)	
Heat gains from water heating, kWh/month	58.5434	51.3009	53.1716	46.6857	45.0386	39.2228	36.7007	41.6101	41.9579	48.4588	52.4707	56.8047 (65)	

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	64.1551	56.9820	46.3409	35.0830	26.2250	22.1402	23.9233	31.0964	41.7375	52.9954	61.8534	65.9382	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	410.9517	415.2160	404.4699	381.5927	352.7143	325.5726	307.4404	303.1760	313.9221	336.7993	365.6777	392.8194	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	78.6874	76.3406	71.4672	64.8412	60.5358	54.4761	49.3289	55.9275	58.2748	65.1328	72.8759	76.3504	(72)
Total internal gains	668.2024	662.9469	636.6863	595.9252	553.8833	516.5973	495.1009	504.6082	528.3427	569.3358	614.8154	649.5162	(73)

6. Solar gains

[Jan]	Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Access factor Table 6d	Gains W
Northeast	8.3200	11.2829	0.4400	0.0000	0.7700	31.8045 (75)
Southeast	0.8400	36.7938	0.4400	0.0000	0.7700	10.4712 (77)
Southwest	7.2400	36.7938	0.4400	0.0000	0.7700	90.2520 (79)
Northwest	1.4400	11.2829	0.4400	0.0000	0.7700	5.5046 (81)

Solar gains	138.0324	247.5129	371.5749	515.5732	627.8450	645.4565	613.0704	525.9240	420.9081	282.4297	167.5878	116.6667 (83)
Total gains	806.2349	910.4598	1008.2612	1111.4984	1181.7284	1162.0538	1108.1713	1030.5322	949.2509	851.7655	782.4032	766.1829 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (C)												21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
tau	42.7534	42.8514	42.9479	43.4069	43.4939	43.9035	43.9035	43.9802	43.7448	43.4939	43.3183	43.1362
alpha	3.8502	3.8568	3.8632	3.8938	3.8996	3.9269	3.9269	3.9320	3.9163	3.8996	3.8879	3.8757
util living area	0.9894	0.9822	0.9657	0.9226	0.8300	0.6753	0.5224	0.5755	0.7984	0.9436	0.9823	0.9913 (86)
MIT	19.4471	19.6315	19.9387	20.3420	20.6888	20.9034	20.9730	20.9606	20.8044	20.3596	19.8326	19.4122 (87)
Th 2	19.8761	19.8784	19.8806	19.8911	19.8931	19.9022	19.9022	19.9039	19.8987	19.8931	19.8891	19.8850 (88)
util rest of house	0.9867	0.9775	0.9564	0.9005	0.7810	0.5864	0.4030	0.4546	0.7244	0.9228	0.9768	0.9890 (89)
MIT 2	17.8296	18.0981	18.5419	19.1171	19.5774	19.8309	19.8902	19.8846	19.7321	19.1541	18.3994	17.7847 (90)
Living area fraction	fLA = Living area / (4) =											0.1278 (91)
MIT	18.0363	18.2941	18.7204	19.2736	19.7195	19.9680	20.0286	20.0221	19.8691	19.3082	18.5826	17.9927 (92)
Temperature adjustment												-0.1500
adjusted MIT	17.8863	18.1441	18.5704	19.1236	19.5695	19.8180	19.8786	19.8721	19.7191	19.1582	18.4326	17.8427 (93)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)

Calculation of Energy Ratings for Improved Dwelling 09 Jan 2014

8. Space heating requirement

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Utilisation	0.9792	0.9670	0.9412	0.8810	0.7641	0.5789	0.4002	0.4508	0.7101	0.9042	0.9662	0.9825	(94)
Useful gains	789.4633	880.3809	948.9941	979.1924	902.9547	672.7567	443.5330	464.6058	674.0339	770.1450	755.9399	752.7675	(95)
Ext temp.	4.3000	4.9000	6.5000	8.9000	11.7000	14.6000	16.6000	16.4000	14.1000	10.6000	7.1000	4.2000	(96)
Heat loss rate W	1921.3386	1868.6617	1699.2304	1424.0282	1093.9309	718.5785	451.5010	477.3178	776.6327	1189.6641	1581.7176	1912.1869	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(97a)
Space heating kWh	842.1152	664.1247	558.1759	320.2818	142.0863	0.0000	0.0000	0.0000	0.0000	312.1222	594.5599	862.6080	(98)
Space heating												4296.0740	(98)
Space heating per m2											(98) / (4) =	38.1297	(99)

8c. Space cooling requirement

Not applicable

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 11)													0.0000	(201)
Fraction of space heat from main system(s)													1.0000	(202)
Efficiency of main space heating system 1 (in %)													90.5000	(206)
Efficiency of secondary/supplementary heating system, %													0.0000	(208)
Space heating requirement													4747.0431	(211)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
Space heating requirement	842.1152	664.1247	558.1759	320.2818	142.0863	0.0000	0.0000	0.0000	0.0000	312.1222	594.5599	862.6080	(98)	
Space heating efficiency (main heating system 1)	90.5000	90.5000	90.5000	90.5000	90.5000	0.0000	0.0000	0.0000	0.0000	90.5000	90.5000	90.5000	(210)	
Space heating fuel (main heating system)	930.5141	733.8394	616.7689	353.9025	157.0014	0.0000	0.0000	0.0000	0.0000	344.8864	656.9723	953.1581	(211)	
Water heating requirement	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(215)	
Water heating														
Water heating requirement	154.1568	115.0297	91.1575	46.9467	19.2991	3.7002	0.0000	27.2102	50.1355	94.9963	131.0394	153.0731	(64)	
Efficiency of water heater	89.9896	90.0129	90.0367	90.0779	90.1050	87.3000	87.3000	87.3000	87.3000	89.7325	89.9049	87.3000	(216)	
(217)m	89.9896	90.0129	90.0367	90.0779	90.1050	87.3000	87.3000	87.3000	87.3000	89.7325	89.9049	90.0028	(217)	
Fuel for water heating, kWh/month	171.3051	127.7925	101.2449	52.1179	21.4184	4.2385	0.0000	31.1687	57.4290	105.8661	145.7534	170.0759	(219)	
Water heating fuel used												988.4103	(219)	
Annual totals kWh/year														
Space heating fuel - main system												4747.0431	(211)	
Space heating fuel - secondary												0.0000	(215)	
Electricity for pumps and fans:														
central heating pump													30.0000	(230c)
main heating flue fan													45.0000	(230e)
pump for solar water heating													50.0000	(230g)
Total electricity for the above, kWh/year													125.0000	(231)
Electricity for lighting (calculated in Appendix L)													453.1995	(232)
Energy saving/generation technologies (Appendices M, N and Q)														
PV Unit 0 (0.80 * 2.50 * 1080 * 0.80) =													-1727.2394	(233)
Total delivered energy for all uses													4586.4136	(238)

10a. Fuel costs - using Table 12 prices

	Fuel kWh/year	Fuel price p/kWh	Fuel cost £/year	
Space heating - main system 1	4747.0431	3.4800	165.1971	(240)
Space heating - secondary	0.0000	0.0000	0.0000	(242)
Water heating (other fuel)	988.4103	3.4800	34.3967	(247)
Pumps and fans for heating	75.0000	13.1900	9.8925	(249)
Pump for solar water heating	50.0000	13.1900	6.5950	(249)
Energy for lighting	453.1995	13.1900	59.7770	(250)
Additional standing charges			120.0000	(251)
Energy saving/generation technologies				
PV Unit	-1727.2394	13.1900	-227.8229	(252)
Total energy cost			168.0354	(255)


11a. SAP rating - Individual heating systems

Energy cost deflator (Table 12):			0.4200	(256)
Energy cost factor (ECF)		[(255) x (256)] / [(4) + 45.0] =	0.4476	(257)
SAP value			93.7558	
SAP rating (Section 12)			94	(258)
SAP band			A	

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF ENERGY RATINGS FOR IMPROVED DWELLING 09 Jan 2014

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year	
Space heating - main system 1	4747.0431	0.2160	1025.3613	(261)
Space heating - secondary	0.0000	0.0000	0.0000	(263)
Water heating (other fuel)	988.4103	0.2160	213.4966	(264)
Space and water heating			1238.8579	(265)
Pumps and fans	125.0000	0.5190	64.8750	(267)
Energy for lighting	453.1995	0.5190	235.2106	(268)
Energy saving/generation technologies				
PV Unit	-1727.2394	0.5190	-896.4372	(269)
Total kg/year			642.5063	(272)
CO2 emissions per m2			5.7000	(273)
EI value			94.5395	
EI rating			95	(274)
EI band			A	

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY FOR IMPROVED DWELLING 09 Jan 2014

SAP 2012 WORKSHEET FOR New Build (As Designed) (Version 9.92, January 2014)
 CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY FOR IMPROVED DWELLING 09 Jan 2014

1. Overall dwelling dimensions

	Area (m ²)	Storey height (m)	Volume (m ³)
Ground floor	56.8600 (1b)	x 2.3500 (2b)	= 133.6210 (1b) - (3b)
First floor	55.8100 (1c)	x 2.5200 (2c)	= 140.6412 (1c) - (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)...(1n)	112.6700		(4)
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)...(3n)	= 274.2622 (5)

2. Ventilation rate

	main heating	secondary heating	other	total	m ³ per hour
Number of chimneys	0	+	0	=	0 * 40 = 0.0000 (6a)
Number of open flues	0	+	0	=	0 * 20 = 0.0000 (6b)
Number of intermittent fans					4 * 10 = 40.0000 (7a)
Number of passive vents					0 * 10 = 0.0000 (7b)
Number of flueless gas fires					0 * 40 = 0.0000 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =					40.0000 / (5) = 0.1458 (8)
Pressure test					Yes
Measured/design AP50					5.0000
Infiltration rate					0.3958 (18)
Number of sides sheltered					2 (19)
Shelter factor				(20) = 1 - [0.075 x (19)] =	0.8500 (20)
Infiltration rate adjusted to include shelter factor				(21) = (18) x (20) =	0.3365 (21)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Wind speed	4.2000	4.0000	4.0000	3.7000	3.7000	3.3000	3.4000	3.2000	3.3000	3.5000	3.5000	3.8000 (22)
Wind factor	1.0500	1.0000	1.0000	0.9250	0.9250	0.8250	0.8500	0.8000	0.8250	0.8750	0.8750	0.9500 (22a)
Adj infilt rate	0.3533	0.3365	0.3365	0.3112	0.3112	0.2776	0.2860	0.2692	0.2776	0.2944	0.2944	0.3196 (22b)
Effective ac	0.5624	0.5566	0.5566	0.5484	0.5484	0.5385	0.5409	0.5362	0.5385	0.5433	0.5433	0.5511 (25)

3. Heat losses and heat loss parameter

Element	Gross m ²	Openings m ²	NetArea m ²	U-value W/m ² K	A x U W/K	K-value kJ/m ² K	A x K kJ/K
Opening Type 1			2.1500	1.4000	3.0100		(26)
Opening Type 2 (Uw = 1.30)			17.8400	1.2357	22.0456		(27)
Opening Type 3			2.1500	1.6000	3.4400		(26a)
Heat Loss Floor 1			56.8600	0.1900	10.8034	75.0000	4264.5000 (28a)
Brick Cavity	149.5100	22.1400	127.3700	0.2500	31.8425	60.0000	7642.2000 (29a)
Main Plane	55.8100		55.8100	0.1100	6.1391	9.0000	502.2900 (30)
Bay Roof	1.5000		1.5000	0.1100	0.1650	9.0000	13.5000 (30)
Total net area of external elements Aum(A, m ²)			263.6800				(31)
Fabric heat loss, W/K = Sum (A x U)				(26)...(30) + (32) =	77.4456		(33)
Internal Wall 1			73.8800			75.0000	5541.0000 (32c)
Internal Wall 2			199.2400			9.0000	1793.1600 (32c)
Internal Floor 1			55.8100			18.0000	1004.5800 (32d)
Internal Ceiling 1			55.8100			18.0000	1004.5800 (32e)
Heat capacity Cm = Sum(A x k)						(28)...(30) + (32) + (32a)...(32e) =	21765.8100 (34)
Thermal mass parameter (TMP = Cm / TFA) in kJ/m ² K							193.1819 (35)
Thermal bridges (Sum(L x Psi) calculated using Appendix K)							10.3899 (36)
Total fabric heat loss						(33) + (36) =	87.8355 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m	50.9016	50.3764	50.3764	49.6368	49.6368	48.7402	48.9548	48.5321	48.7402	49.1757	49.1757	49.8769 (38)
Heat transfer coeff	138.7371	138.2119	138.2119	137.4723	137.4723	136.5757	136.7903	136.3676	136.5757	137.0112	137.0112	137.7124 (39)
Average = Sum(39)m / 12 =												137.3458 (39)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
HLP	1.2314	1.2267	1.2267	1.2201	1.2201	1.2122	1.2141	1.2103	1.2122	1.2160	1.2160	1.2223 (40)
HLP (average)												1.2190 (40)
Days in month	31	28	31	30	31	30	31	31	30	31	30	31 (41)

4. Water heating energy requirements (kWh/year)

Assumed occupancy												2.8299 (42)
Average daily hot water use (litres/day)												101.4110 (43)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Daily hot water use	111.5521	107.4957	103.4392	99.3828	95.3264	91.2699	91.2699	95.3264	99.3828	103.4392	107.4957	111.5521 (44)
Energy conte	165.4286	144.6849	149.3019	130.1650	124.8964	107.7761	99.8704	114.6027	115.9715	135.1535	147.5307	160.2088 (45)

Regs Region: England

Elmhurst Energy Systems

SAP2012 Calculator (Design

System) version 4.14r16

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY FOR IMPROVED DWELLING 09 Jan 2014

Energy content (annual)												Total = Sum(45)m =	1595.5903 (45)
Distribution loss (46)m = 0.15 x (45)m													
	24.8143	21.7027	22.3953	19.5247	18.7345	16.1664	14.9806	17.1904	17.3957	20.2730	22.1296	24.0313 (46)	
Water storage loss:													
Total storage loss													
	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (56)	
If cylinder contains dedicated solar storage													
	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000 (57)	
Combi loss	14.1536	12.7725	14.1149	13.6233	14.0423	13.5489	13.9753	14.0188	13.5894	14.0809	13.6669	14.1411 (61)	
Total heat required for water heating calculated for each month													
	179.5822	157.4574	163.4167	143.7882	138.9387	121.3250	113.8457	128.6215	129.5609	149.2345	161.1975	174.3498 (62)	
Aperture area of solar collector												3.0000 (H1)	
Zero-loss collector efficiency												0.7000 (H2)	
Collector heat loss coefficient												1.8000 (H3)	
Collector 2nd order heat loss coefficient												0.0050 (H3a)	
Collector effective heat loss coefficient												1.8063 (H3b)	
Collector performance ratio												2.5804 (H4)	
Annual solar radiation per m2												1140.0998 (H5)	
Overshading factor												0.8000 (H6)	
Solar energy available												1915.3676 (H7)	
Adjustment factor for showers												1.0000 (H7a)	
Solar-to-load ratio												1.2004 (H8)	
Utilisation factor												0.5653 (H9)	
Collector performance factor												0.8793 (H10)	
Dedicated solar storage volume												75.0000 (H11)	
Effective solar volume												75.0000 (H13)	
Daily hot water demand												101.4110 (H14)	
Volume ratio Veff/V												0.7396 (H15)	
Solar storage volume factor												0.9397 (H16)	
Solar input												-894.5790 (H17)	
Solar input	-27.5347	-41.3846	-69.6969	-96.3424	-116.0287	-122.1152	-119.1829	-106.4311	-83.0698	-56.5109	-33.4691	-22.8127 (63)	
	Solar input (sum of months) = Sum(63)m =											-894.5790 (63)	
Output from w/h	152.0475	116.0728	93.7198	47.4458	22.9100	0.0000	0.0000	22.1904	46.4910	92.7236	127.7284	151.5371 (64)	
	Total per year (kWh/year) = Sum(64)m =											872.8665 (64)	
Heat gains from water heating, kWh/month	58.5434	51.3009	53.1716	46.6857	45.0386	39.2228	36.7007	41.6101	41.9579	48.4588	52.4707	56.8047 (65)	

5. Internal gains (see Table 5 and 5a)

Metabolic gains (Table 5), Watts	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	169.7963	(66)
Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5	64.1551	56.9820	46.3409	35.0830	26.2250	22.1402	23.9233	31.0964	41.7375	52.9954	61.8534	65.9382	(67)
Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5	410.9517	415.2160	404.4699	381.5927	352.7143	325.5726	307.4404	303.1760	313.9221	336.7993	365.6777	392.8194	(68)
Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	54.8096	(69)
Pumps, fans	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	3.0000	(70)
Losses e.g. evaporation (negative values) (Table 5)	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	-113.1975	(71)
Water heating gains (Table 5)	78.6874	76.3406	71.4672	64.8412	60.5358	54.4761	49.3289	55.9275	58.2748	65.1328	72.8759	76.3504	(72)
Total internal gains	668.2024	662.9469	636.6863	595.9252	553.8833	516.5973	495.1009	504.6082	528.3427	569.3358	614.8154	649.5162	(73)

6. Solar gains

[Jan]	Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Access factor Table 6d	Gains W
Northeast	8.3200	12.9236	0.4400	0.0000	0.7700	36.4291 (75)
Southeast	0.8400	40.4699	0.4400	0.0000	0.7700	11.5174 (77)
Southwest	7.2400	40.4699	0.4400	0.0000	0.7700	99.2691 (79)
Northwest	1.4400	12.9236	0.4400	0.0000	0.7700	6.3050 (81)

Solar gains	153.5207	248.4493	370.3669	532.4620	633.4976	697.4744	655.1384	573.6553	455.8138	303.2521	191.1020	128.4161	(83)
Total gains	821.7232	911.3963	1007.0532	1128.3872	1187.3809	1214.0716	1150.2393	1078.2635	984.1565	872.5879	805.9174	777.9323	(84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9a, Th1 (C)												21.0000 (85)
Utilisation factor for gains for living area, nil,m (see Table 9a)												
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
tau	43.5793	43.7448	43.7448	43.9802	43.9802	44.2689	44.1995	44.3365	44.2689	44.1282	44.1282	43.9035
alpha	3.9053	3.9163	3.9163	3.9320	3.9320	3.9513	3.9466	3.9558	3.9513	3.9419	3.9419	3.9269
util living area	0.9866	0.9790	0.9577	0.8973	0.7656	0.5356	0.3641	0.3979	0.7037	0.9186	0.9755	0.9889 (86)
MIT	19.6075	19.7649	20.0856	20.4863	20.8092	20.9673	20.9947	20.9926	20.9002	20.5130	20.0036	19.5795 (87)
Th 2	19.8950	19.8987	19.8987	19.9039	19.9039	19.9103	19.9088	19.9117	19.9103	19.9072	19.9072	19.9022 (88)
util rest of house	0.9830	0.9734	0.9458	0.8677	0.6999	0.4301	0.2382	0.2660	0.6056	0.8880	0.9676	0.9858 (89)
MIT 2	18.0752	18.3050	18.7646	19.3233	19.7309	19.8929	19.9077	19.9101	19.8409	19.3743	18.6581	18.0397 (90)
Living area fraction	fLA = Living area / (4) =											0.1278 (91)
MIT	18.2711	18.4916	18.9334	19.4720	19.8687	20.0302	20.0466	20.0484	19.9762	19.5198	18.8301	18.2365 (92)
Temperature adjustment												-0.1500
adjusted MIT	18.1211	18.3416	18.7834	19.3220	19.7187	19.8802	19.8966	19.8984	19.8262	19.3698	18.6801	18.0865 (93)

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)

CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY FOR IMPROVED DWELLING 09 Jan 2014

8. Space heating requirement

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Utilisation	0.9743	0.9619	0.9294	0.8482	0.6873	0.4270	0.2368	0.2644	0.5971	0.8684	0.9548	0.9781	(94)
Useful gains	800.6181	876.7030	935.9708	957.1194	816.0610	518.4616	272.4011	285.0509	587.6426	757.7492	769.5199	760.9272	(95)
Ext temp.	5.1000	5.6000	7.4000	9.9000	13.0000	16.0000	17.9000	17.8000	15.2000	11.6000	8.0000	5.1000	(96)
Heat loss rate W	1806.5037	1761.0403	1573.3284	1295.2597	923.6403	529.9383	273.1165	286.1582	631.8333	1064.5549	1463.2896	1788.4048	(97)
Month fracti	1.0000	1.0000	1.0000	1.0000	1.0000	0.0000	0.0000	0.0000	0.0000	1.0000	1.0000	1.0000	(97a)
Space heating kWh	748.3788	594.2746	474.1941	243.4610	80.0390	0.0000	0.0000	0.0000	0.0000	228.2634	499.5142	764.4434	(98)
Space heating												3632.5685	(98)
Space heating per m2											(98) / (4) =	32.2408	(99)

8c. Space cooling requirement

Not applicable

9a. Energy requirements - Individual heating systems, including micro-CHP

Fraction of space heat from secondary/supplementary system (Table 11)													0.0000 (201)
Fraction of space heat from main system(s)													1.0000 (202)
Efficiency of main space heating system 1 (in %)													90.5000 (206)
Efficiency of secondary/supplementary heating system, %													0.0000 (208)
Space heating requirement													4013.8879 (211)
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Space heating requirement	748.3788	594.2746	474.1941	243.4610	80.0390	0.0000	0.0000	0.0000	0.0000	228.2634	499.5142	764.4434	(98)
Space heating efficiency (main heating system 1)	90.5000	90.5000	90.5000	90.5000	90.5000	0.0000	0.0000	0.0000	0.0000	90.5000	90.5000	90.5000	(210)
Space heating fuel (main heating system)	826.9379	656.6571	523.9714	269.0177	88.4409	0.0000	0.0000	0.0000	0.0000	252.2247	551.9494	844.6888	(211)
Water heating requirement	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	(215)
Water heating													
Water heating requirement	152.0475	116.0728	93.7198	47.4458	22.9100	0.0000	0.0000	22.1904	46.4910	92.7236	127.7284	151.5371	(64)
Efficiency of water heater	89.9433	89.9612	89.9559	89.9622	89.7678	87.3000	87.3000	87.3000	87.3000	89.5518	89.8295	87.3000	(216)
(217)m	89.9433	89.9612	89.9559	89.9622	89.7678	87.3000	87.3000	87.3000	87.3000	89.5518	89.8295	89.9545	(217)
Fuel for water heating, kWh/month	169.0482	129.0255	104.1843	52.7397	25.5214	0.0000	0.0000	25.4186	53.2543	103.5419	142.1898	168.4598	(219)
Water heating fuel used												973.3834	(219)
Annual totals kWh/year													
Space heating fuel - main system												4013.8879	(211)
Space heating fuel - secondary												0.0000	(215)
Electricity for pumps and fans:													
central heating pump												30.0000	(230c)
main heating flue fan												45.0000	(230e)
pump for solar water heating												50.0000	(230g)
Total electricity for the above, kWh/year												125.0000	(231)
Electricity for lighting (calculated in Appendix L)												453.1995	(232)
Energy saving/generation technologies (Appendices M, N and Q)													
PV Unit 0 (0.80 * 2.50 * 1140 * 0.80) =										-1824.1596		-1824.1596	(233)
Total delivered energy for all uses												3741.3112	(238)

10a. Fuel costs - using BEDF prices (470)


	Fuel kWh/year	Fuel price p/kWh	Fuel cost £/year	
Space heating - main system 1	4013.8879	3.8700	155.3375	(240)
Space heating - secondary	0.0000	0.0000	0.0000	(242)
Water heating (other fuel)	973.3834	3.8700	37.6699	(247)
Pumps and fans for heating	75.0000	18.9000	14.1750	(249)
Pump for solar water heating	50.0000	18.9000	9.4500	(249)
Energy for lighting	453.1995	18.9000	85.6547	(250)
Additional standing charges			93.0000	(251)
Energy saving/generation technologies				
PV Unit	-1824.1596	18.9000	-344.7662	(252)
Total energy cost			50.5209	(255)

12a. Carbon dioxide emissions - Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year	
Space heating - main system 1	4013.8879	0.2160	866.9998	(261)
Space heating - secondary	0.0000	0.0000	0.0000	(263)
Water heating (other fuel)	973.3834	0.2160	210.2508	(264)
Space and water heating			1077.2506	(265)
Pumps and fans	125.0000	0.5190	64.8750	(267)
Energy for lighting	453.1995	0.5190	235.2106	(268)
Energy saving/generation technologies				

FULL SAP CALCULATION PRINTOUT

Calculation Type: New Build (As Designed)



CALCULATION OF EPC COSTS, EMISSIONS AND PRIMARY ENERGY FOR IMPROVED DWELLING 09 Jan 2014

PV Unit	-1824.1596	0.5190	-946.7389 (269)
Total kg/year			430.5973 (272)

13a. Primary energy - Individual heating systems including micro-CHP

	Energy kWh/year	Primary energy factor kg CO2/kWh	Primary energy kWh/year
Space heating - main system 1	4013.8879	1.2200	4896.9432 (261)
Space heating - secondary	0.0000	0.0000	0.0000 (263)
Water heating (other fuel)	973.3834	1.2200	1187.5278 (264)
Space and water heating			6084.4710 (265)
Pumps and fans	125.0000	3.0700	383.7500 (267)
Energy for lighting	453.1995	3.0700	1391.3225 (268)
Energy saving/generation technologies			
PV Unit	-1824.1596	3.0700	-5600.1701 (269)
Primary energy kWh/year			2259.3734 (272)
Primary energy kWh/m2/year			20.0530 (273)

SAP 2012 OVERHEATING ASSESSMENT FOR New Build (As Designed) 9.92

Overheating Calculation Input Data

Dwelling type	Detached House
Number of storeys	2
Cross ventilation possible	Yes
SAP Region	Thames Valley
Front of dwelling faces	South West
Overshading	Average or unknown
Thermal mass parameter	193.2 (calculated from construction elements)
Night ventilation	Yes
Ventilation rate during hot weather (ach)	4.00 (Windows half open)

Overheating Calculation

Summer ventilation heat loss coefficient	362.03 (P1)
Transmission heat loss coefficient	87.84 (37)
Summer heat loss coefficient	449.86 (P2)

Overhangs Orientation	Ratio	Z_overhangs	Overhang type
North East	0.000	1.000	None
South East	0.000	1.000	None
South West	0.000	1.000	None
North West	0.000	1.000	None

Solar shading Orientation	Z blinds	Solar access	Z overhangs	Z summer
North East	1.000	0.90	1.000	0.900 (P8)
South East	1.000	0.90	1.000	0.900 (P8)
South West	1.000	0.90	1.000	0.900 (P8)
North West	1.000	0.90	1.000	0.900 (P8)

[Jul]	Area m2	Solar flux Table 6a W/m2	g Specific data or Table 6b	FF Specific data or Table 6c	Shading	Gains W
North East	8.3200	98.8453	0.4400	0.0000	0.9000	325.6675
South East	0.8400	119.9223	0.4400	0.0000	0.9000	39.8910
South West	7.2400	119.9223	0.4400	0.0000	0.9000	343.8222
North West	1.4400	98.8453	0.4400	0.0000	0.9000	56.3655
total:						765.7462

	Jun	Jul	Aug	
Solar gains	815	766	671	(P4)
Internal gains	514	492	502	
Total summer gains	1329	1258	1172	(P5)
Summer gain/loss ratio	2.95	2.80	2.61	(P6)
Summer external temperature	16.00	17.90	17.80	
Thermal mass temperature increment (TMP = 193.2)	0.65	0.65	0.65	
Threshold temperature	19.60	21.34	21.05	(P7)
Likelihood of high internal temperature	Not significant	Slight	Slight	
Assessment of likelihood of high internal temperature:	Slight			