

[REDACTED]

From: Mark Warwick
Sent: 31 May 2019 15:05
To: Michael Eastham
Subject: A/40/18/OUT - Suggested condition in respect of Retained Tree Protection Measures

In the event that a RPA of any tree which is proposed for retention overlaps the development then BS5837:2012 requires that the Detailed Planning Application is accompanied by an Arboricultural Method Statement (AMS) and also most importantly a Tree Protection Plan – to both describe and illustrate the mitigation measures which are to be employed to ensure that the trees survive without detriment to their vigour and vitality and are given adequate protection both above and below ground.

Mark Warwick | Tree Officer, Greenspace, Arun District Council | Location: Bognor Regis Town Hall, Clarence Road, Bognor Regis, West Sussex, PO21 1LD

Internal: 37974 | External: +44 (0) 1903 737974 | E-mail: mark.warwick@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.