



Sussex Police
Serving Sussex

www.sussex.police.uk

Local Policing Branch

Your Ref: A/44/17/OUT

Our Ref: PE/ARU/17/15/A

Date: 18th April 2017

Contact Name: Phillip Edwards

Dear Mr Easton

Re: Land West of Brook Lane & South of A259 Angmering, BN16 3JL.

Thank you for your correspondence of 13th March 2017, advising me of an outline planning application (with all matters reserved) for demolition of existing buildings on site and the erection of a mixed use development comprising 90No residential units and a care home (Use Class C2 and C3) & ancillary facilities, including railway crossing, together with associated access, car parking & landscaping at the above location, for which you seek advice from a crime prevention viewpoint. My comments will be broad with more in-depth advice being delivered at reserved matters.

I have had the opportunity to examine the detail within the application and in an attempt to reduce the opportunity for crime and the fear of crime I offer the following comments from a Secured by Design (SBD) perspective. SBD is owned by the Police service and supported by the home office that recommends a minimum standard of security using proven, tested and accredited products. Detail can be found on www.securedbydesign.com

The National Planning Policy Framework demonstrates the government's commitment to creating safe and accessible environments where crime and disorder, and the fear of crime, do not undermine the quality of life or community cohesion, and with the level of crime and anti-social behaviour in Arun district being below average when compared with the rest of Sussex, I have no major concerns with the proposals, however, additional measures to mitigate against any identified local crime trends should be considered.

I was pleased to note contact was established with network rail and they have been consulted.

The development in the main has outward facing dwellings with back to back gardens which has created good active frontage with the streets and the public areas being overlooked. Parking in the main has been provided with in-curtilage, garage and a number of on street parking bays, this should leave the street layout free and unobstructed.

Where communal parking occurs it is important that they must be within view of an active room within the property. An active room is where there is direct and visual connection between the room and the street or the car parking area. Such visual connections can be expected from rooms such as kitchens and living rooms, but not from bedrooms and bathrooms. Gable ended windows can assist in providing observation over an otherwise unobserved area.

Mr D Easton
Planning Officer
Planning Control
Arun District Council

Sussex Police Headquarters
Mailing House, Mailing, Lewes, East Sussex, BN7 2DZ

Telephone: 101 | 01273 470 101

As the first line of defence, perimeter fencing must be adequate with vulnerable areas such as side and rear gardens needing more robust defensive barriers by using walls or fencing to a minimum height of 1.8metres. In circumstances that require a more open feature such as a garden overlooking a rear parking court or a rear garden pathway, 1.5metre high close board fencing topped with 300mm of trellis can achieve both security and surveillance requirements. This solution provides surveillance into an otherwise unobserved area and a security height of 1.8 metres.

Gates that provide access to the side of the dwelling or rear access to the gardens must be robustly constructed of timber, be the same height as the adjoining fence and be lockable from both sides. Such gates must be located on or as near to the front of the building line as possible.

Areas of play should be situated in an environment that is stimulating and safe for all children, be overlooked with good natural surveillance to ensure the safety of users and the protection of equipment, which can be vulnerable to misuse. I would recommend that the eventual location is surrounded with railings with self-closing gates to provide a dog free environment.

Care Home

Given the proposed end user of the building it will be essential to incorporate access control to the building skin and additionally within the building. Compartmentalisation to some aspects within the building will need to be implemented such as segregating the residential side from the semi-public meeting recreational areas. Further advice can be given at reserved matters.

Finally lighting throughout the development will be an important consideration and should conform to BS5489:2013.

I would also ask you to note that Sussex Police is now exploring the impact of growth on the provision of policing infrastructure over the coming years and further comment on this application may be made by our Joint Commercial Planning Manager.

The Crime & Disorder Act 1998 heightens the importance of taking crime prevention into account when planning decisions are made. Section 17 of the Act places a clear duty on both police and local authorities to exercise their various functions with due regard to the likely effect on the prevention of crime and disorder. You are asked to accord due weight to the advice offered in this letter which would demonstrate your authority's commitment to work in partnership and comply with the spirit of The Crime & Disorder Act.

Yours sincerely



Phillip Edwards
Designing Out Crime Officer
Sussex Police Headquarters

Sussex Police Headquarters
Malling House, Malling, Lewes, East Sussex, BN7 2DZ

