Julie Grieves

From: Fiona Fitzgerald
Sent: 08 June 2015 10:25
To: Planning.Responses; Anita Gardner
Subject: A/50/15/PL

Dear Anita,

Environmental Health have no objections in principle to this application.

Please could you ask the applicant to forward details of any external units to be installed on the exterior of the new annex –air conditioning/heating installations. Please ask them to include details of the location, number, and assessment of any noise impact on the nearest noise sensitive neighbours.

Many thanks

Fiona