

**ADC Planning Consultation
Response from the Historic Buildings Adviser**

Application Number	A/51/12/DOC
Address	The Dower House, Angmering
Description	Approval of details reserved by Conditions 5 and 6 following approval of A/147/11/L
Case Officer	Peter Cleveland
Site Visit	

No Objection subject to amendment

Condition 5

The details are considered acceptable and may be discharged. Sample panel required for approval in due course.

Condition 6

The approved scheme shows full height casements with light framing, however the window details appear to refer to the use of storm casements with top opening vents. This type of window design is overly heavy and not normally appropriate for use on listed buildings. Ideally the windows should be a flush timber casement and more in accordance with that shown in drawing no: JC/11/07A of the approval.

Ian Wightman
Historic Buildings Adviser