



Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119
Email: developerservices@southernwater.co.uk

Your Ref
A/67/15/DOC
Our Ref
PLAN-010386
Date
09/07/2015

Dear Sirs,

Proposal: Application for approval of matters reserved by condition imposed under A/167/14/PL relating to conditions 3, 4, 6, 10, 11, 12, 13, 14, 15, 18, 20, 21, 22 & 23 for schedule of materials, tree protection, prevention of surface water drainage on highway, construction of roads, footways/casual parking areas, Travel Plan, archaeological programme, ecological mitigation report, broadband speed, foul water sewerage disposal, surface water drainage, SUDs system, refuse & recycling bins & decentralised & renewable or low carbon energy source.

Site: Former Pound Nursery, Roundstone Lane, Angmering, BN16 4AL.
A/67/15/DOC

Thank you for your letter of 06/07/2015

We regret that Southern Water cannot recommend discharge of foul condition as the drawing submitted does not comply with Sewer for Adoption standards.

The Council's Building Control officers/technical staff and the Environment Agency should be consulted regarding the discharge condition for surface water disposal.

Yours sincerely

JP Developer Services

SOUTHERN WATER

The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298536

O.S. REF: TQ0703NW

Scale: 1:1250

Sewer Plot

WARNING: BAC pipes are constructed of Bonded Asbestos Cement
WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement



Printed By: banuh

Date: 7-7-2015

Southern Water MapGuide Browser

Requested By:



SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: TQ0703NW

Scale: 1:1250

Sewer Plot

WARNING: BAC pipes are constructed of Bonded Asbestos Cement

WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement

ARUN DISTRICT COUNCIL A/67/15/DOC



Printed By: banuh

Date: 7-7-2015

Southern Water MapGuide Browser

Requested By: