




From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 07 February 2022 11:14

To: Harry Chalk <Harry.Chalk@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Stitches And Frames The Square Angmering BN16 4EA - A/6/22/DOC

Planning Application: A/6/22/DOC

Proposal: Approval of details reserved by condition imposed under A/197/21/PL relating to conditions 5-Acoustic Assessment and 6-sound insulation test.

Location: Stitches And Frames The Square Angmering BN16 4EA

Dear Harry,

Condition 5 (Noise Assessment)

Having reviewed the document entitled 'Noise Assessment for a Discharge of Condition' (dated 21/12/2021) [produced by Acoustics Associates Sussex], I find the report, methodology and findings to be reliable. I therefore recommend that any future permission granted is in accordance with the Acoustics Associates Sussex report such that the Sound Pressure Level produced by the extraction system is attenuated by 16.4dB(A), and the sound power level of the proposed condensers shall not exceed 68dB(A) if they are to be used during night time hours 77dB(A) through day time hours. The mitigation methods detailed in section 13 of the report shall also be implemented and maintained.

Condition 6 (floor / ceiling testing)

Having reviewed sections 9 and 10 of the document entitled 'Noise Assessment for a Discharge of Condition' (dated 21/12/2021) [produced by Acoustic Associates Sussex Ltd.] I find the report and methodology to be reliable. I therefore recommend partial discharge of the condition. The condition may be fully discharged following approval of sound testing after completion.

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

