

From: Paul Cann
Sent: 08 June 2017 09:38
To: Planning.Responses
Subject: RE: Planning Consultation on A/70/17/DOC

Please refer to my comments made under A/22/17/DOC. I assume A/70/17/DOC is a duplicate application.

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

Paul Cann | Senior Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF
Internal: 37819 | External: +44 (0) 1903 737819 | Fax: +44 (0) 1903 716019 | E-mail: Paul.Cann@arun.gov.uk
Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 25 May 2017 16:33
To: Paul Cann
Subject: Planning Consultation on A/70/17/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION **A/70/17/DOC**

NO:

Registered: 04-MAY-17
Site Address: Juniper Mead Angmering BN16 4AX
Description of Works: Application for approval of details reserved by conditions imposed under A/144/15/PL relating to condition 3 - Surface Water Drainage Scheme.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 8th June 2017.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Lucy Harding who can be contacted on telephone number 01903 737789.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
