

From: Amanda Scholes on behalf of Planning.Responses
Sent: 01 July 2020 09:57
To: Planning Scanning
Subject: FW: A/76/20/PL

Amanda Scholes | Receptionist, Department, [Arun District Council](#) | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: amanda.scholes@arun.gov.uk



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)



Save the environment - think before you print.

From: Laura Gibbons [REDACTED]
Sent: 30 June 2020 16:35
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Michael Eastham <Michael.Eastham@arun.gov.uk>
Subject: Re: A/76/20/PL

In addition to my earlier comments on surface water drainage we will also require the following:

5. evidence that a 3m buffer is provided throughout the site to the southern watercourse (N.B. 3m is measured from the top of bank of watercourse).
6. Written assurances that should discharge to the watercourse be necessary that works will be completed to ensure the receiving watercourse and culvert are in an appropriate condition. These works should be in accordance with the works previously detailed in discussions with ADC and included as an appendix to the strategy submitted.

Kind regards,

On Tue, 30 Jun 2020 at 13:38, Laura Gibbons <laura.gibbons@adur-worthing.gov.uk> wrote:

Engineers Comments Regarding Surface Water Drainage

The application submitted includes a detailed surface water drainage strategy document that includes details of ground water monitoring. This monitoring indicates that groundwater is at or very near to the surface, therefore infiltration will not be viable on this site.

The proposal is for an attenuation basin and lined permeable paving to provide storage prior to discharge to watercourse or new surface water sewer. This is acceptable in principle as it follows the hierarchy for sustainable drainage, will provide adequate treatment, and provides wider benefits of SuDS such as amenity and biodiversity.

As the application seeks approval of a layout we request more details are provided at this time:

1. Catchment area plan to enable verification of provided calculations, preferably in dwg format.

2. Cross sections of attenuation basin, detailing offset of basin to surrounding features, including adjacent ordinary watercourse. An unobstructed 3m buffer should be provided around the attenuation basin.
3. Flotation calculations demonstrating that a safe basin design can be achieved in the given footprint and provide the required free volume for water storage.
4. Revisions to landscaping plans to move trees out of the attenuation basin- currently acers for example are proposed within the basin extents. This is not acceptable as the basin will have to be lined. Please ensure that all root potential areas are outside of surface water drainage feature extents.

Until this information is provided we would like to raise a holding objection. It is essential to establish if there is adequate space for surface water drainage prior to agreement of site layout. Drainage should be a fundamental consideration in design. Failure to secure a robustly evidenced implementable drainage strategy at this stage will likely unduly prejudice the drainage design and result in proposals failing to meet policy requirements.

Should this information be adequately provided we would then request a series of standard pre-commencement conditions, PCENG2 (amended to account for prior supply of winter testing results), PCENG3, PCENG4, and ENG1.

Please reconsult us once information for points 1-4 above is supplied.

Kind Regards,


Laura Gibbons

Engineer, Adur & Worthing Councils



Address: Facilities & Technical Services, Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA

Adur and Worthing Councils are working in partnership with Arun District Council




--

Laura Gibbons

Engineer, Adur & Worthing Councils



Address: Facilities & Technical Services, Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA



This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please send it back to us, and immediately and permanently delete it. Do not use, copy or disclose the information contained in this message or in any attachment. Whilst every care has been taken to check this e-mail for viruses, it is your responsibility to carry out checks upon receipt.