

Please treat as substitute details

Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/cil

Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.

Hi Laura

Thank you for your email and for keeping us updated. Please find attached the revised information and responses to questions below:

Condition 14

- 1) We have added this baffle between catchments A and C which is now shown on the revised Drawing 201 attached.
- 2) The subbase formation level is flat meaning there is no gradient at the base of the highway construction so each catchment acts as an infiltration blanket. The subbase thickness will therefore vary and will be greater than the minimum thickness required for surface water storage in all cases. We have shown these formation levels on Drawings 103 and 201 attached. Drawing 501 has also been updated including a note stating that the subbase thickness varies.
- 3) This detail has been added to the construction detail on Drawing 501.

Condition 16


- 1) We have updated the table to make this annually, aligning with Table 20.15 of the SuDS manual.
- 2) Table 2 has been updated to align with the frequencies shown in Table 1.

Hopefully this provides the clarifications required and we look forward to the above conditions now being recommended for discharge.

Kind regards

Martin

Martin Kempshall BSc. (Hons.) MSc CEng MICE




As an ISO 9001 : 2008 certified company, we invite you to reply to this email with any feedback (positive or negative) that you would like to share. Any response will be reviewed by the directors and quality assurance department.

This transmission contains information which may be confidential and which may also be privileged. It is intended for the named addressee only. Unless you are the named addressee, or authorised to receive it for the addressee, you may not copy or use it, or disclose it to anyone else. If you have received this transmission in error, please contact reception@civil.co.uk

Whilst this e-mail and any attachments are believed to be free of any virus, it is the recipient's responsibility to ensure that they are virus-free and no responsibility is accepted by The Civil Engineering Practice for any loss or damage arising in any way from receipt or use thereof.

The Civil Engineering Practice is GDPR compliant. The security of your data is important to us. Please contact us if you want to update, change, amend or remove your personal information.




Hi Martin,

I have just provided a response to planning regarding the discharge of conditions application for this site. I have attached a copy of this response for your information.

Kind regards,

Laura Gibbons



A



This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please send it back to us, and immediately and permanently delete it. Do not use, copy or disclose the information contained in this message or in any attachment. Whilst every care has been taken to check this e-mail for viruses, it is your responsibility to carry out checks upon receipt.