

From: Amanda Scholes on behalf of Planning.Responses
Sent: 19 November 2018 12:25
To: Planning Scanning
Subject: FW: Planning Consultation on A/82/18/DOC

From: Laura Gibbons
Sent: 19 November 2018 11:07
To: Planning.Responses
Cc: Michael Eastham
Subject: RE: Planning Consultation on A/82/18/DOC

Engineers comments regarding Condition 6- Surface water drainage

I recommend the discharge of this condition based on the information supplied.

Condition 7- maintenance manual

I recommend the discharge of this condition based on the information supplied.

Thanks,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses
Sent: 30 October 2018 12:19
To: Land Drainage
Subject: Planning Consultation on A/82/18/DOC

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION **A/82/18/DOC**
NO:

Registered: 23-MAY-18
Site Address: Quiet Waters Roundstone Lane Angmering BN16 4AX

Description of Works:

Approval of details reserved by condition imposed under A/132/17/OUT relating to conditions 5-details of materials & finishes of buildings, surfaces for roads/footpaths, means of enclosure & parking of vehicles, 6-surface water drainage, 7-SuDS details, 10-landscape & layout, 11-refuse & recycling bins, 12-car, motorcycle & cycle parking, 13-location of fire hydrants, 14- decentralised & renewable or low carbon energy source, 16-covered & secured cycle parking & 27-noise levels.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 13th November 2018.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Michael Eastham who can be contacted on telephone number [REDACTED]

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
