



Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex BN17 5LF
Planning General Enquiries
Tel: (01903) 737756 Fax: (01903) 730442
Dx: 57406 Littlehampton
Minicom: 01903 732765
e-mail: planning@arun.gov.uk
website: www.arun.gov.uk/planning

Future Planning and Development
2 Wardrobe Place
London
EC4R 1BB

Your Ref: A/82/18/DOC

Please ask for:

Michael Eastham

03 December 2018

Dear Mr Hutchinson

Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Order 2015
Approval of details reserved by condition imposed under A/132/17/OUT relating to conditions 5-
details of materials & finishes of buildings, surfaces for roads/footpaths, means of enclosure &
parking of vehicles, 6-surface water drainage, 7-SuDS details, 10-landscape & layout, 11-refuse &
recycling bins, 12-car, motorcycle & cycle parking, 13-location of fire hydrants, 14-decentralised &
renewable or low carbon energy source, 16-covered & secured cycle parking & 27-noise levels.
Quiet Waters Roundstone Lane, Angmering,

Notification regarding the above application:

Condition Number 13

No development hereby permitted shall be commenced until a scheme for the location and installation of fire hydrants has been submitted to and approved in writing by the Local Planning Authority. For the purposes of this condition the scheme shall be in accordance with the Guidance Note: The Provision of Fire Hydrants and an Adequate Water Supply for Fire Fighting as published by West Sussex Fire and Rescue Services (as amended from time to time). No building hereby permitted shall be occupied until the fire hydrant(s) required to serve that building have been installed in accordance with the approved scheme.

Reason: In order to provide adequate infrastructure for emergency services, in accordance with Policy GEN7 of the Arun District Local Plan. It is considered necessary for this to be a pre-commencement condition because of the need to ensure the safety of residents on the site.

Decision:

Arun District Council have decided to **APPROVE details reserved by this condition**
The following information submitted regarding Condition 13 imposed on the outline planning permission A/132/17/OUT: relating to a scheme for the location and installation of fire hydrants is approved and the condition is hereby discharged:

- Drawing Number 1006-ANG102F (Southmill) - Materials Layout
- A Fire Hydrant is located between Plot 15 and the apartment block.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning