




From: Russell McCourty [REDACTED]
Sent: 25 July 2017 12:22
To: Mark Jones
Cc: John Hinds
Subject: A/87/17/HH & A/88/17/L

Hi Mark,

Following comments from Ian Wightman, we have amended the main elevation as per the attached.

Proposed Wall

The main wall construction of the extension will be 215mm solid brick in English Bond pattern, tanked and internally insulated to bring it up to today's UK Building Regulations standard in accordance with Part L. This will make the external wall thickness approximately 290mm from outside of brick to inside of plaster.

Proposed Windows

Proposed windows and doors are to be hardwood, painted white and fitted with slim double-glazing (10-12mm). Window style to be in small panes as per the elevations (to match the existing main property).

Kind regards,
Russell McCourty ACIAT
Associate Director


11 The Parade, Willowhayne Crescent,
East Preston, West Sussex BN16 1NS



or visit our [Checkatrade](#) / [Checkaprofessional](#) site by scanning in the QR code below.



Checkaprofessional.com



COMPANY REG. 2369036
VAT NO: 587484873