

From: Jessica Riches <Jessica.Riches@arun.gov.uk>
Sent: 19 July 2022 14:05
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: A/90/22/DOC - Land North of Water Lane, Angmering

Hello,

Please could the below be uploaded as a further consultation response.

Jessica Riches *(She / Her)*
Principal Planning Officer,
Strategic Development Team, Planning

T: 01903 737852
E: jessica.riches@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd,
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



From: Kate Giddings <kate.giddings@arun.gov.uk>
Sent: 19 July 2022 14:04
To: Jessica Riches <jessica.riches@arun.gov.uk>
Subject: RE: A/90/22/DOC - Land North of Water Lane, Angmering

Hi Jessica,

Hope you're keeping well.

The additional information provided is helpful. The Remedial Method Statement (ref.: RMS-22115-21-341, dated April 2022) has been reviewed. It is understood from section 4.1.1 that this document will be supported by the remediation contractor's own method statement (to be prepared in due course) and other procedures specific to each demolition/remediation/groundworks contractor. The aforementioned report contains some specific detail but is lacking in other areas, therefore it cannot be considered to provide 'full details of the remediation measures required and how they are to be undertaken'. A satisfactory verification plan will stem from a completed remediation strategy consequently, Environmental Health is not currently able to recommend discharge of parts C and D of condition 33 of A/40/18/OUT.

Thank you,

Kate.

Kate Giddings

Senior Environmental Health Technical Officer, Environmental Health

T: 01903 737586

E: kate.giddings@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Road

Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

