

From: Bruce Taunton <Bruce.Taunton@arun.gov.uk>
Sent: 26 May 2021 15:00
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: RE: Planning Consultation on: A/92/21/DOC

I have read through the proposed Construction Method Statement for the above application and believe the Engineer has taken sufficient consideration for protection and maintaining stability of the existing building during the alteration process. This includes temporary works to enable construction of new foundations and floor slabs. The Engineer has also requested that the contractor provide a detailed method statement to them to ensure/demonstrate that the building stability is maintained throughout the works in line with their method statement.

Bruce Taunton
Principal Engineer Structures,
Engineering Services

T: 01903 737816
E: bruce.taunton@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Planning.Responses <Planning.Responses@arun.gov.uk>
Sent: 12 May 2021 11:49
To: Bruce Taunton <Bruce.Taunton@arun.gov.uk>
Subject: Planning Consultation on: A/92/21/DOC

To: **Engineers (structural)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: A/92/21/DOC
Registered: 10th May 2021
Site Address: Outbuildings at Decoy Barn Decoy Lane Angmering BN18 9QA
Description of Works: Approval of details reserved by condition imposed under ref A/17/18/PL relating to Condition No 3 - construction method statement and details.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you wish to make any comments click on the link www.arun.gov.uk/planning and click into ?Enter Comment? or if this is not possible email your response to planning.responses@arun.gov.uk by **26th May 2021**.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

Yours sincerely

Mrs A Gardner

Planning Case Officer- Arun District Council

Telephone: 01903 737529

Email: Anita.Gardner@arun.gov.uk

PLCOND00 (008) 2020