

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to www.arun.gov.uk/planning and click on Local Planning Application Finder

Sign up to our newsletter [here](#)



From: Ian Stocks [REDACTED] **On Behalf Of** FRS Water and Access

Sent: 30 June 2021 08:22

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Hydrant condition - A/96/21/PL Worthing Rugby Club, Beech Tree Childcare Roundstone Lane Angmering BN16 4AX

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

FAO: Rebecca Perris

Dear Rebecca,

Having viewed the plans for planning application A/96/21/PL, and wanted to inform you there is insufficient supply of water for firefighting in the area, the supply of water i.e. a fire hydrant should be within 90 metres of a commercial property, currently the nearest fire hydrant is 240 metres away.


I appreciate this is an additional portacabin to be used for teaching, therefore this is to inform you, the developer and the owner / occupier of the short fall. In the event of a fire there is a possibility the fire appliance may run out of water before the fire is extinguished. The Fire Appliance only carries a certain amount of water supply hoses, that is why we require a water supply within this distance. As the nearest fire hydrant is 240 metres plus away, the Fire Crew would need the attendance of another fire appliance to have sufficient water supply hoses to reach the hydrant.

Regards

Ian Stocks
Water & Access manager

Ian Stocks – Water and Access Manager
Water and Access Office
West Sussex Fire and Rescue Service [West Sussex County Council](#)

Living Our Values Every Day



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
