

This consultation from Environmental Health refers to BE/102/14/A.(not BE/103/14/A)

From: Anna Appleton
Sent: 08 October 2014 10:40
To: Planning.Responses
Subject: BE/103/14/A - Marks and Spencer, Arun Retail Park

I note that no comments were made regarding noise in the original planning application for this site. However, I would draw the applicants attention to the acoustic report by Lcp, Lee Cunningham Partnership, dated 30 January 2014 and submitted with the original application.

Paragraph 3.1.6 details appropriate noise levels for plant associated with the site based on background measurements taken and BS4142. In order to avoid possible noise disturbance to neighbours the levels set out in this paragraph if the acoustic report should be adhered to when plant and equipment is operating.

Should you have any queries please do not hesitate to contact me.

Regards

Anna Appleton

Anna Appleton | Environmental Health Team Leader, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37676 | External: +44 (0) 1903 737676 | E-mail: anna.appleton@arun.gov.uk Secure E-mail: aappleton@arun.gcsx.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.