



The only comment I would like to make, is that the applicant needs to ensure the pumping station compound shown in the north west corner of the site is kept at least 3 metres from the top of the bank of the boundary ditch.

Regards

Paul Cann
Principal Engineer (Drainage)



To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO: BE/103/19/RES

Registered: 01-OCT-19

Site Address: Land west of New Barn Lane Bersted PO21 5DN

Grid Reference:

Category: Plan Applicat'n

Description of Works: Approval of reserved matters following the grant of BE/77/16/OUT and BE/40/18/PL for 50 No. residential units with associated roads, drainage & other related infrastructure.

I am able to inform you that I have received an amendment to the above application dated 26th February 2020 relating to:- Revised plans

[Click here to view the plans and documents](#)

If you should wish to make further representations as a result of this amendment you should click the link below and then click on 'comment on this application'. Please make any further comment by 26th March 2020.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

[Click here to make further comments](#)

The officer dealing with this application is Raymond Cole who can be contacted on telephone number [REDACTED]

Thanking you in anticipation

Planning Case Officer

pmac21_email
