

Amber Willard

From: Nick Howard
Sent: 13 November 2020 10:46
To: Amber Willard
Subject: RE: BE/110/20/DOC

Morning Amber,

Thank you for your information. I had not seen this.

From the attached photos provided, in principle the kitchen ventilation extract system seems adequate but EH cannot verify this till the ventilation system is operational.

If this department receives a complaint about noise/odour from the ventilation system then EH shall investigate.

I was unsure if the flue has a cowl or not from the photo? I see the metal baffles will capture the grease but what odour controls are there within the kitchen ventilation extract system? Is there any technical data for the system from the manufacturer available for our records? and what noise mitigation properties are there in the system e.g. to reduce noise vibration? Could the applicant forward this information please.

Kind Regards

Nick Howard
Senior Environmental Health Officer
Environmental Health

T: [REDACTED]
E: [REDACTED]



Arun District Council, Civic Centre, Maltrovers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Amber Willard <[REDACTED]>
Sent: 13 November 2020 08:02
To: Nick Howard <[REDACTED]>
Subject: FW: BE/110/20/DOC

Hi

Please see response and photos received for BE/110/20/DOC for the extraction.

Still not sure if its enough.

Thanks

Amber

Amber Willard
Planning Officer



T: [REDACTED]
E: [REDACTED]

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Mick Browning [REDACTED]
Sent: 12 November 2020 13:26
To: Amber Willard [REDACTED]
Subject: Re: BE/110/20/DOC

Hi Amber,

Sorry for the delay, I had to self isolate and didnt have my laptop with me, all free again, was just the good old common cold!.

I have pictures of the equipment to be installed along with its location being indicated on the location plan in Blue ink. This shows that it is of the correct quality(Commercial grade), the grease interceptors are visible(although we are considering lambswool filter covers on the advice of In the Hoods as they catch approximately 90% of the grease and leaves the inside much cleaner) and the flue is also shown in the pictures. Measurements show that the flue will exit 4 metres from the upstairs dwelling, the top of the flue is level with the gutter height of the above property and fumes are blown straight up. It is also fitted with a water drain at the bottom, internal flaps to stop birds nesting and is also backed up by wire mesh being fitted to the top of the flue.

Kind Regards

Mick Browning

On Mon, 9 Nov 2020 at 10:09, Amber Willard [REDACTED] wrote:

Dear Mr Browning,

Apologies I have spoken with him again and he advised he still requires

detailed plans/drawings on the kitchen ventilation system. If anything like this was submitted for the previous application then please sent that across also and if you have any other documents which would provide details of the extraction system, including where it will be on the building.

Thanks

Amber

Amber Willard

Planning Officer



T:

E:



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



Sign up to our newsletter [here](#)

From: Mick Browning
Sent: 03 November 2020 22:14
To: Amber Willard
Subject: Re: BE/11

Hi Amber.

In the hoods are the firm that have checked the equipment through for me as it is second hand, they specialise in this equipment and I have used them as it is their field and could advise me whether it is fit for purpose.

I'm unsure what you mean about Mr Howard not having the details, I emailed him whilst he was in annual leave and on his return he thanked me for the detailed report, please can you clarify for me?.

I will use the plan to show you the detail of where the hood will be mounted and also where the exit will be.

I did put all of the specifications of the system to be installed on my initial application, do you want me to send them again?, I am happy to give you any information that you require. Please forgive me if this is incorrect, I'm not used to the planning process.

Kind regards

Mick

Sent from my iPhone

On 3 Nov 2020, at 16:05, Amber Willard <[REDACTED]> wrote:

Mr Browning,

I have contacted Nick Howard from Environmental Health but he said he has not received anything from you. Are you able to send it to me and I can pass it on?

I note it is to be supplied by 'In the Hoods', Do you happen to have any booklets from them which includes details of the extraction system which I can also send on.


If it is to be to the external elevation are you able to submit a plan or photo to show whereabouts it will be located.

Thanks

Amber

Amber Willard

Planning Officer



<image010.jpg>

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

<image011.jpg>

<image009.png>

<imag

Sign up to our newsletter [here](#)

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
