INDICATES ATTENUATION REQUIRED IN UNITS 6 AND 7 TO BE DONE BY OTHERS
SUBJECT TO DETAILED DESIGN (BY OTHERS

UNIT 7 (BY OTHERS) ATTENUATION TANK
DRAINED AREA: 1,157m²
145m³ STORAGE PROVIDED CELLULAR STORAGE CRATES
155m² x 1.0m DEEP.
TOP OF CRATE: 2.095 (APPROX)

UNIT 6 (BY OTHERS) ATTENUATION TANK
DRAINED AREA: 1,087m²
145m³ STORAGE PROVIDED CELLULAR STORAGE CRATES
155m² x 1.0m DEEP.
TOP OF CRATE: 2.095 (APPROX)

OIL INTERCEPTOR - OI-401
FULL RETENTION SEPARATOR (WITH ALARM). KLARGESTER NSFA150 OR SIMILAR APPROVED. SIZED ACCORDING TO EA DOCUMENT PPG3 AND INSTALLED IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS.
TREATMENT AREA = 6127m²
IL (IN) = 1.310
IL(OUT) = 1.210

INDICATES SW SPUR FOR FUTURE CONNECTION DRAINAGE TO BE DESIGNED BY OTHERS **TBC**

INDICATES DIFFUSER UNITS FOR DISCHARGE INTO SUB BASE

INDICATES LINK CONNECTION FOR UNIT 9 DRAINAGE

ATTENUATION TANK - AT-401
TO BE LOCATED BENEATH CAR PARK
SRP = 1 IN 100 YR + 40% CLIMATE CHANGE.
DRAINED AREA: 9,984m²
676m³ STORAGE PROVIDED IN SDS GEOLIGHT 400 CELLULAR STORAGE CRATES (OR SIMILAR APPROVED).
951m²(70.5m x 13.5m) x 0.75m DEEP.
TO BE INSTALLED IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS
CL = 2.670 (LOWEST POINT)
IL = 1.380
TOP OF TANK = 2.130
BASE OF TANK = 1.380

PERMEABLE PAVING - PP-01
STORAGE AND CONVEYANCE
TO BE LOCATED BENEATH CARPARK
SRP = 1 IN 100 YR + 40% CLIMATE CHANGE.
183m³ STORAGE PROVIDED IN OPEN GRADED CRUSHED ROCK (OGCR) TYPE 3 OR SIMILAR WITH MIN 30% VOIDS.
STORAGE DEPTH: 275mm MIN

SW-414 A15 CVR CL: 2.560 IL: 1.510
FW-407e B125 CVR CL: 2.560 IL: 0.850
FW-407d B125 CVR CL: 2.590 IL: 0.980
SW-413 A15 CVR CL: 2.590 IL: 1.700
SW-401 CATCHPIT D400 CVR CL: 2.620 IL: 1.700 SUMP: 1.400
FW-407a B125 CVR CL: 2.610 IL: 1.350
FW-407b B125 CVR CL: 2.610 IL: 1.150
FW-407c B125 CVR CL: 2.610 IL: 0.760
FW-408 D400 CVR CL: TBC IL (BD): -0.160 IL: -0.935
FW-407 B125 CVR CL: 2.610 IL: 0.140
FW-407 B125 CVR CL: 2.610 IL: 0.010
SW-402 CATCHPIT D400 CVR CL: 2.620 IL: 1.650 SUMP: 1.350
SW-403 CATCHPIT D400 CVR CL: 2.580 IL(225Ø): 1.800 IL(450Ø): 1.575 SUMP: 1.275
SW-410 B125 CVR CL: 2.630 IL(225Ø): 1.355 IL(450Ø): 1.130
SW-411 D400 CVR CL: TBC IL: 1.095
FW-406 B125 CVR CL: 2.590 IL: 0.150
FW-405 B125 CVR CL: 2.610 IL(BD): 1.290 IL: 0.250
FW-404 B125 CVR CL: 2.590 IL: 0.375
FW-404/01 B125 CVR CL: 2.800 IL: 1.800
FW-409 B125 CVR CL: 2.620 IL: 1.900
FW-404a B125 CVR CL: 2.620 IL: 0.315
SW-404 CATCHPIT D400 CVR CL: 2.590 IL(225Ø): 1.720 IL(450Ø): 1.495 SUMP: 1.195
SW-405 CATCHPIT D400 CVR CL: 2.690 IL: 1.390 SUMP: 1.085
SW-423 CATCHPIT D400 CVR CL: 2.900 IL: 1.965 SUMP: 1.665
SW-424 CATCHPIT D400 CVR CL: 2.830 IL: 1.905 SUMP: 1.515
SW-425 CATCHPIT D400 CVR CL: 2.830 IL: 1.870 SUMP: 1.570
SW-419 CATCHPIT D400 CVR CL: 2.870 IL: 1.640 SUMP: 1.340
SW-418 CATCHPIT D400 CVR CL: 2.660 IL(225Ø): 1.610 IL(450Ø): 1.460 SUMP: 1.085
SW-422 CATCHPIT D400 CVR CL: 2.580 IL: 1.580 SUMP: 1.280
SW-409 D400 CVR CL: 2.590 IL: 1.320
SW-407 D400 CVR CL: 2.540 IL: 1.700
SW-406 CATCHPIT D400 CVR CL: 2.620 IL(225Ø): 1.605 IL(450Ø): 1.380 SUMP: 1.080
SW-408 D400 CVR CL: 2.530 IL(225Ø): 1.560 IL(450Ø): 1.335
SW-416 CATCHPIT D400 CVR CL: 2.620 IL: 1.755 SUMP: 1.455
SW-417 D400 CVR CL: 2.750 IL: 1.660
SW-426 A15 CVR CL: 2.750 IL: 2.000
FW-404/02 B125 CVR CL: 2.800 IL: 2.000
FW-403 D400 CVR CL: 2.660 IL: 0.535
SW-421 D400 CVR CL: 2.690 IL: 1.720
SW-420 D400 CVR CL: 2.980 IL: 1.915
FW-402 D400 CVR CL: 2.900 IL: 1.550
SW-415 CATCHPIT D400 CVR CL: 2.600 IL: 1.825 SUMP: 1.525
FW-401 A15 CVR CL: 2.770 IL: 1.700

UNIT 6 FFL +2650
UNIT 5 FFL: 2.800
UNIT 8 FFL: 2.650
UNIT 4 FFL: 2.800
20 CAR PARKING SPACES
SEE UNIT 6 ATTENUATION NOTE
SEE UNIT 7 ATTENUATION NOTE
SEE FC-401 NOTE
FOR SECTIONS 1 AND 2 SEE DRAWING 7103
ROAD
FIN DRAIN
RECYFIX PLUS 150 DRAINAGE CHANNEL
ACO SUMP
MONOTEC 100 X 380
450Ø PERFORATED PIPE
FABDRAIN SUPER 150 F900 SLOTTED
FABDRAIN SUPER 150 F900 SOLID
INDICATES 300Ø T JUNCTION RODDING POINT (D400 CVR) FOR ACCESS TO SDS GEOLIGHT TANK
+3020

LEGEND

PROPOSED DRAINAGE - FOUL

- 100Ø@1:100 — FOUL WATER DRAIN - **CLAY** — Approx. gradient and diameter as noted, 100mm Ø UNO
- FW-01 — FOUL WATER MANHOLE — PC Ring REFER TO DETAILS FOR MANHOLE DIAMETER
- FW-01 — FOUL WATER INSPECTION CHAMBER — PVCu 450mm Ø. Max 1.2m depth - reduced access to 3.0m

Note: All internal foul MH's and IC's to have recessed covers. double sealed and locking to prevent odours. Refer to layout for location.

- SAC — FOUL WATER SHALLOW ACCESS CHAMBER — Max depth to invert 600mm from GL, 300mm Ø
- RE — FOUL RODDING EYE — Ø as noted

- YG — FOUL YARD GULLY (to be trapped) — Gully reference as noted on drawing. Cover grade to suit loading.
- FD — FLOOR DRAIN (to be trapped) — Internal use only, refer to architect for details / specification. Roddable from above slab into standard (01) fitting. Floor Drain / Gully to be kept charged to avoid odours.
- 01 & 01A — FOUL OUTLET / STACK POSITION — Shown indicative, refer to architect for setting out. All branches 100mm Ø UNO. 01 - Outlet connects into standard 90° rest bend. 01A - Indicates access required in above slab plumbing for rodding, refer to service engineers drawings for details. SVP - Indicates soil vent pipe by service engineer: with access.

PROPOSED DRAINAGE - STORM

- 150Ø@1:100 — STORM WATER DRAIN - **CLAY** — Approx. gradient and diameter as noted, 150mm Ø UNO
- SW-01 — STORM WATER MANHOLE — PC Ring - REFER TO DETAILS FOR MH DIAMETER
- SW-01 — STORM WATER INSPECTION CHAMBER — PVCu 450mm Ø. Max 1.2m depth - reduced access to 3.0m
- RE — STORM RODDING EYE — Ø as noted
- SILT TRAP
- CONCRETE ENCASEMENT TO PIPE — Refer to limits of cover table drawing 7101
- RAIN WATER OUTLET — Shown indicative, refer to architect for setting out. All branches 100mm Ø UNO. 01 - Outlet connects into standard 90° rest bend. 01A - Indicates access required in above slab plumbing for rodding, refer to service engineers drawings for details.
- 00.00 — PERMEABLE PAVING SUB BASE LEVELS — Refer to drawing 7300 for paving details

- AG — RAIN WATER OUTLET ACCESS GULLY — AG - Outlet connects to gully.
- RG — ROAD GULLY (to be trapped)
- YG — YARD GULLY (to be trapped)
- PG — PAVED AREA GULLY (to be trapped)
- DC — DRAINAGE CHANNEL (Refer to layout for specification)
- TH — THRESHOLD DRAINAGE CHANNEL (Refer to architect for details / specification)
- FIN DRAIN — FIN DRAIN — Refer to details for specifications) all pipes to be 150Ø UNO

Note: All internal foul MH's and IC's to have recessed covers. double sealed and locking to prevent odours. Refer to layout for location.

Note: All connections not made to manholes to be connected via oblique 45 degree junctions with the incoming connecting pipe positioned at 10 or 2 o'clock in section

KEYPLAN



NOTES

1. All dimensions are to be checked on site before the commencement of works. Any discrepancies are to be reported to Hydrock's Engineer for verification. Figured dimensions only are to be taken from the drawing.
2. The DWG file is issued for the purposes of coordination only and do not represent formal drawing issue and are not to be reprinted in any form. Formal issue of drawings is via DWF, Adobe PDF files and/or hard copies and their associated information issue sheets.
3. Whilst every effort has been made to ensure the accuracy of this survey, we do not recommend that you make due dimensional checks before using any DWG file information. Any errors found are to be reported to Hydrock immediately.
4. All levels are in metres above Ordnance Datum (mAOD).
5. All private drainage to comply with current Building Regulations, BS EN752 Drain and Sewer Systems outside Buildings and other relevant British Standards and Codes of Practices.
6. All external drainage within trafficked areas with less than 1.2m cover to have type 2 concrete bed and surround. All drainage with between 1.2m and 2.5m cover or under less than 0.6m to have type 2 concrete bed and surround. All drainage with greater cover than the minimum required to have type 5 bed and surround.
7. All drainage to be laid soffit to soffit unless otherwise shown.
8. The Contractor is to verify the line, level and diameter of existing sewers before commencing any work.
9. All foul drainage to be minimum 100mm diameter; all surface water drainage to be minimum 150mm diameter unless otherwise shown.
10. Where possible, all gullies are to be sited in permeable surface levels. It is the contractors responsibility to ensure that access covers and frames are set at the final surface levels.
11. Where possible the contractor is to orientate manhole biscuits and covers to locate them parallel to kerbs and gutters.
12. All drainage works should comply with Health & Safety Executive guidance HSG47 "Avoiding Danger from Underground Services" when excavating around existing services.
13. It is the contractors responsibility to determine the location and depth of all existing services prior to the commencement of any excavation.
14. Contractor to provide temporary screens in each of the down stream manholes during the construction period of the development in accordance with SFA 2.5.10 and the local sewerage undertakers requirements.
15. All in-situ concrete and precast concrete components to be manufactured using Sulphate Resisting Cement complying with BS 4027 (DC-3 mix minimum) if required, subject to soil conditions.
16. Manhole components to be to BS EN 1917:2002.
17. All ironwork to be kite marked by BSI or certified by equal inspection authority.
18. All new drainage pipes to be laid to the gradients shown between adjacent inspection manhole.
19. All new drainage pipes to be jetted, CCTV surveyed with DVD recording and any defects highlighted to the supervising officer. Following the rectification of any defects, the drain is to be re-surveyed with CCTV and the recordings made available to the project manager/engineer.
20. Prior to commencing the works the contractor is to confirm details of the existing drainage system as noted on the drawing.
21. Prior to commencing the works the contractor is to undertake the drainage investigation work as noted on the drawing.

REV						
	REVISION NOTES/COMMENTS					
	DRAWN BY	DATE	CHECKED BY	DATE	APPROVED BY	DATE
C06	AS BUILT ISSUE					
	J.SHIMMIN	27.07.21	D.GALLIMORE	27.07.21	J. MAGEE	27.07.21
C05	CONSTRUCTION ISSUE					
	J.SHIMMIN	28/06/21	D.GALLIMORE	28/06/21	M. GRIFFIN	28/06/21
C04	ISSUED FOR CONSTRUCTION					
	D. GALLIMORE	17/12/20	D.GALLIMORE	17/12/20	M. GRIFFIN	17/12/20
C03	ISSUED FOR CONSTRUCTION					
	D. GALLIMORE	23/10/20	D.GALLIMORE	23/10/20	M. GRIFFIN	23/10/20
C02	ISSUED FOR CONSTRUCTION					
	D. GALLIMORE	21/08/20	D.GALLIMORE	21/08/20	M. GRIFFIN	21/08/20
C01	ISSUED FOR CONSTRUCTION					
	D. GALLIMORE	24/07/20	D.GALLIMORE	24/07/20	M. GRIFFIN	24/07/20
P05	ISSUED FOR CONTRACT					
	D. GALLIMORE	04/05/20	D.GALLIMORE	04/05/20	M. GRIFFIN	04/05/20
P04	ISSUED FOR CONTRACT					
	R.HUNT	13/03/20	D.GALLIMORE	13/03/20	M. GRIFFIN	13/03/20
P03	DRAWING TITLE CHANGED					
	R.HUNT	24/02/20	D. GALLIMORE	24/02/20	M. GRIFFIN	24/02/20
P02	TENDER ISSUE					
	R.HUNT	21/02/20	D. GALLIMORE	21/02/20	M. GRIFFIN	21/02/20
P01	TENDER ISSUE					
	R.HUNT	20/12/19	D. GALLIMORE	20/12/19	M. GRIFFIN	20/12/19

Hydrock
Merchants' House North
Wapping Road
Bristol
BS1 4RW
t: +44 (0)117 945 9225
e: bristolcentral@hydrock.com

CLIENT
LANDLINK ESTATES

PROJECT
SALTBOX
BOGNOR REGIS

TITLE
UNITS 4, 5 AND 8
DRAINAGE LAYOUT

HYDROCK PROJECT NO.
C-13319-C

SCALE @ A1
1:250

STATUS DESCRIPTION
AS BUILT ISSUE

STATUS
A1

DRAWING NO. (PROJECT CODE-ORGINATOR-ZONE-LEVEL-TYPE-ROLE-NUMBER)
SAL-HYD-PH2-ZZ-DR-C-7010

REVISION
C06

ARUN DISTRICT COUNCIL BE/13/21/DOC