

Application No: BE/118/21/PL

I understand that when the original factory units were constructed the archaeological interest that the general area is known to contain was preserved through a combination of raising the level of the ground and the use of piled foundations. Provided that the construction of the proposed storage facility on the concrete hardstanding does not require significant continuous foundations it is unlikely that archaeological mitigation measures would be warranted.

James Kenny
Archaeology advisor
24/08/2021