

From: David Easton
Sent: 14 November 2018 13:07
To: Planning.Responses
Subject: BE/119/18/DOC

Please upload as a consultation response.

From: [REDACTED]
Sent: 14 November 2018 10:26
To: David Easton
Subject: BE/119/18/DOC

Dear David

I have reviewed the application BE/119/18/DOC and can confirm that we have been in consultation with the water undertaker (Portsmouth Water) and have agreed the submitted plan as attached to the condition 22 application compliance. The application shows the addition of the hydrant and adoption of a second washout hydrant to fitted by the water undertaker.


This completes the pre application condition as far as the FRS are concerned and we will await final installation notice to sign off the correct installation when appropriate.

Regards

David

David Boarer | Water and Access Manager, West Sussex County Council
Location: West Sussex Fire and Rescue Service, Bognor Regis Fire Station, West Mead Drive, Bognor Regis West Sussex PO21 5TB [REDACTED]

Living Our Values Everyday



Think sustainably. Do you have to print? Can you double side? Do you need colour?

--
This e-mail and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of

its content. West Sussex County Council takes steps to ensure e-mails and attachments are virus-free but you should carry out your own checks before opening any attachment.