

From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>

Sent: 07 December 2021 10:25

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Cc: Michael Eastham <Michael.Eastham@arun.gov.uk>

Subject: BE/121/21/RES-Unit 3 Land At Salt Box West of Shripney Road Bognor Regis PO22 9NW

Hi Michael,

I have reviewed the latest plans for this application. There still appears to be conflict between the proposed tree and drainage. As you suggested, it may be best to just replace this tree with hedging. We would recommend that the species is selected from the list within section 4 of the Southern Water tree planting guide, which can be found here: <https://www.southernwater.co.uk/media/1642/ds-tree-planting-guide.pdf>

Please ensure that the drainage plans are NOT listed as approved.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk [REDACTED]

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF