

Julie Grieves

From: Graham Evans
Sent: 11 October 2012 09:50
To: Planningecons
Subject: FW: Planning Consultation on: BE/127/12/A

I do not consider it likely that light intrusion arising from the proposed illuminated advertisement scheme will give rise to nuisance to nearby residential neighbours.

Certification should be sought from a suitably qualified lighting professional that light pollution arising from the scheme will be minimised, particularly as it is assumed that much of the lighting will operate throughout the night. I would recommend that the applicant is requested to confirm compliance with design guidance contained in "Guidance Notes for the Reduction of Obtrusive Light – Institution of Lighting Professionals 2011", and suggest that Environmental Zone E3 would be appropriate.

Graham Evans
Senior Environmental Health Officer
Arun District Council
01903 737694

From: Sam Humphries
Sent: 09 October 2012 13:47
To: Graham Evans
Subject: FW: Planning Consultation on: BE/127/12/A

C/N: 195124

From: planningecons@arun.gov.uk [<mailto:planningecons@arun.gov.uk>]
Sent: 09 October 2012 11:17
To: EH Planning Consultations
Subject: Planning Consultation on: BE/127/12/A

*******DO NOT CHANGE OR DELETE THIS EMAIL*******

To: Environmental Health - John Green

NOTIFICATION FROM ARUN DISTRICT COUNCIL
Town & Country Planning (Control of Advertisement) (England) Regulations 2007 (as amended)
Consent to Display an Advertisement(s)

APPLICATION BE/127/12/A
NO:
Registered: 11th September
2012

Site Address: Former LEC Site Shripney Way Bognor Regis PO22 9NQ

Grid Reference: 94300 101800

Description of Various non-illuminated & internally illuminated signage

Works:

The Council have received the above planning application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email

by 18-OCT-12.

You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:

www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Mr C Cronin who can be contacted on telephone number 01903 737776.

Regards

Planning Officer

consultee_email
