

[REDACTED]

From: Ben Daines [REDACTED]
Sent: 21 January 2019 10:49
To: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: RE: Planning Consultation on: BE/131/18/PL

Hi Simon,

Having now had chance to properly consider the engineer's drainage comments, I consider that the requirements of conditions 9 and 11 are excessive in relation to Phase 1. Phase 1 proposes a replacement dwelling rather than an additional dwelling and the existing dwelling on site could be demolished immediately upon completion of the new Phase 1 dwelling. Any additional impacts on surface water run-off would therefore surely be negligible.

To wait a full year in order to carry out ground water monitoring next winter would result in significant and unnecessary delays to the proposed development. I would be grateful if you could discuss this matter with the Council's engineer to explore a more proportionate way to address the requirements of Phase 1 without the need for ground water monitoring (condition 9). Additionally, Condition 11 refers to full details of the maintenance and management of the SuDS system, financial management, and the potential for a management company. The Phase 1 dwelling sits separately from the main development and the responsibility to ensure maintenance and management of the SuDS system will belong to the owner of the Phase 1 dwelling. Therefore the requirements of Condition 11 are unnecessary in relation to Phase 1.

Please let me know if you have any queries.

Kind Regards

Ben Daines MRTPI
Associate Planner

ECE Planning

ECE Planning are recruiting! – click [here](#) to read more



Brooklyn Chambers 11 Goring Road Worthing West Sussex BN12 4AP

Privacy/Confidentiality Statement
www.eceplanning.com

ECE Planning Limited, Registered in England No 07644833, Registered Office Amelia House, Crescent Road, Worthing, West Sussex BN11 1QR.

From: Simon Davis [<mailto:Simon.Davis@arun.gov.uk>]
Sent: 03 January 2019 15:12
To: Ben Daines
Subject: FW: Planning Consultation on: BE/131/18/PL

Hi Ben,

Please note the below drainage comments.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Laura Gibbons
Sent: 02 January 2019 16:01
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: RE: Planning Consultation on: BE/131/18/PL

Engineers comments regarding requested amendments to conditions 9, 10, 11 and 12

It is unclear what winter groundwater levels are at the site. If it is found that groundwater levels are too high to permit infiltration, or that infiltration is too slow even phase 1 will have to drain to the ditch. Without winter groundwater monitoring phase 1 wouldn't comply with building regulations approved document H. It is possible that the drainage of phase 1 and 2 will need to be interconnected. Therefore I do not recommend the alteration to conditions 9, 10 or 11. However, I am satisfied that the wording of condition 12 can be amended.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk
Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.