


PL- Consultation- Ecology Officer response

Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Our priorities...

 Improving the wellbeing of Arun	 Delivering the right homes in the right places	 Supporting our environment to support us	 Fulfilling Arun's economic potential	 Our core foundations	 
--	---	---	---	--	--

Connect with us: [Facebook](#) | [X](#) | [Instagram](#)

From: Daniel Vick <Daniel.Vick@arun.gov.uk>
Sent: 16 January 2026 16:13
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: BE/133/25/DOC


Please upload as Ecology response.

Daniel Vick
Team Leader (Development Management), Planning

T: 01903 737771
E: daniel.vick@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk





From: Jonathan Best <Jonathan.Best@arun.gov.uk>

Sent: 28 November 2025 14:30

To: Daniel Vick <Daniel.Vick@arun.gov.uk>

Subject: BE/133/25/DOC

Hi Dan,

The lighting specification lists the light temperature as 4000 kelvins. Guidance dictates that to be bat friendly the lighting temperature needs to be reduced to 3000K and ideally 2700K.

Could the applicant review and confirm if the lighting scheme will conform with the recommendations of the Institution of Lighting Professionals (ILP) "Guidance Notes for the Reduction of Obtrusive Light" (GN01:2011) and. "Bats and Artificial Lighting at Night" (GN08 2023).

Regards,

Jonathan Best MCIEEM
Ecology Officer, Planning Policy

T: 01903 737579

E: jonathan.best@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

