




From: Joanne Lewis <Joanne.Lewis@arun.gov.uk>
Sent: 21 October 2021 11:18
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: RE: Planning Consultation on: BE/151/21/PL

I have no objections to the proposals, however, the site is situated on an area of land which has been identified as being potentially contaminated and as excavations are required for foundations and cabling the following condition should be included on any permission granted;

Prior to commencement of the development hereby approved (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site shall each be submitted to and approved in writing by the Local Planning Authority:

1. A 'Preliminary Risk Assessment' which has identified: all previous (historical) uses; potential contaminants associated with those uses; a conceptual model of the site indicating sources, pathways and receptors; and potentially unacceptable risks arising from contamination at the site.
2. A 'Site Investigation Scheme', based on (1) above to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.
3. Based on the 'Site Investigation Scheme' and the detailed risk assessment (2), an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.

4. A 'Verification Report' providing details of the data that will be collected in order to demonstrate that the works set out in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Note: Any changes to these components, (1) to (4) require the express written consent of the Local Planning Authority.

The scheme shall be implemented as approved above and, prior to commencement of any construction work (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), a Verification Report demonstrating completion of the works set out in the approved remediation strategy and the effectiveness of that remediation shall be submitted to and approved in writing by the Local Planning Authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. The report shall also include a 'long-term monitoring and maintenance plan' for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action, as identified in the verification report, and for the reporting of this in writing to the Local Planning Authority.

Reason: To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

Please note that I work part time, usually between 09.30 and 14.45 Tuesday – Friday.

Joanne Lewis

Senior Environmental Health Officer,
Environmental Health

T: 01903 737666

E: joanne.lewis@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

I occasionally send emails outside of working hours. If this arrives outside your normal working hours, please do not feel compelled to respond immediately.

Sign up to our newsletter [here](#)



Business Support during Coronavirus click [here](#)

From: Planning.Responses <Planning.Responses@arun.gov.uk>

Sent: 14 October 2021 11:49

To: EHPlanningConsultations <EHPlanningConsultations@arun.gov.uk>

Subject: Planning Consultation on: BE/151/21/PL

To: **Environmental Health - Planning consultation**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Planning Permission

Application No: BE/151/21/PL
Registered: 14th October 2021
Site Address: McDonalds 3 Oldlands Way Bognor Regis PO22 9SA
Grid Reference: 494079 101290
Description of Works: Installation of one rapid electric vehicle charging station. This application is in CIL Zone 4 (zero rated) as other development.

The Council have received the above application.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 18th November 2021 . You can also monitor the progress of this application through the Council web site:

<https://www.arun.gov.uk/planning-application-search>

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website

<https://www.arun.gov.uk/development-plan> as can information on what comments we can consider

<https://www.arun.gov.uk/planning-application-comments>

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: <https://app.planninginspectorate.gov.uk/> but they will protect personal details.

In the absence of a reply within the period stated, I shall assume that you have no observations to make

Yours sincerely

Maria Tomalova

Planning Officer- Arun District Council

Telephone: 01903 737510

Email: maria.tomalova@arun.gov.uk

PLCONSULT (CDB) 2020