




From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 05 April 2022 08:51
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Maria Tomalova <Maria.Tomalova@arun.gov.uk>
Subject: RE: Planning Consultation on: BE/16/22/PL

Engineers Comments Regarding Surface Water Drainage

We note that the application is within Flood Zone 2/3, the Environment Agency should be consulted.

The application includes minor changes to impermeable area, due to the small scale of changes we have no conditions to request. We would encourage the use of permeable paving/ surfaces to infiltrate or attenuate as is found suitable whilst providing treatment at source.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

From: Planning.Responses <Planning.Responses@arun.gov.uk>

Sent: 04 March 2022 12:04

To: Land Drainage <Land.Drainage@arun.gov.uk>

Subject: Planning Consultation on: BE/16/22/PL

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Planning Permission

Application No: BE/16/22/PL

Registered: 22nd February 2022

Site Address: Arun Retail Park Shripney Road Bognor Regis PO22 9NF

Grid Reference: 494006 100808

Description of Works: External alterations to the existing building associated with the change of use from Class E Restaurant to Sui Generis (consisting of a coffee shop / restaurant selling food and drink for consumption on and off the premises), alterations to car park (including the creation of a drive-through lane, reconfiguration of cycle parking, new pedestrian crossings, and the increase in number of car parking spaces), relocation of footpath, removal of 4 x TPO trees (to be replaced), landscaping and associated works. This site is in CIL Zone 4 (Zero Rated) as other development.

The Council have received the above application.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 7th April 2022 . You can also monitor the progress of this application through the Council web site:

<https://www.arun.gov.uk/planning-application-search>

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website

<https://www.arun.gov.uk/development-plan> as can information on what comments we can consider

<https://www.arun.gov.uk/planning-application-comments>

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: <https://app.planninginspectorate.gov.uk/> but they will protect personal details.

In the absence of a reply within the period stated, I shall assume that you have no observations to make

Yours sincerely

Maria Tomalova

Planning Officer- Arun District Council

Telephone: 01903 737510

Email: maria.tomalova@arun.gov.uk

PLCONSULT (ODS) 2020