



To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 14 January 2022 11:29

To: Simon Davis <Simon.Davis@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: The Cottage Shripney Road Bognor Regis PO22 9PA - BE/176/21/PL

Planning Application Reference: BE/176/21/PL

Proposal: Demolition of existing dwelling and ancillary outbuildings and erection of a 66 bedroom care home with associated access, parking and landscaping. This site is in CIL Zone 3 (Zero Rated) as other development & is a Departure from the Development Plan.

Address: The Cottage Shripney Road Bognor Regis PO22 9PA

Dear Simon,

Environmental Health has no objection in principle to the above proposal, however the following matters must be considered.

Unexpected contamination

If during development, any visible contaminated or odorous material, (for example, asbestos containing material, stained soil, petrol / diesel / solvent odour, underground tanks or associated pipework) not previously identified, is found to be present at the site, no further development (unless otherwise expressly agreed in writing with the Local Planning Authority) shall be carried out until it has been fully investigated using suitably qualified independent consultant(s). The Local Planning Authority must be informed immediately of the nature and degree of the contamination present and a method statement detailing how the unsuspected contamination shall be dealt with must be prepared and submitted to the Local Planning Authority for approval in writing before being implemented.

If no such contaminated material is identified during the development, a statement to this effect must be submitted in writing to the Local Planning Authority.

Reason: To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

Electric Vehicle Charging Points

Prior to occupation of the development, a scheme for the provision of facilities to enable the charging of electric vehicles to serve the approved development shall be submitted to the local planning authority for approval and thereafter implemented in accordance with the approved details and the charge points shall thereafter be retained and maintained in good working condition.

Reason: New petrol and diesel cars/vans will not be sold beyond 2030, and to mitigate against any potential adverse impact of the development on local air quality, in accordance with policy QE DM3 (c) of the Arun Local Plan, Building Regulations Approved Document S, the Arun District Council Electric Vehicle Infrastructure Study (November 2017) and the National Planning Policy Framework (NPPF).

Construction

No development shall take place, including any works of demolition, until a Construction Management Plan has been submitted to, and approved in writing by, the Local Planning Authority. Thereafter the approved Plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters:

- a) An indicative programme for carrying out of the works;
- b) Details of the arrangements for public engagement / consultation both prior to and continued liaison during the construction works;
- c) Measures to minimise the noise (including vibration) generated by the construction process to include hours of work, proposed method of piling for foundations, the careful selection of plant and machinery and use of noise mitigation barrier(s);
- d) Details of any floodlighting, including location, height, type and direction of light sources and intensity of illumination;
- e) The parking of vehicles of site operatives and visitors;
- f) Loading and unloading of plant and materials, including permitted times for deliveries;
- g) Storage of plant and materials used in constructing the development;
- h) The erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate;
- i) The provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulations Orders);
- j) Measures to control the emission of dust and dirt during construction;
- k) A scheme for recycling / disposing of waste resulting from demolition and construction works i.e. no burning permitted.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Construction hours

No demolition/construction activities shall take place other than from 08:00 hours until 18:00 hours (Monday to Friday) and from 08:00 hours until 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays.

[In addition to these hours of working the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Control of fumes / odours / cooking smells

Prior to the first operation of the premises, a scheme and maintenance schedule for the extraction and treatment of fumes and odours generated from cooking or any other activity undertaken on the premises, shall be submitted to and approved in writing by the Local Planning Authority. Any equipment, plant or

process provided or undertaken in pursuance of this condition shall be installed prior to the first operation of the premises and these shall thereafter be operated and retained in compliance with the approved scheme.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Installation of Grease Traps in New Commercial Hot Food Premises

The drainage serving the kitchen(s) of the proposed care home shall be fitted with a grease trap / separator of a proportionate capacity to effectively contain grease residue arising from the estimated numbers of hot meals served and waste water flow rate.

The applicant shall provide the Local Planning Authority with details of their proposed grease trap / separator in order to demonstrate design and installation will be in compliance with BS EN 1825-1:2004 and BS EN 1825-2:2002 (Current Status: 'Under Review') or other effective means of grease removal.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Hours for Deliveries / vehicle movements

No goods shall be loaded, unloaded, stored or otherwise handled and no delivery vehicles shall arrive or depart, within the application site outside the hours 07:00 to 19:00 Monday to Friday, 08:00 to 18:00 Saturday or at any time on Sunday or Public or Bank Holidays.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

