

From: Amanda Scholes on behalf of Planning.Responses
Sent: 19 February 2020 09:05
To: Planning Scanning
Subject: FW: Be/17/20/DOC - Site 6, Chichester Road, North Bersted

Amanda Scholes | Receptionist, Department, [Arun District Council](#) | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)



Save the environment - think before you print.

From: Kate Giddings >
Sent: 18 February 2020 17:08
To: Amy Myer
Cc: Planning.Responses
Subject: Be/17/20/DOC - Site 6, Chichester Road, North Bersted

Hi Amy,

It is my understanding of the ADC Parking Standards Supplementary Planning Document that 100% of houses with garages or driveways shall have an electric vehicle charging point and that a certain percentage of other parking spaces should have active charge points. From the Site Layout Phase 4C document, it appears that there are five electric supply points to garages but it is not clear if this is solely the supply point or the actual charging point.

It is anticipated that every property with a garage or driveway will have their own electric vehicle charging point unless there is a justifiable reason as to why it is not possible. Furthermore, residents of flats and/or apartments should have access to a shared charging point, as per the percentage stated in the Parking Standards document.

Many thanks,

Kate.

Kate Giddings | Senior Technical Officer, Environmental Health, [Arun District Council](#) | Location: Arun Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

