

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Sign up to our newsletter **[here](#)**



From: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Sent: 30 March 2022 11:54
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Michael Eastham <Michael.Eastham@arun.gov.uk>
Subject: BE/20/22/DOC

Dear Planning,

Condition 4 – Lighting

1. Please could the applicant confirm whether or not they have referred to (ILE) Guidance Note 1 for the reduction of obtrusive light 2021 as this does not appear to be stated in the Relevant Standards and Guidance section?
2. The document alludes to the fact that the scheme is consistent with Zone E2 but does not directly state it (last 2 paragraphs on page 5). Please could the applicant confirm whether or not the scheme complies with Zone E2 or not?

Condition 28 – Acoustic Fencing

Environmental Health has no further comments and is satisfied that Condition 28 can be discharged.

Regards

Fiona Fitzgerald
Senior Environmental Health Officer
Environmental Health

T: 01903 737674
E: fiona.fitzgerald@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

