




Dear Michael,

In relation to the above application, please may EH comment as follows:

- the application does not include any detail of how dust generation will be minimised. The applicant should therefore provide a dust management plan in relation to potential impact on neighbouring properties, including an assessment of the nearest sensitive receptor(s);
- the proposed bund should be separated from the underlying soil/material (using, for example, a suitable barrier and/or membrane);
- No demolition/construction activities shall take place other than between 08.00 hours and 18.00 hours (Monday to Friday) and 08.00 hours and 13.00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays. **Reason:** To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031.

Many thanks,

Kate.



Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.