

[REDACTED]

From: Amanda Scholes on behalf of Planning.Responses
Sent: 23 April 2019 11:34
To: Planning Scanning
Subject: FW: BE/38/19/PL

From: Kate Giddings
Sent: 23 April 2019 10:32
To: Fiona Fitzgerald; Michael Eastham
Cc: Planning.Responses
Subject: RE: BE/38/19/PL

Good morning,

Thank you for forwarding this.

It is recommended that the bund material is kept separate from the underlying topsoil to prevent cross-contamination.

Many thanks,

Kate.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road,
Littlehampton, West Sussex, BN17 5LF

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Fiona Fitzgerald
Sent: 23 April 2019 09:41
To: Kate Giddings
Subject: FW: BE/38/19/PL

Hi,

Do you have any CL comments on this one? Could you pass them to Michael Eastham in Planning by Friday please?

Thanks

Fiona

From: Michael Eastham
Sent: 23 April 2019 09:30
To: Fiona Fitzgerald
Subject: RE: BE/38/19/PL

Hi Fiona,

Have the issues set out in your email below been addressed or does the applicant need to revise the Construction Management Plan (CMP) attached to this email?

Kind regards,

Michael

From: Fiona Fitzgerald
Sent: 15 April 2019 11:05
To: Planning.Responses
Cc: Michael Eastham
Subject: BE/38/19/PL

Dear Michael,

There is no mention of dust control or working hours for this application.

Please could the applicant advise measures that will be taken to ensure that dust from the stockpile does not affect local residents. This should include where they consider the nearest sensitive receptors to be.

Further, we would request a condition restricting the working hours to: 8.00am – 6pm Mondays to Fridays, 8.00am – 1pm Saturdays and no work on Sundays or Public Holidays.

I am waiting for a response from Kate Giddings in Environmental Health and will forward this to you when I receive it.

Regards

Fiona