

From: Daniel Vick
Sent: 22 March 2024 18:30
To: HOLDSWORTH, George (LPSOUTH)
Cc: WATSON, Mark (LPSOUTH); SMITH, Leanne (LPSOUTH); [REDACTED]
Subject: RE: Arun - Bersted - Next Steps
Attachments: llfa.pdf

Hello George,

Please see attached objection from the LLFA on our website. I do have the technical note from Martin at GTA but that would have arrived at a similar time to the response from the LLFA. There concerns seem to relate to mission information.

The LLFA have also raised concerns re ground water flooding – our maps show the site in the 50% to 75% risk zone. (or be reaching) the final total.

Daniel Vick
Team Leader (Development Management), Planning

T: 01903 737771
E: daniel.vick@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



From: HOLDSWORTH, George (LPSOUTH) [REDACTED]
Sent: Thursday, March 21, 2024 9:13 AM
To: Daniel Vick <Daniel.Vick@arun.gov.uk>
Cc: WATSON, Mark (LPSOUTH) [REDACTED] SMITH, Leanne (LPSOUTH)
[REDACTED] Philip Murphy [REDACTED] Malcolm Mayo [REDACTED]
Subject: RE: Arun - Bersted - Next Steps

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Morning Daniel,

From your out-of-office, I believe you are back in work today:

- Could I please ask for an urgent update on the below?

We've, again, done everything asked of us from our side and urgently need to know what your next steps are for this application?

Very happy to meet / have a call anytime today / tomorrow to discuss if easier?

My number is here if you just want to call [REDACTED]

Looking forward to hearing from you,

George

George Holdsworth

Development Manager

LOVELL

A MORGAN SINDALL GROUP COMPANY



Suite 8, Broadmade House, Farnham Business Park, Farnham, GU9 8QT
lovell.co.uk



From: HOLDSWORTH, George (LPSOUTH) [REDACTED]

Sent: 18 March 2024 14:25

To: Daniel Vick <Daniel.Vick@arun.gov.uk>

Cc: WATSON, Mark (LPSOUTH) [REDACTED] SMITH, Leanne (LPSOUTH)

[REDACTED] Philip Murphy [REDACTED] Malcolm Mayo [REDACTED]

Subject: Arun - Bersted - Next Steps

Good afternoon Daniel,

I understand our Engineer Martin Roberts has sent the attached to you in relation to closing the flooding query at North Bersted.

Please can you confirm your availability for a quick call between ourselves, to understand next steps?

- The following looks free for us:
 - o Tues 19th (tomorrow) – anytime before 12.30
 - o Thu 21st - between 12 and 2pm.
 - o Anytime Friday 22nd after 11am

Thanks,

George

George Holdsworth

Development Manager



A MORGAN SINDALL GROUP COMPANY

Suite 8, Broadmeade House, Farnham Business Park, Farnham, GU9 8QT
lovell.co.uk



The information in this e-mail is intended only for the named recipient and may be privileged or confidential. If you are not the intended recipient, please notify us immediately and do not copy, distribute or take any action based on the e-mail.

Although we have taken steps to ensure that this e-mail and attachments are free from any viruses, we advise that in keeping with good computing practice, the recipient should ensure that they are actually virus free.

Lovell Partnerships Limited Registered office: Kent House, 14-17 Market Place, London W1W 8AJ. Registered Number: 2387333

Ground Floor
Northleigh
County Hall
Chichester
West Sussex
PO19 1RH



Lead Local Flood Authority

Mr Vick
Planning and Building Control
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Date 7th March 2024

Dear Mr Vick,

RE: BE/40/22/PL – Former Bartons Infant School, Romney Broadwalk, Bersted, PO22 9BH

Thank you for your consultation on the above site, received on 13th February 2024. We have reviewed the application as submitted and wish to make the following comments.

This is a full planning application for the demolition of former school building and erection of 20 new dwellings and associated car parking, cycle parking and landscaping.

We **object** to this planning application in the absence of an acceptable Flood Risk Assessment (FRA) & Drainage Strategy relating to:

- The application is not in accordance with Policy W DM2 Flood risk and Policy W DM3 Sustainable Urban Drainage Systems in Arun Local Plan, paragraph 173 and 175 in NPPF and PPG Flood risk and coastal change.

Reason

To prevent flooding in accordance with National Planning Policy Framework paragraph 173, 175 and 180 by ensuring the satisfactory management of local flood risk, surface water flow paths, storage and disposal of surface water from the site in a range of rainfall events and ensuring the SuDS proposed operates as designed for the lifetime of the development.

We will consider reviewing this objection if the issues highlighted below are adequately addressed:

1. Although the FRA states calculations are in the appendices, they are not there. Calculations using up to date parameters (Cv value 1 and 45% climate change allowance) must be provided for:
 - 50% AEP rainfall event does not surcharge in the drainage network
 - 3.33% AEP rainfall event plus climate change does not flood outside the drainage network which is designed to hold water

- 1% AEP rainfall event plus climate change does not leave the application boundary or flood any part of a building or utility plant susceptible to water within the development boundary.
- Half drain down times must be provided and show that they are within 24 hours or 48 hours for lined features.
- Include a surcharged outfall to a watercourse or sewer. This surcharge level must be the 1% AEP flood event of the receiving watercourse if known or bank full or bank full if not already hydraulically modelled.


Note for LPA: I have emailed separately about sequential test and PPG update now considering all sources of flood risk.

Erection of flow control structures or any culverting of an ordinary watercourse requires consent from the appropriate authority, which in this instance is Arun District Council on behalf of West Sussex County Council. It is advised to discuss proposals for any works at an early stage of proposals.

Please note if the LPA decide to grant planning permission, we wish to be notified for our records should there be any subsequent surface water flooding that we may be required to investigate as a result of the new development.

Yours sincerely,

Eleanor Read
Flood Risk Management Team



Annex

The following documents have been reviewed, which have been submitted to support the application;

- Drainage Layout by GTA Civils & Transport, 21/06/2023, revision P7.
- Flood Risk Assessment by GTA Civils & Transport, 29/03/2022, corrected first issue

Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

To register to receive notifications of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>



From: [REDACTED]
Sent: Thursday, March 7, 2024 4:34 PM
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: Response to application BE/40/22/PL

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Please could the attached response be distributed to the relevant case officer.

Regards

Flood Risk Management

Please do not reply directly to this email.

Any formal reconsultation on the application should be directed to [REDACTED] but the responding officer can be contacted directly via email if there are any questions relating to this response.

LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
