



Mr J Salisbury
Rapleys
55 Spring Gardens
Manchester
M2 2BY

Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex, BN17 5LF

Tel: 01903 737500
Fax: 01903 730442
DX: 57406 Littlehampton
Minicom: 01903 732765
e-mail:



18 April 2019

Our Ref: BE/41/19/DOC

Please ask for:
David Easton
Planning Department
Direct Dial: 01903 737619

Dear Mr Salisbury,

Approval of details reserved by condition imposed under ref BE/61/13/ relating to Condition Nos 16 BREEAM report, 19 landscaping, 20 cycle/motorcycling parking, 22 car parking spaces, 23 archaeology and 26 remediation strategy.

Oldlands Farm, Steyning Way, Bognor Regis

Notification regarding the above application:

Condition 16 (outline permission)

Prior to the commencement of construction of a phase, written evidence will be submitted to and approved in writing by the Local Planning Authority that the development is registered with a BREEAM certification body and a pre-assessment report (or a design stage certificate with interim rating if available) has been submitted indicating that the development can achieve the BREEAM level "Very Good". The documentation will include an energy plan showing that a minimum of 10 percent of on-site energy will be produced by low and zero carbon technologies. The statement shall be approved by the Local Planning Authority and the building shall be constructed in accordance with the detailed scheme.

Prior to the occupation of each phase of the development a post construction review statement for that phase shall be submitted by the applicant including a BRE certified BREEAM final assessment and associated paper work and approved in writing by the Local Planning Authority

Reason: To reduce carbon dioxide and other greenhouse gas emissions and adapt to climate change in accordance with Policy GEN21 of the adopted Arun District Local Plan.


Decision:

Arun District Council have decided to **APPROVE details reserved by this condition**

The Condition is discharged in so far as it relates to the detail as specified within the Sustainability & Energy Statement (Reference: 19-E024-002) prepared by Ensphere Group Ltd on behalf of Hanbury (PM) Limited.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely,



Neil Crowther
Group Head of Planning