

From: Claire Potts <Claire.Potts@arun.gov.uk>
Sent: 08 October 2019 16:22
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: BE/42/19/DOC Oldlands Farm
Importance: High

Please can the additional details for BE/42/19/DOC be uploaded to the file.

Thanks

Claire

Claire Potts BSc MSc MSc MRTPI | Strategic Development Team Leader, Directorate of Place, Arun District Council | First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37698 | External: +44 (0) 1903 737698 E-mail: claire.potts@arun.gov.uk
Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.

From: Daniel Wheelwright [REDACTED]
Sent: 08 October 2019 16:15
To: Claire Potts <Claire.Potts@arun.gov.uk>; Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Subject: FW: BE/42/19/DOC Oldlands Farm
Importance: High

Hi Claire,

I understand that David has now left ADC. Please see email below providing the final detail to enable discharge of the surface water drainage conditions associated with this DOC application. I have directly copied in Laura to expedite the process, but I would be grateful if we can now get this finalised as soon as possible.

Kind regards

Daniel

Daniel Wheelwright
BA (Hons) MA MRTPI
Associate
Town Planning



RAPLEYS LLP



From: Daniel Wheelwright
Sent: 08 October 2019 16:10
To: 'David Easton'
Subject: RE: BE/42/19/DOC Oldlands Farm
Importance: High

Hi David,

On point 3, we confirm that the chamber was built in accordance with WSCC standards (see drawing 5278/38/14 Rev A of the attached). I would be grateful if discharge of these final conditions can now be confirmed.

Kind regards

Daniel

Daniel Wheelwright
BA (Hons) MA MRTPI
Associate
Town Planning



RAPLEYS LLP



From: David Easton [<mailto:David.Easton@arun.gov.uk>]
Sent: 04 October 2019 09:58
To: Daniel Wheelwright
Cc: Claire Potts
Subject: BE/42/19/DOC Oldlands Farm

Dear Daniel,

I have received the below comments from our drainage engineers confirm that the only outstanding matter is point (3) below.

1. ~~Groundwater being located 1-1.5m below ground level is insufficient justification for not using infiltration. Outside of source protection zones we do not require 1m clearance to groundwater level. Infiltration test results in the Hydrock report were all completed lower than anticipated ground water levels so unsurprisingly failed. The site has been raised as part of flood compensation works and as such infiltration has been dismissed across the site, this is the same for all parts of the site. It is therefore not possible to rely on infiltration methods and as such attenuation needs to be provided with flow control that will not interact with the flood plain i.e. no hydraulic linkage. Acknowledged that infiltration will not work due to works to raise site.~~

2. ~~The greenfield runoff rate for the road is less than 5l/s. It appears this rate was previously agreed due to concerns with the risks of blockage. The total discharge from the road and phase 1A should not exceed QBar Greenfield for these areas.~~

~~Noted, greenfield runoff rate recalculated to 8.8l/s and results provided as attached. Okay.~~

3. ~~Construction details for hydrobrake chambers need to be site specific as we need to review proposed elevations of overflows, etc.~~

~~Following remodelling no new hydrobrake chambers required, hence no detail required. Only the unit will need to be replaced in existing manhole to ensure restriction to 8.8l/s rather than 5l/s. No changes to existing manhole construction. Please provide as built detail then. As stated, we need to review elevations of overflows against calculations to ensure that flood risk is not being increased elsewhere.~~

4. ~~Are diffuser units really being proposed immediately next to one of the units, running down its entire length? Please confirm, I am unsure if this is actually intended to be a linear channel drain.~~

~~This has now been rationalised. Diffuser shown next to linear channel at outfall points (from channel). Okay.~~

5. ~~Please clearly show locations of linear channel drains on plan.~~

~~These are already shown as per the key. Okay.~~

6. ~~Can distinctions be made on plan between diffuser and collector units. With invert levels of each specified.~~

~~See change in key. Now colour delineates which are collector and which are diffuser. Table provided to show invert depths that will apply to all units, both collector and diffuser for clarity. Okay.~~

7. ~~A permeable sub-base is being specified to multiple areas of asphalt. The formation level of these areas is 800mm below surface, yet the formation level of permeable paving where the collector units are located is at 630mm depth. Are you not going to have 170mm of water permanently sat at the base of the tarmac roads?~~

~~Noted. Additional collector units added at lower side where there is a change in pavement construction to ensure there are no areas with permanent water levels, i.e. all freely drained. Okay.~~

8. ~~I have noticed that a surcharged outfall has not been modelled, apologies that I did not raise this previously. Please model with a surcharged outfall to anticipated flood level. Okay.~~

9. ~~Please provide manhole schedule printout or similar in MicroDrainage to enable cover levels to be checked. Okay.~~

I would be grateful if you could liaise with your drainage engineers to resolve this final point.

Many thanks,
David

David Easton | Principal Planning Officer, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37619 | External: +44 (0) 1903 737619 | E-mail: David.Easton@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

Rapleys LLP is registered as a Limited Liability Partnership in England and Wales. Registration No: OC308311
Registered Office at Falcon Road, Hinchingsbrooke Business Park, HUNTINGDON PE29 6FG
A full list of Members is available on our website or at any of our offices during normal business hours.
Regulated by RICS.

Rapleys LLP operates an Environmental Management System which complies with the requirements of ISO
14001:2004 Certificate No. EMS 525645

This email is not intended, nor shall it form part of any legally enforceable contract and any contract shall only be entered into by way of an exchange of correspondence by each party's solicitor. Where this Email message is sent in connection with a contentious issue, the contents are Without Prejudice.

This email has been scanned for email related threats and delivered safely by Mimecast.
For more information please visit <http://www.mimecast.com>
