

From: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Sent: 07 February 2022 09:36
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Michael Eastham <Michael.Eastham@arun.gov.uk>
Subject: BE/4/22/DOC

Dear Michael,

With regard to Condition 4 (Lighting) Environmental Health is **not** satisfied that this condition can be discharged. This is due to the fact that the applicant has referred to the lighting being compliant with the ILP Guidance for Reduction of Obtrusive Light Zone E3 (Medium District Brightness, Small Town Centre or Urban Location) whereas this location is E2 (Sparsely inhabited rural areas, village or relatively dark outer suburban locations).

With regard to Condition 28 (Acoustic Fencing) Environmental Health, for the avoidance of doubt, please could the applicant forward the site plan referred to, in order that the proposed location of the fence can be checked?

Regards

Fiona Fitzgerald
Senior Environmental Health Officer
Environmental Health

T: 01903 737674
E: fiona.fitzgerald@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)



