

From: Laura Gibbons
Sent: 09 May 2018 14:55
To: Planning.Responses
Subject: RE: Planning Consultation on BE/56/18/DOC

The proposed geocellular soakaway in the rear garden is proposed to be formed of 400mm deep geocells. The calculations show a maximum water depth of 421mm. Please increase the plan area of the soakaway to ensure modelled water depth is less than 400mm.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 08 May 2018 15:49
To: Land Drainage
Subject: Planning Consultation on BE/56/18/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL
TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION BE/56/18/DOC
NO:

Registered: 24-APR-18
Site Address: Land rear of 17 - 21 Greencourt Drive Bersted PO21 5EU

Description of Works: Approval of details reserved by condition imposed under
BE/138/16/OUT relating to condition 5-surface water drainage.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 22nd May 2018.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Zac Denton who can be contacted on telephone number 01903 737500 x37447.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
