

From: Ian Stocks [REDACTED] **On Behalf Of** FRS Water and Access
Sent: 06 May 2021 09:14
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: Planning consultation - BE/61/21/DOC Land At Salt Box West Of Shripney Road Bognor Regis PO22 9NW

FAO: Michael Eastham

Dear Michael,


Having viewed the documents attached to this consultation, details are required on the supply of water for firefighting in the form of fire hydrants for this site, to ensure it complies with the requirements of Approved Document – B Volume 2: 2019 edition B5 section 16. No information has been provided on this requirement and will need to be in place prior to any occupation of the units.

Regards

Ian Stocks

Ian Stocks – Water and Access Manager
Water and Access Office
West Sussex Fire and Rescue Service [West Sussex County Council](#)
Location: Bognor Fire Station, West Meads Drive, Bognor, PO21 5TB
[REDACTED]

Living Our Values Every Day



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.

.....