

Raymond Cole

From: Laura Gibbons <laura.gibbons@adur-worthing.gov.uk>
Sent: 14 October 2020 12:48
To: Raymond Cole
Subject: Re: FW: BE/70/20/DOC Drainage Planning Comments

Hi Ray,

I recommend the discharge of conditions 6, 7 and 8.

The groundwater monitoring was not completed at the site in question, and the applicant should note that such a lack of monitoring will not be accepted in the future and has only been permitted on this occasion due to the ground raising/ stabilising works that previously occurred.

Kind regards,

Laura Gibbons

Engineer, Adur & Worthing Councils

Phone: 01903 221374

Email: laura.gibbons@adur-worthing.gov.uk

Website: www.adur-worthing.gov.uk

Address: Facilities & Technical Services, Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA



This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please send it back to us, and immediately and permanently delete it. Do not use, copy or disclose the information contained in this message or in any attachment. Whilst every care has been taken to check this e-mail for viruses, it is your responsibility to carry out checks upon receipt.