

Zoe Toppin

From: Laura Gibbons
Sent: 08 September 2020 12:01
To: Planning.Responses
Cc: Simon Davis
Subject: BE/79/20/RES The Cottage Shripney

Engineers Comments Regarding Surface Water Drainage

The proposed changes to the layout are unlikely to have a significant impact upon drainage. Our comments from the previous application (BE/58/19/RES) therefore still apply and are detailed below.

Infiltration testing and groundwater monitoring results have been provided to us previously. Based on these results we believe a surface water drainage design is achievable and that details can be agreed at discharge of conditions stage.

If a culvert is found along Shripney Road when forming the access way we should be contacted immediately.

Regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk or laura.gibbons@adur-worthing.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF