

From: Joanne Lewis <Joanne.Lewis@arun.gov.uk>
Sent: 28 May 2021 07:07
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: RE: Planning Consultation on: BE/80/21/DOC

I refer to the application below to discharge conditions 11 - contamination and 12 - electric vehicle charging.

11 - contamination – comments to follow from the contaminated land specialist

12 - electric vehicle charging – the plan showing the number and location of EV points is acceptable but I can not see that any information on the type of charger to be installed has been submitted and without this I am unable to recommend discharge of this condition. Applicants should note that Environmental Health would be looking for a Mode 3, 7kW fast charger as a minimum.

Joanne Lewis

Please note that I work part time, usually between 09.30 and 14.30 Tuesday – Friday.

Joanne Lewis
Senior Environmental Health Officer,
Environmental Health

T: 01903 737666
E: joanne.lewis@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)



Business Support during Coronavirus click [here](#)

From: Planning.Responses <Planning.Responses@arun.gov.uk>
Sent: 25 May 2021 12:04
To: EHPlanningConsultations <EHPlanningConsultations@arun.gov.uk>
Subject: Planning Consultation on: BE/80/21/DOC

To: Environmental Health - Planning consultation

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: BE/80/21/DOC
Registered: 20th May 2021
Site Address: 47 South Way Bersted PO21 5EY
Description of Works: Approval of details reserved by condition imposed under BE/43/20/PL relating to Condition Nos 3 - materials & finishes, 4 - screen walls & fences, 5 - dustbin storage, 7 - covered & secure cycle parking, 9 - site set up during construction, 10 - surface water drainage, 11 - contamination and 12 - electric vehicle charging.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you wish to make any comments click on the link www.arun.gov.uk/planning and click into ?Enter Comment? or if this is not possible email your response to planning.responses@arun.gov.uk by **9th June 2021**.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

Yours sincerely

Maria Tomalova

Planning Case Officer- Arun District Council

Telephone: 01903 737510

Email: maria.tomalova@arun.gov.uk

PLCOND00 (ODS) 2020