

Paul Stack
Arun District Council
Development Control
1, Arun Civic Centre Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Our ref: HA/2011/112481/06-L01
Your ref: BE/84/12/DOC
Date: 20 July 2012

Dear Paul

**APPLICATION FOR APPROVAL OF DETAILS RESERVED BY CONDITION 11
OF PREVIOUSLY APPROVED BE/122/08
LAND AT LEC SITE SHRIPNEY ROAD BOGNOR REGIS PO22 9NQ**

Thank you for consulting us on the further information submitted.

Environment Agency Position

We do not recommend discharge of the surface water condition (condition 11).

We appreciate there are difficulties with a gravity system due to the necessary ground and cover levels. However, we feel there are other options available which should be fully explored before we would accept a pumped solution.

Notwithstanding the above we are pleased to see confirmation of the inclusion of coalescer filters on the separators. Therefore with regards to pollution prevention this is acceptable.

If you have any queries or require any further information please contact me.

Yours sincerely

**Catherine McLeod
Planning Liaison Officer
Environment Agency**

Direct dial 01903 703858
Direct e-mail PlanningSSD@environment-agency.gov.uk