



FW: Soakaway location BE/88/18/DOC

From Amanda Scholes <Amanda.Scholes@arun.gov.uk>
on behalf of
Planning.Responses <Planning.Responses@arun.gov.uk>
Date Mon 26/11/2018 12:52
To Planning Scanning <Planning.Scanning@arun.gov.uk>

From: Simon Davis
Sent: 26 November 2018 12:46
To: Planning.Responses
Subject: FW: Soakaway location BE/88/18/DOC

Further drainage comments

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |

Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Laura Gibbons
Sent: 19 November 2018 11:21
To: Simon Davis
Subject: RE: Soakaway location BE/88/18/DOC

Simon,

Comments Regarding Condition 3

The soakaway depth and size is fine. However there are still some points which need to be rectified. The plastic pipe which connects from the down pipe to the soakaway needs to have concrete bed and surround. Also, a catchpit needs to be provided upstream of the soakaway.

Condition 4

Happy to discharge this.

Condition 5

Happy to discharge this.

Kind Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltrovers Road, Littlehampton, BN17 5LF
Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk
Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.