

From: Laura Gibbons
Sent: 19 November 2018 11:21
To: Simon Davis
Subject: RE: Soakaway location BE/88/18/DOC

Simon,

Comments Regarding Condition 3

The soakaway depth and size is fine. However there are still some points which need to be rectified. The plastic pipe which connects from the down pipe to the soakaway needs to have concrete bed and surround. Also, a catchpit needs to be provided upstream of the soakaway.

Condition 4

Happy to discharge this.

Condition 5

Happy to discharge this.

Kind Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF
Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk
Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.