

From: Simon Davis
Sent: 05 December 2018 15:54
To: Planning.Responses
Subject: FW: BE/88/18/DOC

Further Drainage comments

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Laura Gibbons
Sent: 05 December 2018 15:49
To: Simon Davis
Subject: RE: BE/88/18/DOC

Hi Simon,

Can they be shown on plan please.

Thanks,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Simon Davis
Sent: 26 November 2018 17:32
To: Laura Gibbons
Subject: FW: BE/88/18/DOC

Hi Laura,

Is this email sufficient or do you need the catchpit and concrete bed & surround showing on a plan?

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: [REDACTED]
Sent: 26 November 2018 16:20
To: Simon Davis
Cc: Christopher Tomkins
Subject: BE/88/18/DOC

Dear Mr Davis

I am the builder undertaking the project for Mr Tomkins.

The engineers points will be carried out.

Back inlet gully will be used for all down pipes for surface water , and as foil drain practice they will be surrounded by concrete.

I can form an interception pit after the two surface water pipes have been joined in a manhole before the pipe enters the soak away crates.

I hope this answers these two questions raised.

I will also be bringing in the samples for the external items which are required to signed off by your self as listed to Mr Tomkins by yourself.

I will try to get them in to you as soon as possible so this is sorted prior to works commencing in April 2019.

If you have any questions please send them to [REDACTED] or mobile [REDACTED]

Address
84 Church Way
Pagham
Bognor Regis
PO214QS

Yours sincerely

Martin Stock
M P Stock Builders