

From: Simon Davis
Sent: 05 December 2018 15:54
To: 'MARTIN STOCK'
Cc: Christopher Tomkins
Subject: RE: BE/88/18/DOC

Dear Martin,

I have been advised by our drainage engineer that we will require the submission of drawings to show the catchpit and the other drainage works. We will not be able to discharge the condition unless we are sure of what is going into the ground and that it will be fit for purpose.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: MARTIN STOCK [REDACTED]
Sent: 26 November 2018 16:20
To: Simon Davis
Cc: Christopher Tomkins
Subject: BE/88/18/DOC

Dear Mr Davis

I am the builder undertaking the project for Mr Tomkins.

The engineers points will be carried out.

Back inlet gully will be used for all down pipes for surface water , and as foil drain practice they will be surrounded by concrete.

I can form an interception pit after the two surface water pipes have been joined in a manhole before the pipe enters the soak away crates.

I hope this answers these two questions raised.

I will also be bringing in the samples for the external items which are required to signed off by your self as listed to Mr Tomkins by yourself.

I will try to get them in to you as soon as possible so this is sorted prior to works commencing in April 2019.

If you have any questions please send them to [REDACTED]

Address
84 Church Way
Pagham
Bognor Regis
PO214QS

Yours sincerely

Martin Stock
M P Stock Builders