

From: Simon Davis
Sent: 04 January 2019 15:07
To: Planning Scanning
Subject: FW: soakaway pipe work details BE/88/18/DOC

Correspondence

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: MARTIN STOCK [REDACTED]
Sent: 04 January 2019 15:02
To: Simon Davis <[REDACTED]>
Subject: Re: soakaway pipe work details BE/88/18/DOC

Hi Simon will change the drawing and send them back in.

I'm sorting your samples which should be with in the next week or two depending on the samples turning up and the application will be sorted.

Thanks for your reply

Many thanks

Martin Stock

Sent from my iPhone

On 4 Jan 2019, at 14:31, Simon Davis [REDACTED] wrote:

Dear Martin,

Please see below comment and provide an amended drawing

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Laura Gibbons
Sent: 04 January 2019 14:22
To: Simon Davis [REDACTED]
Subject: RE: soakaway pipe work details BE/88/18/DOC

Hi Simon,

The drawing shows that the pipe bed and surround wouldn't meet our requirements. Please can the applicant ensure 150mm concrete bed and surround is provided. After this, I am happy with the proposals.

Kind Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)