

From: Laura Gibbons
Sent: 05 March 2019 12:05

Cc: Juan Baeza; David Easton
Subject: Drainage Consultation on: BE/137/18/PL and BE/91/18/PL

Charlie,

I have looked at the information you have provided for both of the above applications. Please can an as built survey be completed and submitted. I note that your contractor states the surface water drainage was constructed in accordance with the plans, but in reality this may not be the case, furthermore there is conflict between the two drawings submitted, so one of the drawings has to be wrong.

Getting an independent surveyor to attend site and complete the survey shouldn't be an onerous or expensive task. I would be unwilling to accept the proposals without this information.

Kind Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF
Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk
Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.